

APPENDIX 1J – SOUND TRANSMISSION RATINGS

Provide acoustic performance in accordance with the minimum requirements listed below

Adjacency between spaces	STC Class - Walls	STC Class - Floors
Between patient rooms	55	50
Between exam rooms	60	50
Between consultation/meeting rooms to patient/exam room	55	50
Between patient/exam rooms and public spaces i.e. lobby, staff room, activity room (excludes corridor serving exam room)	55	50
Between patient rooms and adjacent corridor	55	50
Between patient/ exam rooms and service areas i.e. elevator and elevator machine room, mechanical rooms on the same floor or above client rooms, offices, care stations	65	50
Between medication rooms and adjacent rooms/areas	50	50
Between consultation/meeting rooms to public space	55	50
Between toilet rooms and public space	50	50
Between exam rooms and conference rooms	50	50
Between conference rooms and public space	55	50
Between exam rooms and staff lounges	45	50
Between public space and staff lounges	40	50