

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling Acoustic Tile Pre-Finished Wall GWB Paint Floor Resilient Slip Resistant Base Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>E</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CL-01</td> </tr> </tbody> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	E	1	1065 x 2135	Solid Core	Plam	CL-01												
type	quantity	size	material	finish	Hardware Group																						
E	1	1065 x 2135	Solid Core	Plam	CL-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																									
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																									
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws		MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table> Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input checked="" type="checkbox"/> Clock	LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks
---	---

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:	quantity	mounting type	faucet type	control type	plumbing remarks										
quantity	mounting type	faucet type	control type	plumbing remarks												

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control
--

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>2</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td>1</td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	2	Television Outlets 1A/1C/1NC	1	Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input checked="" type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing
	quantity											
Telecommunication Outlets 2A/1I	2											
Television Outlets 1A/1C/1NC	1											
Patient Monitoring Outlets 2A Red Data Port												
Headwall Outlets 2PM/3A (per headwall)												

NURSE CALL: DS Duty Station MCS Full feature master control station EPCA Emergency Pull Cord station with Audio Other:	quantity 1
---	-----------------------

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Infant Abduction System <input checked="" type="checkbox"/> Patient Wandering System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB - Moisture and Mould Resistant Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																		
type	quantity	size	material	finish	Hardware Group																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	1	GFI
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: II Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control										
quantity	mounting type	faucet type	control type	plumbing remarks																	
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

- Intercom Station
- Video Intercom Station
- Overhead Paging (Pub Address)
- Teleconferencing

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Non-Skid
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	1065 x 2135	Solid Core	Plam	WR-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Lavatory	1	Wall Hung	Gooseneck	Electronic Control

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CL-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	CL-01
type	quantity	size	material	finish	Hardware Group										
A	1	914 x 2135	Solid Core	Plam	CL-01										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input checked="" type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds													
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												

MILLWORK:		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	
Upper Cabinets	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	
Lower Cabinets/Drawers	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Countertop:	min. length (mm)	finish	Custom:	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/>					finish
Washroom Vanity:				Patient Wardrobe: <input type="checkbox"/>					
				Mail Slots: <input type="checkbox"/>					

MECHANICAL REQUIREMENTS

HVAC: Type: II Remarks:	PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																		
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																			

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	2	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: <input type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PA-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	PA-01
type	quantity	size	material	finish	Hardware Group										
B	1	1065 x 2135	Solid Core	Plam	PA-01										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input checked="" type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds													
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												

MILLWORK:		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Countertop:	min. length (mm)	finish	Custom:		finish			
2400	2400	Solid Surfacing	Reception, Transaction Counter, or Care Team Station Desk:		<input checked="" type="checkbox"/> Solid Surfacing			
Washroom Vanity:			Patient Wardrobe:		<input type="checkbox"/>			
			Mail Slots:		<input type="checkbox"/>			

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																		
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																			

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	2	convenience
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input checked="" type="checkbox"/> Clock
LIGHTING: <input checked="" type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input checked="" type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks provide zone lighting controller.

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input checked="" type="checkbox"/> Intercom Station <input checked="" type="checkbox"/> Video Intercom Station <input checked="" type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing
	quantity											
Telecommunication Outlets 2A/1I	1											
Television Outlets 1A/1C/1NC												
Patient Monitoring Outlets 2A Red Data Port												
Headwall Outlets 2PM/3A (per headwall)												

NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>		quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:	
	quantity									
DS Duty Station										
MCS Full feature master control station										
EPCA Emergency Pull Cord station with Audio										
Other:										

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist	
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Infant Abduction System <input checked="" type="checkbox"/> Patient Wandering System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Slip Resistant
Base: Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

DOORS:

type	quantity	size	material	finish	Hardware Group

Door Hardware: Access Control
Other Features: Sidelight
 Integral Blinds
 Security Grille
 Laser Ready Integral Blinds

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	pneumatic tube
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Lighting:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

Lighting:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

Upper Cabinets	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter

Countertop: min. length (mm) 915 finish Plastic Laminate
Washroom Vanity: min. length (mm) Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Patient Wardrobe:
Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III
Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
Exhaust Required: Yes No Dedicated Exhaust
Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: provide nurse call connection to pneumatic tube

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </tbody> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	CR-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	1065 x 2135	Solid Core	Plam	CR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																									
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																									
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws		MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table> Countertop: min. length (mm) 10500 finish Solid Surfacing Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																					

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	2	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		2	charging stations
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

LIGHTING:
 Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks
 provide master zone lighting controller. Provide specialty lighting - LED under cabinet & cove lighting

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> </tbody> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:				quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control	
quantity	mounting type	faucet type	control type	plumbing remarks											
1	Wall Hung	Gooseneck	Electronic Control												
MEDICAL GASES: (Quantity)		Headwall 1		Headwall 2		Overhead Booms		Other							
		Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side										
Oxygen															
Medical Air															
Medical Vacuum															
Nitrous Oxide															
Nitrogen															
CO2															
Scavenging															
Laser Smoke Evac.															

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td>2</td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>			quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port	2	Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet																																				
	quantity																																															
Telecommunication Outlets 2A/1I	1																																															
Television Outlets 1A/1C/1NC																																																
Patient Monitoring Outlets 2A Red Data Port	2																																															
Headwall Outlets 2PM/3A (per headwall)																																																
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td>1</td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>			quantity	DS Duty Station		MCS Full feature master control station	1	EPCA Emergency Pull Cord station with Audio		Other:		<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td>1</td> <td>Code Blue</td> <td>Code White</td> <td>Staff Assist</td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>		quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist		VST: VoIP Staff Terminal/Station						Other					
	quantity																																															
DS Duty Station																																																
MCS Full feature master control station	1																																															
EPCA Emergency Pull Cord station with Audio																																																
Other:																																																
	quantity	feature 1	feature 2	feature 3	feature 4																																											
PS: Patient Station																																																
2/3B: 2/3 button station																																																
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist																																												
VST: VoIP Staff Terminal/Station																																																
Other																																																

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:	
VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:	

SECURITY SYSTEM: <input checked="" type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input checked="" type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	
--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	CR-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	1065 x 2135	Solid Core	Plam	CR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish 9,000 Solid Surfacing Washroom Vanity: min. length (mm) finish Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	2	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

- SECURITY SYSTEM:**
- Security Camera
 - Clinical Camera Monitor
 - Panic Duress - Wired
 - Security Camera Monitor
 - Clinical Camera
 - Infant Abduction System
 - Patient Wandering System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets: <input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers: <input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		

Countertop: min. length (mm) 2700 finish Plastic Laminate

Washroom Vanity: _____

Reception, Transaction Counter, or Care Team Station Desk: _____ finish _____

Patient Wardrobe: _____

Mail Slots: _____

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks: _____

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: _____

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout

Room Control Remarks: _____

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust

Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	4	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Boom:	Vital	Duplex	2	
	UPS			
	Normal			
	Conditional			
Boom:	Delayed Vital			
	Vital			
	UPS			
	Normal			
	Conditional			
Boom:	Delayed Vital			
	Vital			
	UPS			
	Normal			
	Conditional			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks: _____

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	4
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																																	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	
type	quantity	size	material	finish	Hardware Group																																																						
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																																					
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		Countertop: min. length (mm) finish 2,400 Solid Surfacing		Washroom Vanity: min. length (mm) finish Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																															
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																																																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																																																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																																																					

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>				quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																					
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																									

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>G</td> <td>1</td> <td>914 x 2135</td> <td>Aluminum</td> <td>Prefinished</td> <td>SL-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	G	1	914 x 2135	Aluminum	Prefinished	SL-01												
type	quantity	size	material	finish	Hardware Group																						
G	1	914 x 2135	Aluminum	Prefinished	SL-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 1500 finish Plastic Laminate Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/> finish																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;	
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack	<input type="checkbox"/> Intercom Station
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack	<input type="checkbox"/> Video Intercom Station
Patient Monitoring Outlets 2A Red Data Port		C – Coax	<input type="checkbox"/> Overhead Paging (Pub Address)
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call	<input type="checkbox"/> Teleconferencing
		PM- Patient Monitoring Outlet	

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	Acoustic Tile	Pre-Finished
Wall	GWB	Paint
Floor	Resilient	Slip Resistant
Base:	Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
B	1	914 x 2135	Solid Core	Plam	PA-01

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Countertop: min. length (mm) 3000 finish Plastic Laminate Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2	Duplex	1	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		2	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	2
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend; Intercom Station Video Intercom Station
A – Active/Allocated Data Port or Data Jack Overhead Paging (Pub Address)
I – Inactive/Unallocated Data Port or Data Jack Teleconferencing
C – Coax NC – Nurse Call
PM- Patient Monitoring Outlet

NURSE CALL:


	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Rubber		DOORS: type quantity size material finish Hardware Group  Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight, <input type="checkbox"/> Integral Blinds, <input type="checkbox"/> Security Grille, <input type="checkbox"/> Laser Ready Integral Blinds	
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input checked="" type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws		MILLWORK: Upper Cabinets <input type="checkbox"/> finish doors <input type="checkbox"/> combination doors & open <input type="checkbox"/> lockable <input type="checkbox"/> adjustable shelves <input type="checkbox"/> microwave shelf <input type="checkbox"/> Lower Cabinets/Drawers <input type="checkbox"/> finish doors <input type="checkbox"/> combination doors & open <input type="checkbox"/> lockable <input type="checkbox"/> adjustable shelves <input type="checkbox"/> microwave shelf <input type="checkbox"/> Options: <input type="checkbox"/> Standing Height Counter Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>	

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	15A/20A, 120V Housekeeping		3	crash cart
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting Checklist:
 Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks:

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																		
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																				
MEDICAL GASES: (Quantity)		Headwall 1 Nursing Side Non-Nursing Side		Headwall 2 Nursing Side Non-Nursing Side		Overhead Booms		Other												
Oxygen																				
Medical Air																				
Medical Vacuum																				
Nitrous Oxide																				
Nitrogen																				
CO2																				
Scavenging																				
Laser Smoke Evac.																				

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	3	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	OF-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>OF-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	OF-01												
type	quantity	size	material	finish	Hardware Group																						
A	1	914 x 2135	Solid Core	Plam	OF-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																						
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	1																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:
VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>OF-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	OF-01												
type	quantity	size	material	finish	Hardware Group																						
A	1	914 x 2135	Solid Core	Plam	OF-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																						
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	1																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:
VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>OF-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	OF-01												
type	quantity	size	material	finish	Hardware Group																						
A	1	914 x 2135	Solid Core	Plam	OF-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;	
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack	<input type="checkbox"/> Intercom Station
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack	<input type="checkbox"/> Video Intercom Station
Patient Monitoring Outlets 2A Red Data Port		C – Coax	<input type="checkbox"/> Overhead Paging (Pub Address)
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call	<input type="checkbox"/> Teleconferencing
		PM- Patient Monitoring Outlet	

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: material: <input type="checkbox"/> Washable Wall: material: <input type="checkbox"/> Washable Floor: material: <input type="checkbox"/> Non-Skid Base: material: <input type="checkbox"/> Flash Cove	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>B</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>KP-01</td> </tr> </table>	type	quantity	size	material	finish	Hardware Group	B	1	1220 x 2135	Solid Core	Plam	KP-01	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator																				
type	quantity	size	material	finish	Hardware Group																													
B	1	1220 x 2135	Solid Core	Plam	KP-01																													
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																																
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>Upper Cabinets</th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td><input checked="" type="checkbox"/></td> <td>Stainless Steel</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <th>Lower Cabinets/Drawers</th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td><input checked="" type="checkbox"/></td> <td>Stainless Steel</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table>			Upper Cabinets	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	<input checked="" type="checkbox"/>	Stainless Steel	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	<input checked="" type="checkbox"/>	Stainless Steel	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Upper Cabinets	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																											
<input checked="" type="checkbox"/>	Stainless Steel	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																											
Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																											
<input checked="" type="checkbox"/>	Stainless Steel	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																												

Countertop: min. length (mm): 5000 finish: Stainless Steel	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish: _____ Patient Wardrobe: <input type="checkbox"/> finish: _____ Mail Slots: <input type="checkbox"/> finish: _____
--	--

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="checkbox"/> III Remarks: _____	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> <tr> <td>1</td> <td>Counter</td> <td>Gooseneck</td> <td>Lever Blade</td> <td></td> </tr> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control		1	Counter	Gooseneck	Lever Blade	
quantity	mounting type	faucet type	control type	plumbing remarks												
1	Wall Hung	Gooseneck	Electronic Control													
1	Counter	Gooseneck	Lever Blade													
Other Fixtures: <input type="checkbox"/> Urinal: <input checked="" type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/> _____																

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: _____

VENTILATION: Relative Pressure: Equal Positive Negative Other: _____
 Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2	30A, 208Volt, 3 Phase	1	4 wire connection / future retherm units
	Conditional 3	30A, 208Volt, 1 Phase	1	3 wire connection / future retherm units
	Delayed Vital			
Vital	Duplex		2	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: locate 2/3B button at door

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Abuse Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB - Abuse Resistant	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>2</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </tbody> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	B	2	1220 x 2135	Solid Core	Plam	CR-01								
GWB	Washable																														
GWB - Abuse Resistant	Washable																														
Resilient	Slip Resistant																														
Flash Cove																															
type	quantity	size	material	finish	Hardware Group																										
B	2	1220 x 2135	Solid Core	Plam	CR-01																										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																													
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																													
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td></td> <td></td> </tr> </tbody> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm): 1800</td><td>finish: Solid Surfacing</td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm):</td><td>finish:</td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			min. length (mm): 1800	finish: Solid Surfacing	min. length (mm):	finish:	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																								
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																								
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>																										
min. length (mm): 1800	finish: Solid Surfacing																														
min. length (mm):	finish:																														

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>II</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"></table>	II	PLUMBING: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> </tbody> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control	
II												
quantity	mounting type	faucet type	control type	plumbing remarks								
1	Wall Hung	Gooseneck	Electronic Control									

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								1
Medical Air								1
Medical Vacuum								1
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

Gases adjacent to plinth

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

--

VENTILATION: Relative Pressure: Equal Positive Negative Other:

--

 Exhaust Required: Yes No Dedicated Exhaust Remarks:

--

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	2	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White	Staff Assist	
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

--

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB - Impact Resistant Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>C</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>SR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	C	1	1220 x 2135	Solid Core	Plam	SR-01												
type	quantity	size	material	finish	Hardware Group																						
C	1	1220 x 2135	Solid Core	Plam	SR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>																						
Countertop: min. length (mm) 1220 finish Stainless Steel Washroom Vanity: min. length (mm) _____ finish _____ Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> _____ finish _____ Patient Wardrobe: <input type="checkbox"/> _____ finish _____ Mail Slots: <input type="checkbox"/> _____ finish _____																											

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Counter</td> <td>Gooseneck</td> <td>Lever Blade</td> <td>10" deep sink</td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Counter	Gooseneck	Lever Blade	10" deep sink
quantity	mounting type	faucet type	control type	plumbing remarks							
1	Counter	Gooseneck	Lever Blade	10" deep sink							
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>											

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other: _____
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2	Quad	6	provide recep. on 1 m centers mounted at 1400mm AFF
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	0
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB - Impact Resistant Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>C</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	C	1	1220 x 2135	Solid Core	Plam	CR-01												
type	quantity	size	material	finish	Hardware Group																						
C	1	1220 x 2135	Solid Core	Plam	CR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3																									
ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																									
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2	Quad	6	provide recep. on 1 m centers mounted at 1400mm AFF
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks			
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>G</td> <td>2</td> <td>1220 x 2135</td> <td>Aluminum</td> <td>Prefinished</td> <td>AO-01</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	G	2	1220 x 2135	Aluminum	Prefinished	AO-01								
GWB	Washable																														
GWB - Moisture and Mould Resistant	Washable																														
Resilient	Slip Resistant																														
Flash Cove																															
type	quantity	size	material	finish	Hardware Group																										
G	2	1220 x 2135	Aluminum	Prefinished	AO-01																										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																													
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input checked="" type="checkbox"/> Ceiling IV Track																													
MILLWORK: <table border="1" style="width:100%;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td></td> <td></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm): 3000</td><td>finish: Solid Surfacing</td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm):</td><td>finish:</td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			min. length (mm): 3000	finish: Solid Surfacing	min. length (mm):	finish:	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																								
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																								
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>																										
min. length (mm): 3000	finish: Solid Surfacing																														
min. length (mm):	finish:																														

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>II</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"></table>		II	PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>		quantity	mounting type	faucet type	control type	plumbing remarks	Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control																																																																				
II																																																																																		
quantity	mounting type	faucet type	control type	plumbing remarks																																																																														
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control																																																																														
MEDICAL GASES: <table border="1" style="width:100%; text-align: center;"> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="2">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> </tr> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </table> Medical Gas Remarks: <table border="1" style="width:100%;"></table>		(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			Oxygen								Medical Air								Medical Vacuum								Nitrous Oxide								Nitrogen								CO2								Scavenging								Laser Smoke Evac.								ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <table border="1" style="width:100%;"><tr><td>BMS Monitor and Control</td></tr></table>		BMS Monitor and Control
(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other																																																																											
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																														
Oxygen																																																																																		
Medical Air																																																																																		
Medical Vacuum																																																																																		
Nitrous Oxide																																																																																		
Nitrogen																																																																																		
CO2																																																																																		
Scavenging																																																																																		
Laser Smoke Evac.																																																																																		
BMS Monitor and Control																																																																																		

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White	Staff Assist	
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

locate 2/3B button at door

VENTILATION: Relative Pressure: Equal Positive Negative Other:

 Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:
 Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>B</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	B	1	1220 x 2135	Solid Core	Plam	CR-01				
GWB	Washable																										
GWB	Washable																										
Resilient	Slip Resistant																										
Flash Cove																											
type	quantity	size	material	finish	Hardware Group																						
B	1	1220 x 2135	Solid Core	Plam	CR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																									
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																									
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: min. length (mm) <input type="text" value="0"/> finish <input type="text"/> Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish <input type="text"/> Washroom Vanity: <input type="text"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/> <input type="text"/>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <input style="width:100%; height:50px;" type="text"/>		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>		quantity	mounting type	faucet type	control type	plumbing remarks																																																																									
quantity	mounting type	faucet type	control type	plumbing remarks																																																																													
MEDICAL GASES: <table border="1" style="width:100%; text-align: center;"> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="2">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th> </th> <th> </th> </tr> <tr><td>Oxygen</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Medical Air</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Medical Vacuum</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Nitrous Oxide</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Nitrogen</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>CO2</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Scavenging</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Laser Smoke Evac.</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table> Medical Gas Remarks: <input style="width:100%; height:20px;" type="text"/>		(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			Oxygen								Medical Air								Medical Vacuum								Nitrous Oxide								Nitrogen								CO2								Scavenging								Laser Smoke Evac.								ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <input style="width:100%; height:20px;" type="text" value="BMS Monitor and Control"/>	
(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other																																																																										
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																													
Oxygen																																																																																	
Medical Air																																																																																	
Medical Vacuum																																																																																	
Nitrous Oxide																																																																																	
Nitrogen																																																																																	
CO2																																																																																	
Scavenging																																																																																	
Laser Smoke Evac.																																																																																	

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </table>			quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet																																					
	quantity																																																
Telecommunication Outlets 2A/1I	1																																																
Television Outlets 1A/1C/1NC																																																	
Patient Monitoring Outlets 2A Red Data Port																																																	
Headwall Outlets 2PM/3A (per headwall)																																																	
NURSE CALL: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>DS Duty Station</td> <td>1</td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other: _____</td> <td></td> </tr> </table>			quantity	DS Duty Station	1	MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other: _____		<table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																																
DS Duty Station	1																																																
MCS Full feature master control station																																																	
EPCA Emergency Pull Cord station with Audio																																																	
Other: _____																																																	
	quantity	feature 1	feature 2	feature 3	feature 4																																												
PS: Patient Station																																																	
2/3B: 2/3 button station																																																	
4B: 4 button station (single gang)																																																	
VST: VoIP Staff Terminal/Station																																																	
Other																																																	
ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <input style="width:100%; height:20px;" type="text" value="BMS Monitor and Control"/>		IMIT Remarks: <input style="width:100%; height:20px;" type="text"/>																																															

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input checked="" type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="text"/> Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <input style="width:100%; height:20px;" type="text"/>	
---	--

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	
---	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: material <input type="text" value="GWB"/> finish <input type="text" value="Washable"/> Wall: material <input type="text" value="GWB - Moisture and Mould Resistant"/> finish <input type="text" value="Washable"/> Floor: material <input type="text" value="Resilient"/> finish <input type="text" value="Slip Resistant"/> Base: material <input type="text" value="Flash Cove"/>	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>B</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CL-02</td> </tr> </table>	type	quantity	size	material	finish	Hardware Group	B	1	1220 x 2135	Solid Core	Plam	CL-02	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:30%;"> WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator </td> <td style="width:30%;"> WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature </td> <td style="width:30%;"> MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3 </td> <td style="width:30%;"> ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track </td> <td style="width:30%;"> HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws </td> </tr> </table>	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws
type	quantity	size	material	finish	Hardware Group														
B	1	1220 x 2135	Solid Core	Plam	CL-02														
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws															

MILLWORK: Upper Cabinets: <input checked="" type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/>	finish: <input type="text" value="Stainless Steel"/> doors: <input type="checkbox"/> combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/>	Options: <input type="checkbox"/> Standing Height Counter	Countertop: min. length (mm) <input type="text" value="2400"/> finish <input type="text" value="Stainless Steel"/> Washroom Vanity: <input type="text"/>	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>	Custom: <input type="text"/> finish <input type="text"/>
---	--	--	---	---	--

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <input type="text"/>	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> <tr> <td>Utility</td> <td>1</td> <td>Counter</td> <td>Gooseneck</td> <td>Lever Blade</td> </tr> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control	Utility	1	Counter	Gooseneck	Lever Blade	Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input checked="" type="checkbox"/> Macerator: <input checked="" type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>
quantity	mounting type	faucet type	control type	plumbing remarks													
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control													
Utility	1	Counter	Gooseneck	Lever Blade													

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:	<input type="checkbox"/> Room Temp Control with Local Adjustment and Readout	<input type="checkbox"/> Room Relative Humidity with Local Readout	<input type="checkbox"/> Room Pressure Monitor with Local Readout	Room Control Remarks: <input type="text" value="BMS Monitor and Control"/>
-----------------------	--	--	---	--

VENTILATION:	Relative Pressure: <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="text"/>	Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Dedicated Exhaust	Remarks: <input type="text"/>
---------------------	---	---	--	-------------------------------

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock	LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input checked="" type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting	lighting remarks <input type="text"/>
--	--	--

TECHNOLOGY REQUIREMENTS


IMIT SYSTEMS:	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet
	quantity											
Telecommunication Outlets 2A/1I	1											
Television Outlets 1A/1C/1NC												
Patient Monitoring Outlets 2A Red Data Port												
Headwall Outlets 2PM/3A (per headwall)												

NURSE CALL:	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>DS Duty Station</td> <td>1</td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other: <input type="text"/></td> <td></td> </tr> </table>		quantity	DS Duty Station	1	MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other: <input type="text"/>		<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing
	quantity											
DS Duty Station	1											
MCS Full feature master control station												
EPCA Emergency Pull Cord station with Audio												
Other: <input type="text"/>												

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

SECURITY SYSTEM:	<input type="checkbox"/> Security Camera	<input type="checkbox"/> Panic Duress - Wired	<input type="checkbox"/> Clinical Camera	<input checked="" type="checkbox"/> Patient Wandering System	<input type="checkbox"/> Clinical Camera Monitor	<input type="checkbox"/> Security Camera Monitor	<input type="checkbox"/> Infant Abduction System	IMIT Remarks: <input type="text"/>
-------------------------	--	---	--	--	--	--	--	------------------------------------

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: type quantity size material finish Hardware Group  Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight, <input type="checkbox"/> Integral Blinds, <input type="checkbox"/> Security Grille, <input type="checkbox"/> Laser Ready Integral Blinds	
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input checked="" type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws		MILLWORK: Upper Cabinets <input type="checkbox"/> finish doors <input type="checkbox"/> combination doors & open <input type="checkbox"/> lockable <input type="checkbox"/> adjustable shelves <input type="checkbox"/> microwave shelf <input type="checkbox"/> Lower Cabinets/Drawers <input type="checkbox"/> finish doors <input type="checkbox"/> combination doors & open <input type="checkbox"/> lockable <input type="checkbox"/> adjustable shelves <input type="checkbox"/> microwave shelf <input type="checkbox"/> Options: <input type="checkbox"/> Standing Height Counter Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>	

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off

Headwall

Clock

LIGHTING:

Workstation Task Light

Bedside Staff Light

Visitor Light

Night Light

Vanity Light

In Use Light Laser and/or X-ray

Zone Controller

Colour Tunable

Reading Light

Hand Hygiene Sink Light

Examination Light

Shower Light

Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																		
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																				
MEDICAL GASES: (Quantity)		Headwall 1		Headwall 2		Overhead Booms		Other												
		Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side															
Oxygen																				
Medical Air																				
Medical Vacuum																				
Nitrous Oxide																				
Nitrogen																				
CO2																				
Scavenging																				
Laser Smoke Evac.																				
Medical Gas Remarks:																				

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td></td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>			quantity	Telecommunication Outlets 2A/1I		Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet																																					
	quantity																																																
Telecommunication Outlets 2A/1I																																																	
Television Outlets 1A/1C/1NC																																																	
Patient Monitoring Outlets 2A Red Data Port																																																	
Headwall Outlets 2PM/3A (per headwall)																																																	
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>			quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:		<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																																
DS Duty Station																																																	
MCS Full feature master control station																																																	
EPCA Emergency Pull Cord station with Audio																																																	
Other:																																																	
	quantity	feature 1	feature 2	feature 3	feature 4																																												
PS: Patient Station																																																	
2/3B: 2/3 button station																																																	
4B: 4 button station (single gang)																																																	
VST: VoIP Staff Terminal/Station																																																	
Other																																																	
ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control		IMIT Remarks:																																															

VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other:		Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:	
---	--	--	--

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	
--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB	Washable
Wall	GWB - Impact & Moisture and Mould Resistant	Washable
Floor	Resilient	Non-Skid
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
C	1	1220 x 2135	Solid Core	Plam	CR-01

Door Hardware: Access Control

Other Features:
 Sidelight
 Integral Blinds
 Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	3	Locate HK outlets at 1400mm AFF
	Normal 2	Duplex	1	GFI
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

	quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control	
Janitorial	1	Floor	Standard	Lever Blade	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: Detergent Dispenser

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>	GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>C</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	type	quantity	size	material	finish	Hardware Group	C	1	1220 x 2135	Solid Core	Plam	CR-01
GWB	Washable																				
GWB - Moisture and Mould Resistant	Washable																				
Resilient	Slip Resistant																				
Flash Cove																					
type	quantity	size	material	finish	Hardware Group																
C	1	1220 x 2135	Solid Core	Plam	CR-01																
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																	

MILLWORK: Upper Cabinets: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/>	finish doors combination doors & open lockable adjustable shelves microwave shelf	Options: <input type="checkbox"/> Standing Height Counter	Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr></table>	min. length (mm)	finish	min. length (mm)	finish	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>
min. length (mm)	finish							
min. length (mm)	finish							

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>III</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td></td></tr></table>	III		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control	
III													
quantity	mounting type	faucet type	control type	plumbing remarks									
1	Wall Hung	Gooseneck	Electronic Control										

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

--

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other:

--

 Exhaust Required: Yes No Dedicated Exhaust Remarks:

--

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

- Intercom Station
- Video Intercom Station
- Overhead Paging (Pub Address)
- Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	0
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	0				
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

--

- SECURITY SYSTEM:**
- Security Camera
 - Clinical Camera Monitor
 - Panic Duress - Wired
 - Security Camera Monitor
 - Clinical Camera
 - Infant Abduction System
 - Patient Wandering System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>F</td> <td>1</td> <td>1530 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	F	1	1530 x 2135	Solid Core	Plam	PR-01												
type	quantity	size	material	finish	Hardware Group																						
F	1	1530 x 2135	Solid Core	Plam	PR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input checked="" type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input checked="" type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input checked="" type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 600 finish Solid Surfacing Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Plastic Laminate Patient Wardrobe: <input checked="" type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex at headwall & 1 duplex for bed
UPS	Duplex		3	2 duplex at HW & 1 duplex above bed non-nursing side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input checked="" type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input checked="" type="checkbox"/> Headwall <input checked="" type="checkbox"/> Clock
LIGHTING: <input checked="" type="checkbox"/> Workstation Task Light <input checked="" type="checkbox"/> Bedside Staff Light <input checked="" type="checkbox"/> Visitor Light <input checked="" type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input checked="" type="checkbox"/> Reading Light <input checked="" type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: II Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control	
quantity	mounting type	faucet type	control type	plumbing remarks							
1	Wall Hung	Gooseneck	Electronic Control								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:											

MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="2">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> </tr> </thead> <tbody> <tr> <td>Oxygen</td> <td>1</td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Medical Air</td> <td>1</td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Medical Vacuum</td> <td>1</td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Nitrous Oxide</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Nitrogen</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>CO2</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Scavenging</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Laser Smoke Evac.</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>	(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			Oxygen	1	1						Medical Air	1	1						Medical Vacuum	1	1						Nitrous Oxide								Nitrogen								CO2								Scavenging								Laser Smoke Evac.							
(Quantity)		Headwall 1		Headwall 2		Overhead Booms			Other																																																																					
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																										
Oxygen	1	1																																																																												
Medical Air	1	1																																																																												
Medical Vacuum	1	1																																																																												
Nitrous Oxide																																																																														
Nitrogen																																																																														
CO2																																																																														
Scavenging																																																																														
Laser Smoke Evac.																																																																														

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC	1	I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port	0	C – Coax
Headwall Outlets 2PM/3A (per headwall)	1	NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Code White	Patient Assist	
2/3B: 2/3 button station					
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist	
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White		
Other					

IMIT Remarks: Locate 2/3b at entrance to room

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Waterproof Cover.</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>	GWB - Moisture and Mould Resistant	Washable	GWB - Moisture and Mould Resistant	Waterproof Cover.	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PW-01</td> </tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	type	quantity	size	material	finish	Hardware Group	A	1	1065 x 2135	Solid Core	Plam	PW-01
GWB - Moisture and Mould Resistant	Washable																				
GWB - Moisture and Mould Resistant	Waterproof Cover.																				
Resilient	Non-Skid																				
Flash Cove																					
type	quantity	size	material	finish	Hardware Group																
A	1	1065 x 2135	Solid Core	Plam	PW-01																
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input checked="" type="checkbox"/> Shower Seat <input checked="" type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain- Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																	

MILLWORK: Upper Cabinets: <input type="checkbox"/> finish: _____ doors: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/> finish: _____ doors: <input type="checkbox"/>	combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/>	Options: <input type="checkbox"/> Standing Height Counter	Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td> </td><td> </td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td> </td><td> </td></tr></table> Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish: _____ Patient Wardrobe: <input type="checkbox"/> finish: _____ Mail Slots: <input type="checkbox"/> finish: _____	min. length (mm)	finish			min. length (mm)	finish		
min. length (mm)	finish										
min. length (mm)	finish										

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td> </td></tr></table>		PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Lever Blade</td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Shower	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Gooseneck	Lever Blade					
quantity	mounting type	faucet type	control type	plumbing remarks													
Lavatory	1	Wall Hung	Gooseneck	Lever Blade													

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

--

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>	

VENTILATION: Relative Pressure: <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: _____ Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>	

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock	LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input checked="" type="checkbox"/> Night Light <input checked="" type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input checked="" type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks: <table border="1" style="width:100%; height: 50px;"><tr><td> </td></tr></table>	

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	2
Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

--

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>F</td> <td>1</td> <td>1530 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	F	1	1530 x 2135	Solid Core	Plam	PR-01												
type	quantity	size	material	finish	Hardware Group																						
F	1	1530 x 2135	Solid Core	Plam	PR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input checked="" type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input checked="" type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input checked="" type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish 600 Solid Surfacing																											
Washroom Vanity: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input checked="" type="checkbox"/> Plastic Laminate Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex at headwall & 1 duplex for bed
UPS	Duplex		3	2 duplex at HW & 1 duplex above bed non-nursing side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input checked="" type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input checked="" type="checkbox"/> Headwall <input checked="" type="checkbox"/> Clock
LIGHTING: <input checked="" type="checkbox"/> Workstation Task Light <input checked="" type="checkbox"/> Bedside Staff Light <input checked="" type="checkbox"/> Visitor Light <input checked="" type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input checked="" type="checkbox"/> Reading Light <input checked="" type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: II Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control	
quantity	mounting type	faucet type	control type	plumbing remarks							
1	Wall Hung	Gooseneck	Electronic Control								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>											

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen	1	1						
Medical Air	1	1						
Medical Vacuum	1	1						
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: _____

VENTILATION: Relative Pressure: Equal Positive Negative Other: _____
 Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC	1	I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port	0	C – Coax
Headwall Outlets 2PM/3A (per headwall)	1	NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Code White	Patient Assist	
2/3B: 2/3 button station					
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist	
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White		
Other					

IMIT Remarks: _____

SECURITY SYSTEM:
 Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Waterproof Cover.</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB - Moisture and Mould Resistant	Washable	GWB - Moisture and Mould Resistant	Waterproof Cover.	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>F</td> <td>1</td> <td>1530 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PW-01</td> </tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight, <input type="checkbox"/> Integral Blinds, <input type="checkbox"/> Security Grille, <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	F	1	1530 x 2135	Solid Core	Plam	PW-01												
GWB - Moisture and Mould Resistant	Washable																																		
GWB - Moisture and Mould Resistant	Waterproof Cover.																																		
Resilient	Non-Skid																																		
Flash Cove																																			
type	quantity	size	material	finish	Hardware Group																														
F	1	1530 x 2135	Solid Core	Plam	PW-01																														
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																																	
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input checked="" type="checkbox"/> Shower Seat <input checked="" type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																																	
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		min. length (mm)	finish			min. length (mm)	finish			HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																												
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																												
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																													
min. length (mm)	finish																																		
min. length (mm)	finish																																		

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Lighting Legend: <input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input checked="" type="checkbox"/> Night Light <input checked="" type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input checked="" type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks				

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td></td></tr></table>			PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Lever Blade</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Shower		quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Gooseneck	Lever Blade																																																																				
quantity	mounting type	faucet type	control type	plumbing remarks																																																																														
Lavatory	1	Wall Hung	Gooseneck	Lever Blade																																																																														
MEDICAL GASES: <table border="1" style="width:100%; text-align: center;"> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="2">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> </tr> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </table>		(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			Oxygen								Medical Air								Medical Vacuum								Nitrous Oxide								Nitrogen								CO2								Scavenging								Laser Smoke Evac.								Medical Gas Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>		
(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other																																																																											
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																														
Oxygen																																																																																		
Medical Air																																																																																		
Medical Vacuum																																																																																		
Nitrous Oxide																																																																																		
Nitrogen																																																																																		
CO2																																																																																		
Scavenging																																																																																		
Laser Smoke Evac.																																																																																		

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;																																														
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack																																														
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack																																														
Patient Monitoring Outlets 2A Red Data Port		C – Coax																																														
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet																																														
NURSE CALL: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td>2</td> </tr> <tr> <td>Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u></td> <td></td> </tr> </table> <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio	2	Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u>			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																															
DS Duty Station																																																
MCS Full feature master control station																																																
EPCA Emergency Pull Cord station with Audio	2																																															
Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u>																																																
	quantity	feature 1	feature 2	feature 3	feature 4																																											
PS: Patient Station																																																
2/3B: 2/3 button station																																																
4B: 4 button station (single gang)																																																
VST: VoIP Staff Terminal/Station																																																
Other																																																

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>			
VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%;"><tr><td></td></tr></table> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>			

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	
--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>F</td> <td>1</td> <td>1530 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PR-01</td> </tr> </tbody> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	F	1	1530 x 2135	Solid Core	Plam	PR-01								
GWB	Washable																														
GWB	Washable																														
Resilient	Slip Resistant																														
Flash Cove																															
type	quantity	size	material	finish	Hardware Group																										
F	1	1530 x 2135	Solid Core	Plam	PR-01																										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input checked="" type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																													
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input checked="" type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input checked="" type="checkbox"/> Ceiling IV Track																													
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm): 600</td><td>finish: Solid Surfacing</td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm):</td><td>finish:</td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		min. length (mm): 600	finish: Solid Surfacing	min. length (mm):	finish:	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																								
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																								
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																									
min. length (mm): 600	finish: Solid Surfacing																														
min. length (mm):	finish:																														

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex at headwall & 1 duplex for bed
	Duplex		3	2 duplex at headwall & 1 duplex above bed non-nursing side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input checked="" type="checkbox"/> Patient Care Area Designation as per CSA Z32
<input type="checkbox"/> Remote Power Shut-Off
<input checked="" type="checkbox"/> Headwall
<input checked="" type="checkbox"/> Clock
LIGHTING:
<input checked="" type="checkbox"/> Workstation Task Light
<input checked="" type="checkbox"/> Bedside Staff Light
<input checked="" type="checkbox"/> Visitor Light
<input checked="" type="checkbox"/> Night Light
<input type="checkbox"/> Vanity Light
<input type="checkbox"/> In Use Light Laser and/or X-ray
<input type="checkbox"/> Zone Controller
<input type="checkbox"/> Colour Tunable
<input checked="" type="checkbox"/> Reading Light
<input checked="" type="checkbox"/> Hand Hygiene Sink Light
<input type="checkbox"/> Examination Light
<input type="checkbox"/> Shower Light
<input type="checkbox"/> Circadian Lighting
lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>I</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"></table>		I	PLUMBING: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> </tbody> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>		quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control																																																																				
I																																																																																	
quantity	mounting type	faucet type	control type	plumbing remarks																																																																													
1	Wall Hung	Gooseneck	Electronic Control																																																																														
MEDICAL GASES: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="2">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> </tr> </thead> <tbody> <tr> <td>Oxygen</td> <td>1</td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Medical Air</td> <td>1</td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Medical Vacuum</td> <td>1</td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Nitrous Oxide</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Nitrogen</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>CO2</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Scavenging</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Laser Smoke Evac.</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table> Medical Gas Remarks: <table border="1" style="width:100%;"></table>		(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			Oxygen	1	1						Medical Air	1	1						Medical Vacuum	1	1						Nitrous Oxide								Nitrogen								CO2								Scavenging								Laser Smoke Evac.								ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input checked="" type="checkbox"/> Room Relative Humidity with Local Readout <input checked="" type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <table border="1" style="width:100%;"></table>	
(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other																																																																										
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																													
Oxygen	1	1																																																																															
Medical Air	1	1																																																																															
Medical Vacuum	1	1																																																																															
Nitrous Oxide																																																																																	
Nitrogen																																																																																	
CO2																																																																																	
Scavenging																																																																																	
Laser Smoke Evac.																																																																																	

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td>1</td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td>0</td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td>1</td> </tr> </tbody> </table>			quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC	1	Patient Monitoring Outlets 2A Red Data Port	0	Headwall Outlets 2PM/3A (per headwall)	1	Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet																																					
	quantity																																																
Telecommunication Outlets 2A/1I	1																																																
Television Outlets 1A/1C/1NC	1																																																
Patient Monitoring Outlets 2A Red Data Port	0																																																
Headwall Outlets 2PM/3A (per headwall)	1																																																
NURSE CALL: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td>1</td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>			quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio	1	Other:		<table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td>1</td> <td>Code Blue</td> <td>Code White</td> <td>Patient Assist</td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td>1</td> <td>Code Blue</td> <td>Code White</td> <td>Staff Assist</td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td>1</td> <td>Code Blue</td> <td>Code White</td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station	1	Code Blue	Code White	Patient Assist		2/3B: 2/3 button station						4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist		VST: VoIP Staff Terminal/Station	1	Code Blue	Code White			Other					
	quantity																																																
DS Duty Station																																																	
MCS Full feature master control station																																																	
EPCA Emergency Pull Cord station with Audio	1																																																
Other:																																																	
	quantity	feature 1	feature 2	feature 3	feature 4																																												
PS: Patient Station	1	Code Blue	Code White	Patient Assist																																													
2/3B: 2/3 button station																																																	
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist																																													
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White																																														
Other																																																	
ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input checked="" type="checkbox"/> Room Relative Humidity with Local Readout <input checked="" type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <table border="1" style="width:100%;"></table>		IMIT Remarks: <table border="1" style="width:100%;"><tr><td>Locate 2/3b at entrance to room</td></tr></table>		Locate 2/3b at entrance to room																																													
Locate 2/3b at entrance to room																																																	

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%;"></table> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"></table>	
--	--

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	
--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>C</td> <td>2</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PA-01</td> </tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	C	2	1065 x 2135	Solid Core	Plam	PA-01												
GWB	Washable																																		
GWB	Washable																																		
Resilient	Slip Resistant																																		
Flash Cove																																			
type	quantity	size	material	finish	Hardware Group																														
C	2	1065 x 2135	Solid Core	Plam	PA-01																														
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																																	
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																																	
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		min. length (mm)	finish			min. length (mm)	finish			HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																												
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																												
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																													
min. length (mm)	finish																																		
min. length (mm)	finish																																		

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Lighting Legend: <input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input checked="" type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks				

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>I</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td></td></tr></table>		I		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>		quantity	mounting type	faucet type	control type	plumbing remarks	Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control																																																																													
I																																																																																												
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control																																																																																								
MEDICAL GASES: <table border="1" style="width:100%; text-align: center;"> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </table>		(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.									Medical Gas Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>		
(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other																																																																																				
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>Telecommunication Outlets 2A/1I</td> <td></td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </table>			quantity	Telecommunication Outlets 2A/1I		Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend: A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet																																					
	quantity																																																
Telecommunication Outlets 2A/1I																																																	
Television Outlets 1A/1C/1NC																																																	
Patient Monitoring Outlets 2A Red Data Port																																																	
Headwall Outlets 2PM/3A (per headwall)																																																	
NURSE CALL: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </table>			quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:		<table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td>1</td> <td>Code Blue</td> <td>Code White</td> <td>Code Pink</td> <td>Staff Assist</td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station	1	Code Blue	Code White	Code Pink	Staff Assist	Other					
	quantity																																																
DS Duty Station																																																	
MCS Full feature master control station																																																	
EPCA Emergency Pull Cord station with Audio																																																	
Other:																																																	
	quantity	feature 1	feature 2	feature 3	feature 4																																												
PS: Patient Station																																																	
2/3B: 2/3 button station																																																	
4B: 4 button station (single gang)																																																	
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White	Code Pink	Staff Assist																																												
Other																																																	

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input checked="" type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>			
VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%;"><tr><td></td></tr></table> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>			

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	
--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Waterproof Cover.</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB - Moisture and Mould Resistant	Washable	GWB - Moisture and Mould Resistant	Waterproof Cover.	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>F</td> <td>1</td> <td>1530 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PW-01</td> </tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	F	1	1530 x 2135	Solid Core	Plam	PW-01												
GWB - Moisture and Mould Resistant	Washable																																		
GWB - Moisture and Mould Resistant	Waterproof Cover.																																		
Resilient	Non-Skid																																		
Flash Cove																																			
type	quantity	size	material	finish	Hardware Group																														
F	1	1530 x 2135	Solid Core	Plam	PW-01																														
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																																	
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input checked="" type="checkbox"/> Shower Seat <input checked="" type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																																	
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		min. length (mm)	finish			min. length (mm)	finish			HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																												
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																												
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																													
min. length (mm)	finish																																		
min. length (mm)	finish																																		

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting Legend:
 Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks:

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <div style="border: 1px solid black; height: 60px; width: 100%;"></div>		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Lever Blade</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Shower		quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Gooseneck	Lever Blade																																																																				
quantity	mounting type	faucet type	control type	plumbing remarks																																																																													
Lavatory	1	Wall Hung	Gooseneck	Lever Blade																																																																													
MEDICAL GASES: <table border="1" style="width:100%; text-align: center;"> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="2">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> </tr> <tr> <td>Oxygen</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Medical Air</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Medical Vacuum</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Nitrous Oxide</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Nitrogen</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>CO2</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Scavenging</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Laser Smoke Evac.</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table> Medical Gas Remarks: <div style="border: 1px solid black; width: 100%;"></div>		(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			Oxygen								Medical Air								Medical Vacuum								Nitrous Oxide								Nitrogen								CO2								Scavenging								Laser Smoke Evac.								ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <div style="border: 1px solid black; width: 100%;"></div>	
(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other																																																																										
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																													
Oxygen																																																																																	
Medical Air																																																																																	
Medical Vacuum																																																																																	
Nitrous Oxide																																																																																	
Nitrogen																																																																																	
CO2																																																																																	
Scavenging																																																																																	
Laser Smoke Evac.																																																																																	

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	2
Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="text"/> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Dedicated Exhaust Remarks: <div style="border: 1px solid black; width: 100%;"></div>	
---	--

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	
--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>F</td> <td>1</td> <td>1530 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PR-01</td> </tr> </tbody> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	F	1	1530 x 2135	Solid Core	Plam	PR-01								
GWB	Washable																														
GWB	Washable																														
Resilient	Slip Resistant																														
Flash Cove																															
type	quantity	size	material	finish	Hardware Group																										
F	1	1530 x 2135	Solid Core	Plam	PR-01																										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input checked="" type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																													
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input checked="" type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input checked="" type="checkbox"/> Ceiling IV Track																													
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm): 600</td><td>finish: Solid Surfacing</td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm):</td><td>finish:</td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		min. length (mm): 600	finish: Solid Surfacing	min. length (mm):	finish:	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																								
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																								
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																									
min. length (mm): 600	finish: Solid Surfacing																														
min. length (mm):	finish:																														

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex at headwall & 1 duplex for bed
UPS	Duplex		3	2 duplex at HW & 1 duplex above bed non-nursing side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
 - Remote Power Shut-Off
 - Headwall
 - Clock
- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>I</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"></table>		I	PLUMBING: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> </tbody> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>		quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control																																																																				
I																																																																																	
quantity	mounting type	faucet type	control type	plumbing remarks																																																																													
1	Wall Hung	Gooseneck	Electronic Control																																																																														
MEDICAL GASES: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="2">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> </tr> </thead> <tbody> <tr> <td>Oxygen</td> <td>1</td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Medical Air</td> <td>1</td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Medical Vacuum</td> <td>1</td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Nitrous Oxide</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Nitrogen</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>CO2</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Scavenging</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Laser Smoke Evac.</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table> Medical Gas Remarks: <table border="1" style="width:100%;"></table>		(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			Oxygen	1	1						Medical Air	1	1						Medical Vacuum	1	1						Nitrous Oxide								Nitrogen								CO2								Scavenging								Laser Smoke Evac.								ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input checked="" type="checkbox"/> Room Relative Humidity with Local Readout <input checked="" type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <table border="1" style="width:100%;"></table>	
(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other																																																																										
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																													
Oxygen	1	1																																																																															
Medical Air	1	1																																																																															
Medical Vacuum	1	1																																																																															
Nitrous Oxide																																																																																	
Nitrogen																																																																																	
CO2																																																																																	
Scavenging																																																																																	
Laser Smoke Evac.																																																																																	

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td>1</td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td>0</td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td>1</td> </tr> </tbody> </table>			quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC	1	Patient Monitoring Outlets 2A Red Data Port	0	Headwall Outlets 2PM/3A (per headwall)	1	NURSE CALL: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td>1</td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>			quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio	1	Other:																		
	quantity																																							
Telecommunication Outlets 2A/1I	1																																							
Television Outlets 1A/1C/1NC	1																																							
Patient Monitoring Outlets 2A Red Data Port	0																																							
Headwall Outlets 2PM/3A (per headwall)	1																																							
	quantity																																							
DS Duty Station																																								
MCS Full feature master control station																																								
EPCA Emergency Pull Cord station with Audio	1																																							
Other:																																								
Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet		<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																																						
IMIT Remarks: <table border="1" style="width:100%;"><tr><td>Locate 2/3b at entrance to room</td></tr></table>		Locate 2/3b at entrance to room	<table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td>1</td> <td>Code Blue</td> <td>Code White</td> <td>Patient Assist</td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td>1</td> <td>Code Blue</td> <td>Code White</td> <td>Staff Assist</td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td>1</td> <td>Code Blue</td> <td>Code White</td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station	1	Code Blue	Code White	Patient Assist		2/3B: 2/3 button station						4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist		VST: VoIP Staff Terminal/Station	1	Code Blue	Code White			Other					
Locate 2/3b at entrance to room																																								
	quantity	feature 1	feature 2	feature 3	feature 4																																			
PS: Patient Station	1	Code Blue	Code White	Patient Assist																																				
2/3B: 2/3 button station																																								
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist																																				
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White																																					
Other																																								

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%;"></table> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"></table>	
--	--

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Infant Abduction System <input checked="" type="checkbox"/> Patient Wandering System	
--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB - Moisture and Mould Resistant	Washable
Wall: GWB - Moisture and Mould Resistant	Waterproof Cover.
Floor: Resilient	Non-Skid
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	1065 x 2135	Solid Core	Plam	PW-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain- Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting Legend:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend:

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Lavatory	1	Wall Hung	Gooseneck	Lever Blade

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: Shower

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	2
Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
C	2	1065 x 2135	Solid Core	Plam	PA-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: I

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off

Headwall

Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White	Code Pink	Staff Assist
Other					

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: type quantity size material finish Hardware Group  Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight, <input type="checkbox"/> Integral Blinds, <input type="checkbox"/> Security Grille, <input type="checkbox"/> Laser Ready Integral Blinds	
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input checked="" type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws		MILLWORK: Upper Cabinets <input type="checkbox"/> finish doors <input type="checkbox"/> combination doors & open <input type="checkbox"/> lockable <input type="checkbox"/> adjustable shelves <input type="checkbox"/> microwave shelf <input type="checkbox"/> Lower Cabinets/Drawers <input type="checkbox"/> finish doors <input type="checkbox"/> combination doors & open <input type="checkbox"/> lockable <input type="checkbox"/> adjustable shelves <input type="checkbox"/> microwave shelf <input type="checkbox"/> Options: <input checked="" type="checkbox"/> Standing Height Counter Countertop: min. length (mm) 1500 finish Plastic Laminate Washroom Vanity: min. length (mm) finish Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> finish Mail Slots: <input type="checkbox"/> finish	

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Vital	Duplex		1
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																		
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																				
MEDICAL GASES: (Quantity)		Headwall 1		Headwall 2		Overhead Booms		Other												
		Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side															
Oxygen																				
Medical Air																				
Medical Vacuum																				
Nitrous Oxide																				
Nitrogen																				
CO2																				
Scavenging																				
Laser Smoke Evac.																				
Medical Gas Remarks:																				

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td>1</td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td>0</td> </tr> </tbody> </table>			quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port	1	Headwall Outlets 2PM/3A (per headwall)	0	Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet																																					
	quantity																																																
Telecommunication Outlets 2A/1I	1																																																
Television Outlets 1A/1C/1NC																																																	
Patient Monitoring Outlets 2A Red Data Port	1																																																
Headwall Outlets 2PM/3A (per headwall)	0																																																
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>			quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:		<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td>1</td> <td>Code Blue</td> <td>Code White</td> <td>Staff Assist</td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist		VST: VoIP Staff Terminal/Station						Other					
	quantity																																																
DS Duty Station																																																	
MCS Full feature master control station																																																	
EPCA Emergency Pull Cord station with Audio																																																	
Other:																																																	
	quantity	feature 1	feature 2	feature 3	feature 4																																												
PS: Patient Station																																																	
2/3B: 2/3 button station																																																	
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist																																													
VST: VoIP Staff Terminal/Station																																																	
Other																																																	
ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:		IMIT Remarks:																																															

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:	
VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:	

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System			
--	--	--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Non-Skid
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

Upper Cabinets	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/> Standing Height Counter

Countertop: min. length (mm) 1800 finish Solid Surfacing

Washroom Vanity: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Double Bowl	1	Counter	Gooseneck	Lever Blade

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: _____

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	GFI
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
- lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																																	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input checked="" type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	
type	quantity	size	material	finish	Hardware Group																																																						
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																																					
MILLWORK: Upper Cabinets: <input type="checkbox"/> finish: doors: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/> finish: doors: <input type="checkbox"/> Combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/> Options: <input type="checkbox"/> Standing Height Counter		Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																																																									

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																					
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																							

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2	Quad	4	Locate HK outlets at 1400mm AFF
	Conditional 1			
	Conditional 2			
	Conditional 3			
Delayed Vital				
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: <input type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB - Impact Resistant Washable Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																																	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	
type	quantity	size	material	finish	Hardware Group																																																						
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																																					
MILLWORK: Upper Cabinets: <input type="checkbox"/> finish: doors: <input type="checkbox"/> combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/> finish: doors: <input type="checkbox"/> combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/>		Options: <input type="checkbox"/> Standing Height Counter		Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: min. length (mm) finish Custom: Patient Wardrobe: <input type="checkbox"/> finish Mail Slots: <input type="checkbox"/> finish																																																							

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																					
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																							

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks	
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF	
	Normal 2	Quad	4	Locate HK outlets at 1400mm AFF	
	Conditional 1				
	Conditional 2				
	Conditional 3				
	Delayed Vital				
Vital					
UPS					
Boom:	Normal				
	Conditional				
	Delayed Vital				
	Vital				
	UPS				
Boom:	Normal				
	Conditional				
	Delayed Vital				
	Vital				
	UPS				
Boom:	Normal				
	Conditional				
	Delayed Vital				
	Vital				
	UPS				

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: <input type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

- SECURITY SYSTEM:**
- Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 - Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>	GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>WR-01</td> </tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	type	quantity	size	material	finish	Hardware Group	A	1	1065 x 2135	Solid Core	Plam	WR-01
GWB	Washable																				
GWB - Moisture and Mould Resistant	Washable																				
Resilient	Non-Skid																				
Flash Cove																					
type	quantity	size	material	finish	Hardware Group																
A	1	1065 x 2135	Solid Core	Plam	WR-01																
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																	

MILLWORK: Upper Cabinets: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/>	finish doors combination doors & open lockable adjustable shelves microwave shelf	Options: <input type="checkbox"/> Standing Height Counter	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>	min. length (mm) finish Custom: finish	Countertop: <table border="1" style="width:100%;"><tr><td> </td><td> </td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td> </td><td> </td></tr></table>				

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>III</td></tr></table> Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>	III		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input type="checkbox"/>	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Gooseneck	Electronic Control
III													
quantity	mounting type	faucet type	control type	plumbing remarks									
Lavatory	1	Wall Hung	Gooseneck	Electronic Control									

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

--

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>	

VENTILATION: Relative Pressure: <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%;"><tr><td> </td></tr></table> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>		

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock	LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input checked="" type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>	

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

--

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Non-Skid
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	WR-03

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Lavatory	1	Wall Hung	Gooseneck	Electronic Control

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	0
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>KP-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	KP-01												
type	quantity	size	material	finish	Hardware Group																						
A	1	914 x 2135	Solid Core	Plam	KP-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input checked="" type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>																						
Countertop: min. length (mm) 1800 finish Solid Surfacing Washroom Vanity: min. length (mm) finish Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	1
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> <tr> <td>Double Bowl</td> <td>1</td> <td>Counter</td> <td>Gooseneck</td> <td>Lever Blade</td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control	Double Bowl	1	Counter	Gooseneck	Lever Blade
quantity	mounting type	faucet type	control type	plumbing remarks												
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control												
Double Bowl	1	Counter	Gooseneck	Lever Blade												
Other Fixtures: <input type="checkbox"/> Urinal: <input checked="" type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

NURSE CALL:	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB - Moisture and Mould Resistant	Paint
Floor: Resilient	Non-Skid
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	KP-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				

Lighting Requirements:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks: 10 air changes minimum

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: _____

VENTILATION: Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System



ARCHITECTURAL REQUIREMENTS

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>WR-03</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	WR-03												
GWB	Washable																																		
GWB - Moisture and Mould Resistant	Washable																																		
Resilient	Non-Skid																																		
Flash Cove																																			
type	quantity	size	material	finish	Hardware Group																														
A	1	914 x 2135	Solid Core	Plam	WR-03																														
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																																	
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																																	
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		min. length (mm)	finish			min. length (mm)	finish			HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																												
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																												
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																													
min. length (mm)	finish																																		
min. length (mm)	finish																																		

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock				
LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input checked="" type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input checked="" type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td></td></tr></table>			PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Staff Shower		quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Gooseneck	Electronic Control																																																																				
quantity	mounting type	faucet type	control type	plumbing remarks																																																																														
Lavatory	1	Wall Hung	Gooseneck	Electronic Control																																																																														
MEDICAL GASES: <table border="1" style="width:100%; text-align: center;"> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="2">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> </tr> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </table>		(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			Oxygen								Medical Air								Medical Vacuum								Nitrous Oxide								Nitrogen								CO2								Scavenging								Laser Smoke Evac.								Medical Gas Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>		
(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other																																																																											
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																														
Oxygen																																																																																		
Medical Air																																																																																		
Medical Vacuum																																																																																		
Nitrous Oxide																																																																																		
Nitrogen																																																																																		
CO2																																																																																		
Scavenging																																																																																		
Laser Smoke Evac.																																																																																		

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>Telecommunication Outlets 2A/1I</td> <td></td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </table>			quantity	Telecommunication Outlets 2A/1I		Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet																																					
	quantity																																																
Telecommunication Outlets 2A/1I																																																	
Television Outlets 1A/1C/1NC																																																	
Patient Monitoring Outlets 2A Red Data Port																																																	
Headwall Outlets 2PM/3A (per headwall)																																																	
NURSE CALL: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td>0</td> </tr> <tr> <td>Other: _____</td> <td></td> </tr> </table>			quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio	0	Other: _____		<table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																																
DS Duty Station																																																	
MCS Full feature master control station																																																	
EPCA Emergency Pull Cord station with Audio	0																																																
Other: _____																																																	
	quantity	feature 1	feature 2	feature 3	feature 4																																												
PS: Patient Station																																																	
2/3B: 2/3 button station																																																	
4B: 4 button station (single gang)																																																	
VST: VoIP Staff Terminal/Station																																																	
Other																																																	
ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>			IMIT Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>																																														

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%;"><tr><td></td></tr></table> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>			

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	
--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling Acoustic Tile Pre-Finished Wall GWB - Abuse Resistant Paint Floor Resilient Slip Resistant Base Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>E</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CL-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	E	1	1065 x 2135	Solid Core	Plam	CL-01												
type	quantity	size	material	finish	Hardware Group																						
E	1	1065 x 2135	Solid Core	Plam	CL-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																												
quantity	mounting type	faucet type	control type	plumbing remarks																																																																														
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																																																																																		
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="2">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> </tr> </thead> <tbody> <tr> <td>Oxygen</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Medical Air</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Medical Vacuum</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Nitrous Oxide</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Nitrogen</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>CO2</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Scavenging</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Laser Smoke Evac.</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			Oxygen								Medical Air								Medical Vacuum								Nitrous Oxide								Nitrogen								CO2								Scavenging								Laser Smoke Evac.							
(Quantity)	Headwall 1		Headwall 2			Overhead Booms		Other																																																																										
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																														
Oxygen																																																																																		
Medical Air																																																																																		
Medical Vacuum																																																																																		
Nitrous Oxide																																																																																		
Nitrogen																																																																																		
CO2																																																																																		
Scavenging																																																																																		
Laser Smoke Evac.																																																																																		
Medical Gas Remarks:																																																																																		

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>2</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td>1</td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	2	Television Outlets 1A/1C/1NC	1	Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input checked="" type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	2																																					
Television Outlets 1A/1C/1NC	1																																					
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td>1</td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio	1	Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio	1																																					
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td>1</td> <td>Code Blue</td> <td>Code White</td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station	1	Code Blue	Code White			4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station	1	Code Blue	Code White																																			
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Slip Resistant
Base: Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group

Access Control Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	1	GFI
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting Legend:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend:

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

MECHANICAL REQUIREMENTS

HVAC: Type: II

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Anti-Ligature	Electronic Control

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: _____

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

IMIT Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB - Impact & Moisture and Mould Resistant	Washable
Floor: Resilient	Non-Skid
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	1065 x 2135	Solid Core	Plam	WR-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting Legend:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend:

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Lavatory	1	Wall Hung	Anti-Ligature	Electronic Control

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other: Locate EPCA between toilet and sink	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>OF-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	OF-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	1065 x 2135	Solid Core	Plam	OF-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input checked="" type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>						
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 3000 finish Solid Surfacing Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	2	convenience
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks
 provide zone lighting controller.

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks										
quantity	mounting type	faucet type	control type	plumbing remarks												
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist	
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB - Moisture and Mould Resistant Washable Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																																	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	
type	quantity	size	material	finish	Hardware Group																																																						
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																																					
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		Countertop: min. length (mm) 915 finish Plastic Laminate Washroom Vanity:		Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																															
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																																																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																																																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																																																					

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>				quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																					
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																									

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
	Vital	Duplex	1	pneumatic tube
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: <input type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	CR-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	1065 x 2135	Solid Core	Plam	CR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 6000 finish Solid Surfacing Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	2	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		2	charging stations
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks
 provide master zone lighting controller. Provide specialty lighting - LED under cabinet & cove lighting

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	2
Headwall Outlets 2PM/3A (per headwall)	

Legend;
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control	
quantity	mounting type	faucet type	control type	plumbing remarks							
1	Wall Hung	Gooseneck	Electronic Control								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:											

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	1
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist	
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: locate Patient monitoring outlets in bulkhead

SECURITY SYSTEM: <input checked="" type="checkbox"/> Security Camera <input checked="" type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Infant Abduction System <input checked="" type="checkbox"/> Patient Wandering System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	CR-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	1065 x 2135	Solid Core	Plam	CR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 9000 finish Solid Surfacing Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	2	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: <input type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

- SECURITY SYSTEM:**
- Security Camera
 - Clinical Camera Monitor
 - Panic Duress - Wired
 - Security Camera Monitor
 - Clinical Camera
 - Infant Abduction System
 - Patient Wandering System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																																	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	
type	quantity	size	material	finish	Hardware Group																																																						
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																																					
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td> </td> </tr> </tbody> </table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		Countertop: min. length (mm) finish 2,400 Solid Surfacing		Washroom Vanity: min. length (mm) finish Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																															
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																																																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																																																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																																																					

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>				quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																					
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																									

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control
--

VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="text"/> Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <input type="text"/>

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	
Telecommunication Outlets 2A/1I	1	
Television Outlets 1A/1C/1NC		
Patient Monitoring Outlets 2A Red Data Port		
Headwall Outlets 2PM/3A (per headwall)		

Legend;

- A – Active/Allocated Data Port or Data Jack
- I – Inactive/Unallocated Data Port or Data Jack
- C – Coax
- NC – Nurse Call
- PM- Patient Monitoring Outlet

- Intercom Station
- Video Intercom Station
- Overhead Paging (Pub Address)
- Teleconferencing

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: <input type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling Acoustic Tile Pre-Finished Wall GWB Paint Floor Resilient Slip Resistant Base Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>G</td> <td>1</td> <td>914 x 2135</td> <td>Aluminum</td> <td>Prefinished</td> <td>SL-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	G	1	914 x 2135	Aluminum	Prefinished	SL-01												
type	quantity	size	material	finish	Hardware Group																						
G	1	914 x 2135	Aluminum	Prefinished	SL-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		DOOR HARDWARE: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 1500 finish Plastic Laminate Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/> finish																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																						
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	1																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB - Abuse Resistant Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>2</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>KP-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	2	1220 x 2135	Solid Core	Plam	KP-01												
type	quantity	size	material	finish	Hardware Group																						
B	2	1220 x 2135	Solid Core	Plam	KP-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input checked="" type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Quad	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks										
quantity	mounting type	faucet type	control type	plumbing remarks												
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	2	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PA-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	914 x 2135	Solid Core	Plam	PA-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	914 x 2135	Solid Core	Plam	PA-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 3000 finish Plastic Laminate Washroom Vanity: min. length (mm) finish Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> finish Mail Slots: <input type="checkbox"/> finish																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2	Duplex	1	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Vital	Duplex	2	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	2	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																		
type	quantity	size	material	finish	Hardware Group																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input checked="" type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	15A/20A, 120V Housekeeping		3	crash cart
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
 - Remote Power Shut-Off
 - Headwall
 - Clock
- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	3	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>OF-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	OF-01												
type	quantity	size	material	finish	Hardware Group																						
A	1	914 x 2135	Solid Core	Plam	OF-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		DOOR HARDWARE: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>OF-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	OF-01												
type	quantity	size	material	finish	Hardware Group																						
A	1	914 x 2135	Solid Core	Plam	OF-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																						
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	1																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:
VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>OF-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	OF-01												
type	quantity	size	material	finish	Hardware Group																						
A	1	914 x 2135	Solid Core	Plam	OF-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																												
quantity	mounting type	faucet type	control type	plumbing remarks																																																																														
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																																																																																		
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="2">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			Oxygen								Medical Air								Medical Vacuum								Nitrous Oxide								Nitrogen								CO2								Scavenging								Laser Smoke Evac.							
(Quantity)	Headwall 1		Headwall 2			Overhead Booms		Other																																																																										
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																														
Oxygen																																																																																		
Medical Air																																																																																		
Medical Vacuum																																																																																		
Nitrous Oxide																																																																																		
Nitrogen																																																																																		
CO2																																																																																		
Scavenging																																																																																		
Laser Smoke Evac.																																																																																		
Medical Gas Remarks:																																																																																		

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	1																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:
VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>	GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>WR-03</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	WR-03
GWB	Washable																				
GWB - Moisture and Mould Resistant	Washable																				
Resilient	Non-Skid																				
Flash Cove																					
type	quantity	size	material	finish	Hardware Group																
A	1	914 x 2135	Solid Core	Plam	WR-03																
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain- Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																	

MILLWORK: Upper Cabinets: <input type="checkbox"/> finish: _____ doors: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/> finish: _____ doors: <input type="checkbox"/>	combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/>	Options: <input type="checkbox"/> Standing Height Counter	Countertop: min. length (mm) _____ finish _____ Washroom Vanity: min. length (mm) _____ finish _____ Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish _____ Patient Wardrobe: <input type="checkbox"/> finish _____ Mail Slots: <input type="checkbox"/> finish _____
--	--	--	---

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <input style="width:100%;" type="text"/>	PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input type="checkbox"/> _____	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Gooseneck	Electronic Control
quantity	mounting type	faucet type	control type	plumbing remarks							
Lavatory	1	Wall Hung	Gooseneck	Electronic Control							

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout	Room Control Remarks: <input style="width:100%;" type="text"/>
---	--

VENTILATION: Relative Pressure: <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: _____ Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust	Remarks: <input style="width:100%;" type="text"/>
--	---

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock	LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input checked="" type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks: <input style="width:100%; height: 50px;" type="text"/>
--	--

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	0
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Washable
Wall: GWB - Impact Resistant	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2	Duplex	2	
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting Requirements:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Anti-Ligature	Electronic Control

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: _____

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB - Moisture and Mould Resistant Washable Floor: Resilient Non-Skid Base: Flash Cove	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>E</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PA-01</td> </tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	type	quantity	size	material	finish	Hardware Group	E	1	914 x 2135	Solid Core	Plam	PA-01
type	quantity	size	material	finish	Hardware Group								
E	1	914 x 2135	Solid Core	Plam	PA-01								
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature												
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track												
HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws													

MILLWORK: Upper Cabinets: <input checked="" type="checkbox"/> Plastic Laminate Lower Cabinets/Drawers: <input checked="" type="checkbox"/> Plastic Laminate	finish doors combination doors & open lockable adjustable shelves microwave shelf	Options: <input checked="" type="checkbox"/> Standing Height Counter	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>
Countertop: min. length (mm) 1800 finish Solid Surfacing	Custom: _____ finish _____		

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Double Bowl</td> <td>1</td> <td>Counter</td> <td>Anti-Ligature</td> <td>Electronic Control</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input checked="" type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/> _____	quantity	mounting type	faucet type	control type	plumbing remarks	Double Bowl	1	Counter	Anti-Ligature	Electronic Control
quantity	mounting type	faucet type	control type	plumbing remarks							
Double Bowl	1	Counter	Anti-Ligature	Electronic Control							

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: _____
--

VENTILATION: Relative Pressure: <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: _____ Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: _____
--

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	GFI
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: material: <input type="checkbox"/> Washable Wall: material: <input type="checkbox"/> Washable Floor: material: <input type="checkbox"/> Non-Skid Base: material: <input type="checkbox"/> Flash Cove	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>B</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>KP-01</td> </tr> </table>	type	quantity	size	material	finish	Hardware Group	B	1	1220 x 2135	Solid Core	Plam	KP-01	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator
type	quantity	size	material	finish	Hardware Group									
B	1	1220 x 2135	Solid Core	Plam	KP-01									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track												
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws														

MILLWORK: Upper Cabinets: <input checked="" type="checkbox"/> Stainless Steel Lower Cabinets/Drawers: <input checked="" type="checkbox"/> Stainless Steel	finish: <input type="checkbox"/> Stainless Steel doors: <input type="checkbox"/> combination doors & open: <input checked="" type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input checked="" type="checkbox"/>	Options: <input checked="" type="checkbox"/> Standing Height Counter	Countertop: min. length (mm): 5000 finish: Stainless Steel Washroom Vanity: min. length (mm): finish: Custom: Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>
--	--	---	---

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> <tr> <td>1</td> <td>Counter</td> <td>Gooseneck</td> <td>Lever Blade</td> <td></td> </tr> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control		1	Counter	Gooseneck	Lever Blade	
quantity	mounting type	faucet type	control type	plumbing remarks												
1	Wall Hung	Gooseneck	Electronic Control													
1	Counter	Gooseneck	Lever Blade													
Other Fixtures: <input type="checkbox"/> Urinal: <input checked="" type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:
--

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2	30A, 208Volt, 3 Phase	1	4 wire connection / future retherm units
	Conditional 3	30A, 208Volt, 1 Phase	1	3 wire connection / future retherm units
	Delayed Vital			
Vital	Duplex		2	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input checked="" type="checkbox"/> Clock
LIGHTING: <input checked="" type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input checked="" type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: locate 2/3B button at door

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB	Washable
Wall	GWB - Abuse Resistant	Washable
Floor	Resilient	Slip Resistant
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

DOORS:

type	quantity	size	material	finish	Hardware Group
B	2	1220 x 2135	Solid Core	Plam	CR-01

Door Hardware: Access Control

Other Features:
 Sidelight
 Integral Blinds
 Security Grille
 Laser Ready Integral Blinds

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		

Countertop: min. length (mm) 1800 finish Solid Surfacing

Washroom Vanity: min. length (mm) finish

Reception, Transaction Counter, or Care Team Station Desk: finish

Patient Wardrobe:

Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: II

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
1	Wall Hung	Anti-Ligature	Electronic Control	

Other Fixtures:
 Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	2
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;
A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White	Staff Assist	
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: locate 2/3B button at door

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Abuse Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB - Abuse Resistant	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>C</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input checked="" type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	C	1	1220 x 2135	Solid Core	Plam	CR-01								
GWB	Washable																														
GWB - Abuse Resistant	Washable																														
Resilient	Slip Resistant																														
Flash Cove																															
type	quantity	size	material	finish	Hardware Group																										
C	1	1220 x 2135	Solid Core	Plam	CR-01																										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																													
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input checked="" type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																													
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td></td> <td></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>1800</td><td>Plastic Laminate</td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td></td><td></td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			1800	Plastic Laminate			HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																								
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																								
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>																										
1800	Plastic Laminate																														

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Lighting: <input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input checked="" type="checkbox"/> Clock <input checked="" type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input checked="" type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks:				

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>II</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td></td></tr></table>	II		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>1</td> <td>Wall Hung</td> <td>Anti-Ligature</td> <td>Electronic Control</td> <td></td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Bathtub	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Anti-Ligature	Electronic Control	
II													
quantity	mounting type	faucet type	control type	plumbing remarks									
1	Wall Hung	Anti-Ligature	Electronic Control										

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								1
Medical Air								1
Medical Vacuum								1
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

Gases adjacent to plinth

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

--

VENTILATION: Relative Pressure: Equal Positive Negative Other:

--

 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

--

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	2	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White	Staff Assist	
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

--

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Impact Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB - Impact Resistant	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>C</td> <td>2</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CL-01</td> </tr> </tbody> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight, <input checked="" type="checkbox"/> Integral Blinds, <input type="checkbox"/> Security Grille, <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	C	2	1065 x 2135	Solid Core	Plam	CL-01								
GWB	Washable																														
GWB - Impact Resistant	Washable																														
Resilient	Slip Resistant																														
Flash Cove																															
type	quantity	size	material	finish	Hardware Group																										
C	2	1065 x 2135	Solid Core	Plam	CL-01																										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																													
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																													
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td></td> <td></td> </tr> </tbody> </table> Countertop: <table border="1" style="width:100%;"><tr><td>1220</td><td>Plastic Laminate</td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td></td><td></td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			1220	Plastic Laminate			HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																								
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																								
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>																										
1220	Plastic Laminate																														

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2	Quad	6	provide recep. on 1 m centers mounted at 1400mm AFF
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Vital			
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks
 Provide multi-sensor lighting environment complete with cove lighting and fiber optic ceiling cloud.

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>II</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td></td></tr></table>	II		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>	quantity	mounting type	faucet type	control type	plumbing remarks															
II																							
quantity	mounting type	faucet type	control type	plumbing remarks																			

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

--

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control
--

VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%;"><tr><td></td></tr></table> Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>		

NURSE CALL:	quantity
DS Duty Station	0
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

--

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Security Camera Monitor <input checked="" type="checkbox"/> Clinical Camera <input type="checkbox"/> Infant Abduction System <input checked="" type="checkbox"/> Patient Wandering System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB	Washable
Wall	GWB - Impact Resistant	Washable
Floor	Resilient	Slip Resistant
Base:	Flash Cove	

WALL PROTECTION:
 Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:
 Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:
 EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:
 Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:
 Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

DOORS:

type	quantity	size	material	finish	Hardware Group
B	1	1065 x 2135	Solid Core	Plam	CL-01

Door Hardware: Access Control
 Other Features: Sidelight Integral Blinds Security Grille Laser Ready Integral Blinds

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		

Countertop: min. length (mm) 1500 finish Plastic Laminate
 Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: finish
 Patient Wardrobe:
 Mail Slots:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		2	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	2
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: II
 Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	0
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: provide remote shutdown of power. Provide tamper proof, ligature proof devices

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB - Impact Resistant	Washable
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
B	1	914 x 2135	Solid Core	Plam	IA-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

Upper Cabinets	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter

Countertop: min. length (mm) 1500 finish Plastic Laminate Custom: Reception, Transaction Counter, or Care Team Station Desk: finish _____

Washroom Vanity: _____ Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: II

Remarks: _____

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: _____

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: _____

VENTILATION: Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks: _____

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	1
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White	Staff Assist	
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	Acoustic Tile	Washable
Wall	GWB - Impact Resistant	Washable
Floor	Resilient	Slip Resistant
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
C	1	1220 x 2135	Solid Core	Plam	CR-01

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2	Quad	6	provide recep. on 1 m centers mounted at 1400mm AFF
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend; Intercom Station Video Intercom Station
A – Active/Allocated Data Port or Data Jack Overhead Paging (Pub Address)
I – Inactive/Unallocated Data Port or Data Jack Teleconferencing
C – Coax NC – Nurse Call
PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB - Impact & Moisture and Mould Resistant Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PA-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	PA-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	1065 x 2135	Solid Core	Plam	PA-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 1800 finish Solid Surfacing Washroom Vanity: min. length (mm) finish Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Vital			
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting

 lighting remarks
 MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Counter</td> <td>Gooseneck</td> <td>Lever Blade</td> <td></td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Counter	Gooseneck	Lever Blade	
quantity	mounting type	faucet type	control type	plumbing remarks							
1	Counter	Gooseneck	Lever Blade								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:											

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

 Medical Gas Remarks:
 ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:
 TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	0	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

- Intercom Station
- Video Intercom Station
- Overhead Paging (Pub Address)
- Teleconferencing

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

 IMIT Remarks:
 SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

DOORS:

type	quantity	size	material	finish	Hardware Group
G	2	1220 x 2135	Aluminum	Prefinished	AO-01

Door Hardware: Access Control
 Other Features:
 Sidelight
 Integral Blinds
 Security Grille
 Laser Ready Integral Blinds

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		

Countertop: min. length (mm) 3000 finish Solid Surfacing

Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: finish

Patent Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: II

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White	Staff Assist	
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: locate 2/3B button at door

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION:

Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>B</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	B	1	1220 x 2135	Solid Core	Plam	CR-01												
GWB	Washable																																		
GWB	Washable																																		
Resilient	Slip Resistant																																		
Flash Cove																																			
type	quantity	size	material	finish	Hardware Group																														
B	1	1220 x 2135	Solid Core	Plam	CR-01																														
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																																	
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																																	
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		min. length (mm)	finish			min. length (mm)	finish			HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																												
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																												
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																													
min. length (mm)	finish																																		
min. length (mm)	finish																																		

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>III</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td></td></tr></table>	III		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>	quantity	mounting type	faucet type	control type	plumbing remarks															
III																							
quantity	mounting type	faucet type	control type	plumbing remarks																			

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

--

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other:

--

 Exhaust Required: Yes No Dedicated Exhaust Remarks:

--

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

--

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

DOORS:

type	quantity	size	material	finish	Hardware Group
B	1	1220 x 2135	Solid Core	Plam	CL-02

Door Hardware: Access Control

Other Features:
 Sidelight
 Integral Blinds
 Security Grille
 Laser Ready Integral Blinds

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Lighting:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

Upper Cabinets	Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	<input type="checkbox"/>	Stainless Steel	<input type="checkbox"/> Standing Height Counter					

Countertop: min. length (mm) 2400 finish: Stainless Steel

Washroom Vanity: min. length (mm) finish: Custom: Reception, Transaction Counter, or Care Team Station Desk: finish: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene: 1	Wall Hung	Gooseneck	Electronic Control	
Utility: 1	Counter	Gooseneck	Lever Blade	

Other Fixtures:
 Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																																	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input checked="" type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	
type	quantity	size	material	finish	Hardware Group																																																						
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																																					
MILLWORK: Upper Cabinets: <input type="checkbox"/> finish: doors: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/> finish: doors: <input type="checkbox"/> Combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/> Options: <input type="checkbox"/> Standing Height Counter		Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																																																									

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																					
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																							

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks	
General Power	Normal 1	15A/20A, 120V Housekeeping	3	Locate HK outlets at 1400mm AFF	
	Normal 2	Duplex	1	GFI	
	Conditional 1				
	Conditional 2				
	Conditional 3				
	Delayed Vital				
Vital					
UPS					
Boom:	Normal				
	Conditional				
	Delayed Vital				
	Vital				
	UPS				
Boom:	Normal				
	Conditional				
	Delayed Vital				
	Vital				
	UPS				
Boom:	Normal				
	Conditional				
	Delayed Vital				
	Vital				
	UPS				

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: <input type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB	Washable
Wall	GWB - Moisture and Mould Resistant	Washable
Floor	Resilient	Non-Skid
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
C	1	1220 x 2135	Solid Core	Plam	CR-01

Door Hardware: Access Control

Other Features:
 Sidelight
 Integral Blinds
 Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

	quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control	
Janitorial	1	Floor	Standard	Lever Blade	

Other Fixtures:
 Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: Detergent Dispenser

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	3	Locate HK outlets at 1400mm AFF
	Normal 2	Duplex	1	GFI
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend:
A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>C</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	C	1	1220 x 2135	Solid Core	Plam	CR-01																
GWB	Washable																																						
GWB - Moisture and Mould Resistant	Washable																																						
Resilient	Slip Resistant																																						
Flash Cove																																							
type	quantity	size	material	finish	Hardware Group																																		
C	1	1220 x 2135	Solid Core	Plam	CR-01																																		
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																																					
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																																					
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws		MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table> Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> <table border="1" style="width:100%;"><tr><td>finish</td></tr><tr><td></td></tr></table> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/> <table border="1" style="width:100%;"><tr><td>finish</td></tr><tr><td></td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		min. length (mm)	finish			min. length (mm)	finish			finish		finish												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																																
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																																
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																																	
min. length (mm)	finish																																						
min. length (mm)	finish																																						
finish																																							
finish																																							

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks:

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>III</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"></table>	III	PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>	quantity	mounting type	faucet type	control type	plumbing remarks	Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control
III												
quantity	mounting type	faucet type	control type	plumbing remarks								
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control								

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

Gases concealed behind tamper proof panel

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <table border="1" style="width:100%;"><tr><td>BMS Monitor and Control</td></tr></table>	BMS Monitor and Control
BMS Monitor and Control	

VENTILATION: Relative Pressure: <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%;"><tr><td></td></tr></table> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>		

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	0				
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

--

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB - Abuse Resistant	Washable
Wall	GWB - Impact Resistant	Washable
Floor	Resilient	Slip Resistant
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

DOORS:

type	quantity	size	material	finish	Hardware Group
F	1	1530 x 2135	Solid Core	Plam	PR-01

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) 600 finish Solid Surfacing Custom: Reception, Transaction Counter, or Care Team Station Desk: finish Plastic Laminate

Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
1	Wall Hung	Anti-Ligature	Electronic Control	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: Shower

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen	1	1						
Medical Air	1	1						
Medical Vacuum	1	1						
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: Gases concealed behind tamper proof panel

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex at headwall & 1 duplex for bed
	Duplex		3	2 duplex at HW & 1 duplex above bed non-nursing side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	1
Patient Monitoring Outlets 2A Red Data Port	0
Headwall Outlets 2PM/3A (per headwall)	1

Legend; Intercom Station Video Intercom Station
 Overhead Paging (Pub Address) Teleconferencing
A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Staff Assist	Patient Assist	
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: 2/3B mounted outside the door in the hallway

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Waterproof Cover.</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>	GWB - Moisture and Mould Resistant	Washable	GWB - Moisture and Mould Resistant	Waterproof Cover.	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PW-01</td> </tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	type	quantity	size	material	finish	Hardware Group	A	1	1065 x 2135	Solid Core	Plam	PW-01
GWB - Moisture and Mould Resistant	Washable																				
GWB - Moisture and Mould Resistant	Waterproof Cover.																				
Resilient	Non-Skid																				
Flash Cove																					
type	quantity	size	material	finish	Hardware Group																
A	1	1065 x 2135	Solid Core	Plam	PW-01																
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input checked="" type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input checked="" type="checkbox"/> Anti-Ligature																				
MENTAL HEALTH GLASS TYPES: <input checked="" type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input checked="" type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input checked="" type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input checked="" type="checkbox"/> Shower Curtain- Anti-ligature <input type="checkbox"/> Ceiling IV Track																				
HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																					

MILLWORK: Upper Cabinets <input type="checkbox"/> Lower Cabinets/Drawers <input type="checkbox"/>	finish doors combination doors & open lockable adjustable shelves microwave shelf	Options: <input type="checkbox"/> Standing Height Counter	Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr></table> Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>	min. length (mm)	finish	min. length (mm)	finish
min. length (mm)	finish						
min. length (mm)	finish						

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="II"/> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td> </td></tr></table>		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Anti-Ligature</td> <td>Electronic Control</td> </tr> </table> Provide remote water supply shut off by staff through BMS	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Anti-Ligature	Electronic Control
quantity	mounting type	faucet type	control type	plumbing remarks								
Lavatory	1	Wall Hung	Anti-Ligature	Electronic Control								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Shower												

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

--

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

--

VENTILATION: Relative Pressure Equal Positive Negative Other:

--

 Exhaust Required: Yes No Dedicated Exhaust Remarks:

--

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks:

--

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	2
Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Code White	Patient Assist	Staff Assist
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

--

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB - Abuse Resistant</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Impact Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB - Abuse Resistant	Washable	GWB - Impact Resistant	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>F</td> <td>1</td> <td>1530 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PR-01</td> </tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight, <input type="checkbox"/> Integral Blinds, <input type="checkbox"/> Security Grille, <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	F	1	1530 x 2135	Solid Core	Plam	PR-01									
GWB - Abuse Resistant	Washable																															
GWB - Impact Resistant	Washable																															
Resilient	Slip Resistant																															
Flash Cove																																
type	quantity	size	material	finish	Hardware Group																											
F	1	1530 x 2135	Solid Core	Plam	PR-01																											
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input checked="" type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input checked="" type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input checked="" type="checkbox"/> Anti-Ligature MENTAL HEALTH GLASS TYPES: <input checked="" type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input checked="" type="checkbox"/> INT-3 ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input checked="" type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input checked="" type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input checked="" type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																														
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm): 600</td><td>finish: Solid Surfacing</td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm):</td><td>finish:</td></tr></table> Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> <table border="1" style="width:100%;"><tr><td>finish:</td></tr></table> Patient Wardrobe: <input checked="" type="checkbox"/> Plastic Laminate Mail Slots: <input type="checkbox"/>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		min. length (mm): 600	finish: Solid Surfacing	min. length (mm):	finish:	finish:											
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																									
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																									
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																										
min. length (mm): 600	finish: Solid Surfacing																															
min. length (mm):	finish:																															
finish:																																

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex at headwall & 1 duplex for bed
UPS	Duplex		3	2 duplex at HW & 1 duplex above bed non-nursing side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off

Headwall

Clock

LIGHTING:

Workstation Task Light

Bedside Staff Light

Visitor Light

Night Light

Vanity Light

In Use Light Laser and/or X-ray

Zone Controller

Colour Tunable

Reading Light

Hand Hygiene Sink Light

Examination Light

Shower Light

Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Anti-Ligature</td> <td>Electronic Control</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Shower	quantity	mounting type	faucet type	control type	plumbing remarks	Hand Hygiene	1	Wall Hung	Anti-Ligature	Electronic Control
quantity	mounting type	faucet type	control type	plumbing remarks							
Hand Hygiene	1	Wall Hung	Anti-Ligature	Electronic Control							

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen	1	1						
Medical Air	1	1						
Medical Vacuum	1	1						
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: Gases concealed behind tamper proof panel

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC	1	I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port	0	C – Coax
Headwall Outlets 2PM/3A (per headwall)	1	NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Staff Assist	Patient Assist	
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: 2/3B mounted outside the door in the hallway

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: material: <input type="checkbox"/> Washable Wall: material: <input type="checkbox"/> Waterproof Cover. Floor: material: <input type="checkbox"/> Non-Skid Base: material: <input type="checkbox"/> Flash Cove	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>F</td> <td>1</td> <td>1530 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PW-01</td> </tr> </table>	type	quantity	size	material	finish	Hardware Group	F	1	1530 x 2135	Solid Core	Plam	PW-01	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input checked="" type="checkbox"/> Bed Bumper / Locator
type	quantity	size	material	finish	Hardware Group									
F	1	1530 x 2135	Solid Core	Plam	PW-01									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input checked="" type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input checked="" type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input checked="" type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input checked="" type="checkbox"/> Shower Curtain- Anti-ligature <input type="checkbox"/> Ceiling IV Track												
HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws														

MILLWORK: Upper Cabinets: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/>	finish: _____ doors: <input type="checkbox"/> combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/>	Options: <input type="checkbox"/> Standing Height Counter	Countertop: min. length (mm) _____ finish _____ Washroom Vanity: _____ Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish _____ Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>
--	---	--	---

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="checkbox"/> I Remarks: _____	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Anti-Ligature</td> <td>Electronic Control</td> </tr> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Anti-Ligature	Electronic Control	Provide remote water supply shut off by staff through BMS
quantity	mounting type	faucet type	control type	plumbing remarks								
Lavatory	1	Wall Hung	Anti-Ligature	Electronic Control								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Shower												

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: _____

VENTILATION: Relative Pressure: Equal Positive Negative Other: _____
 Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks: _____

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	2
Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Code White	Patient Assist	
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist	
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: Locate 2/3b at entrance to room

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB - Abuse Resistant	Washable
Wall	GWB - Impact Resistant	Washable
Floor	Resilient	Slip Resistant
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

DOORS:

type	quantity	size	material	finish	Hardware Group
F	1	1530 x 2135	Solid Core	Plam	PR-01

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) 600 finish Solid Surfacing Custom: Reception, Transaction Counter, or Care Team Station Desk: finish Plastic Laminate
Washroom Vanity: Patient Wardrobe: Mail Slots:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex at headwall & 1 duplex for bed
	Duplex		3	2 duplex at headwall & 1 duplex above bed non-nursing side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: I

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
1	Wall Hung	Anti-Ligature	Electronic Control	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen	1	1						
Medical Air	1	1						
Medical Vacuum	1	1						
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: Gases concealed behind tamper proof panel

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	1
Patient Monitoring Outlets 2A Red Data Port	0
Headwall Outlets 2PM/3A (per headwall)	1

Legend; Intercom Station Video Intercom Station
A – Active/Allocated Data Port or Data Jack Overhead Paging (Pub Address)
I – Inactive/Unallocated Data Port or Data Jack Teleconferencing
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Staff Assist	Patient Assist	
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White	Code Pink	Staff Assist
Other					

IMIT Remarks: 2/3B mounted outside the door in the hallway

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

DOORS:

type	quantity	size	material	finish	Hardware Group
C	2	1065 x 2135	Solid Core	Plam	PA-01

DOOR HARDWARE: Access Control

Other Features:

Sidelight
 Integral Blinds
 Security Grille
 Laser Ready Integral Blinds

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain- Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Lighting:				
<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input checked="" type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input checked="" type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks				

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: I

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Anti-Ligature	Electronic Control

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White	Code Pink	Staff Assist
Other					

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: material: <input type="checkbox"/> Washable Wall: material: <input type="checkbox"/> Waterproof Cover. Floor: material: <input type="checkbox"/> Non-Skid Base: material: <input type="checkbox"/> Flash Cove	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>F</td> <td>1</td> <td>1530 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PW-01</td> </tr> </table>	type	quantity	size	material	finish	Hardware Group	F	1	1530 x 2135	Solid Core	Plam	PW-01	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input checked="" type="checkbox"/> Bed Bumper / Locator
type	quantity	size	material	finish	Hardware Group									
F	1	1530 x 2135	Solid Core	Plam	PW-01									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input checked="" type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input checked="" type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input checked="" type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input checked="" type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input checked="" type="checkbox"/> Shower Curtain- Anti-ligature <input type="checkbox"/> Ceiling IV Track												
HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws														

MILLWORK: Upper Cabinets: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/>	finish: _____ doors: <input type="checkbox"/> combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/>	Options: <input type="checkbox"/> Standing Height Counter	Countertop: min. length (mm) _____ finish _____ Washroom Vanity: _____ Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish _____ Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>
--	---	--	---

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="checkbox"/> I Remarks: _____	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Anti-Ligature</td> <td>Electronic Control</td> </tr> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Anti-Ligature	Electronic Control	Provide remote water supply shut off by staff through BMS Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Shower
quantity	mounting type	faucet type	control type	plumbing remarks								
Lavatory	1	Wall Hung	Anti-Ligature	Electronic Control								

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input checked="" type="checkbox"/> Room Relative Humidity with Local Readout <input checked="" type="checkbox"/> Room Pressure Monitor with Local Readout	Room Control Remarks: _____
--	-----------------------------

VENTILATION: Relative Pressure: <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: _____ Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Dedicated Exhaust	Remarks: _____
--	----------------

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input checked="" type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock	LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input checked="" type="checkbox"/> Night Light <input checked="" type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input checked="" type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks: _____
---	---

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	2
Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Code White	Patient Assist	
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist	
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: Locate 2/3b at entrance to room

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	_____
---	-------

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB - Abuse Resistant</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Impact Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB - Abuse Resistant	Washable	GWB - Impact Resistant	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>F</td> <td>1</td> <td>1530 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PR-01</td> </tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	F	1	1530 x 2135	Solid Core	Plam	PR-01
GWB - Abuse Resistant	Washable																						
GWB - Impact Resistant	Washable																						
Resilient	Slip Resistant																						
Flash Cove																							
type	quantity	size	material	finish	Hardware Group																		
F	1	1530 x 2135	Solid Core	Plam	PR-01																		
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input checked="" type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input checked="" type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input checked="" type="checkbox"/> Anti-Ligature																					
MENTAL HEALTH GLASS TYPES: <input checked="" type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input checked="" type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input checked="" type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input checked="" type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input checked="" type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																					
MILLWORK: Upper Cabinets: <input type="checkbox"/> finish: <input type="checkbox"/> doors: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/> finish: <input type="checkbox"/> doors: <input type="checkbox"/> combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/> Options: <input type="checkbox"/> Standing Height Counter		HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																					
Countertop: min. length (mm) 600 finish Solid Surfacing Washroom Vanity: min. length (mm) finish		Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input checked="" type="checkbox"/> Plastic Laminate Mail Slots: <input type="checkbox"/>																					

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex at headwall & 1 duplex for bed
UPS	Duplex		3	2 duplex at HW & 1 duplex above bed non-nursing side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off

Headwall

Clock

LIGHTING:

Workstation Task Light

Bedside Staff Light

Visitor Light

Night Light

Vanity Light

In Use Light Laser and/or X-ray

Zone Controller

Colour Tunable

Reading Light

Hand Hygiene Sink Light

Examination Light

Shower Light

Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; text-align: center;"> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Anti-Ligature</td> <td>Electronic Control</td> <td></td> </tr> </table>				Hand Hygiene	1	Wall Hung	Anti-Ligature	Electronic Control	
Hand Hygiene	1	Wall Hung	Anti-Ligature	Electronic Control							
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Shower											

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC	1	I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port	0	C – Coax
Headwall Outlets 2PM/3A (per headwall)	1	NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Staff Assist	Patient Assist	
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: 2/3B mounted outside the door in the hallway

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Waterproof Cover.</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>	GWB - Moisture and Mould Resistant	Washable	GWB - Moisture and Mould Resistant	Waterproof Cover.	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PW-01</td> </tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	type	quantity	size	material	finish	Hardware Group	A	1	1065 x 2135	Solid Core	Plam	PW-01
GWB - Moisture and Mould Resistant	Washable																				
GWB - Moisture and Mould Resistant	Waterproof Cover.																				
Resilient	Non-Skid																				
Flash Cove																					
type	quantity	size	material	finish	Hardware Group																
A	1	1065 x 2135	Solid Core	Plam	PW-01																
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input checked="" type="checkbox"/> Anti-Ligature																				
MENTAL HEALTH GLASS TYPES: <input checked="" type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input checked="" type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input checked="" type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input checked="" type="checkbox"/> Shower Curtain- Anti-ligature <input type="checkbox"/> Ceiling IV Track																				
HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																					

MILLWORK: Upper Cabinets <input type="checkbox"/> Lower Cabinets/Drawers <input type="checkbox"/>	finish doors combination doors & open lockable adjustable shelves microwave shelf	Options: <input type="checkbox"/> Standing Height Counter	Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr></table> Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>	min. length (mm)	finish	min. length (mm)	finish
min. length (mm)	finish						
min. length (mm)	finish						

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="I"/> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td></td></tr></table>		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Anti-Ligature</td> <td>Electronic Control</td> </tr> </table> Provide remote water supply shut off by staff through BMS	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Anti-Ligature	Electronic Control
quantity	mounting type	faucet type	control type	plumbing remarks								
Lavatory	1	Wall Hung	Anti-Ligature	Electronic Control								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Shower												

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

--

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input checked="" type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%;"><tr><td></td></tr></table> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>		

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input checked="" type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock	
LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input checked="" type="checkbox"/> Night Light <input checked="" type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input checked="" type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks: <table border="1" style="width:100%; height: 50px;"><tr><td></td></tr></table>	

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	2
Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White	Code Pink	Staff Assist
Other					

IMIT Remarks:

--

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB	Washable
Wall	GWB	Washable
Floor	Resilient	Slip Resistant
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
C	2	1065 x 2135	Solid Core	Plam	PA-01

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: I Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
1	Wall Hung	Anti-Ligature	Electronic Control	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend; Intercom Station Video Intercom Station
A – Active/Allocated Data Port or Data Jack Overhead Paging (Pub Address)
I – Inactive/Unallocated Data Port or Data Jack Teleconferencing
C – Coax NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White	Code Pink	Staff Assist
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB - Impact Resistant Washable Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																																	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	
type	quantity	size	material	finish	Hardware Group																																																						
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input checked="" type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input checked="" type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																																					
MILLWORK: Upper Cabinets <input type="checkbox"/> finish doors <input type="checkbox"/> Lower Cabinets/Drawers <input type="checkbox"/> finish doors <input type="checkbox"/> combination doors & open <input type="checkbox"/> lockable <input type="checkbox"/> adjustable shelves <input type="checkbox"/> microwave shelf <input type="checkbox"/> Options: <input checked="" type="checkbox"/> Standing Height Counter		Countertop: min. length (mm) 1500 finish Plastic Laminate Washroom Vanity: Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																																																									

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2	Quad	4	Locate HK outlets at 1400mm AFF
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32	<input type="checkbox"/> Remote Power Shut-Off	<input type="checkbox"/> Headwall	<input type="checkbox"/> Clock
LIGHTING:			
<input type="checkbox"/> Workstation Task Light	<input type="checkbox"/> Bedside Staff Light	<input type="checkbox"/> Visitor Light	<input type="checkbox"/> Night Light
<input type="checkbox"/> Vanity Light	<input type="checkbox"/> In Use Light Laser and/or X-ray	<input type="checkbox"/> Zone Controller	<input type="checkbox"/> Colour Tunable
<input type="checkbox"/> Reading Light	<input type="checkbox"/> Hand Hygiene Sink Light	<input type="checkbox"/> Examination Light	<input type="checkbox"/> Shower Light
<input type="checkbox"/> Circadian Lighting	lighting remarks		

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																		
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																				
MEDICAL GASES: (Quantity)		Headwall 1		Headwall 2		Overhead Booms		Other												
		Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side															
Oxygen																				
Medical Air																				
Medical Vacuum																				
Nitrous Oxide																				
Nitrogen																				
CO2																				
Scavenging																				
Laser Smoke Evac.																				
Medical Gas Remarks:																				

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td></td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>			quantity	Telecommunication Outlets 2A/1I		Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet		<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																																					
	quantity																																																		
Telecommunication Outlets 2A/1I																																																			
Television Outlets 1A/1C/1NC																																																			
Patient Monitoring Outlets 2A Red Data Port																																																			
Headwall Outlets 2PM/3A (per headwall)																																																			
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>			quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:		<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td><td></td><td></td><td></td><td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td><td></td><td></td><td></td><td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td><td></td><td></td><td></td><td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td><td></td><td></td><td></td><td></td> </tr> <tr> <td>Other</td> <td></td><td></td><td></td><td></td><td></td> </tr> </tbody> </table>					quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																																		
DS Duty Station																																																			
MCS Full feature master control station																																																			
EPCA Emergency Pull Cord station with Audio																																																			
Other:																																																			
	quantity	feature 1	feature 2	feature 3	feature 4																																														
PS: Patient Station																																																			
2/3B: 2/3 button station																																																			
4B: 4 button station (single gang)																																																			
VST: VoIP Staff Terminal/Station																																																			
Other																																																			
IMIT Remarks:																																																			

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:	
VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:	

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	
--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
B	2	1830 x 2135	Solid Core	Plam	CL-10

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1			
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust Remarks:

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB - Impact Resistant Washable Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																																	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	
type	quantity	size	material	finish	Hardware Group																																																						
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																																					
MILLWORK: Upper Cabinets: <input type="checkbox"/> finish: doors: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/> finish: lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/> Options: <input type="checkbox"/> Standing Height Counter		Countertop: min. length (mm) finish: Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish: Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																																																									

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2	Quad	4	Locate HK outlets at 1400mm AFF
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks:

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																					
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																							
MEDICAL GASES: (Quantity)		Headwall 1 Nursing Side Non-Nursing Side		Headwall 2 Nursing Side Non-Nursing Side		Overhead Booms		Other															
Oxygen																							
Medical Air																							
Medical Vacuum																							
Nitrous Oxide																							
Nitrogen																							
CO2																							
Scavenging																							
Laser Smoke Evac.																							
Medical Gas Remarks:																							

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:		quantity		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet		<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing					
Telecommunication Outlets 2A/1I											
Television Outlets 1A/1C/1NC											
Patient Monitoring Outlets 2A Red Data Port											
Headwall Outlets 2PM/3A (per headwall)											
NURSE CALL:		quantity									
DS Duty Station											
MCS Full feature master control station											
EPCA Emergency Pull Cord station with Audio											
Other:											
		quantity		feature 1		feature 2		feature 3		feature 4	
PS: Patient Station											
2/3B: 2/3 button station											
4B: 4 button station (single gang)											
VST: VoIP Staff Terminal/Station											
Other											
IMIT Remarks:											
ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control											
VENTILATION: Relative Pressure: <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:											
SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System											

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Non-Skid
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	WR-03

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting Legend:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MILLWORK:

Upper Cabinets	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/> Standing Height Counter

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	1
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend:

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
1	Wall Hung	Gooseneck	Electronic Control	

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	KP-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				

Lighting Legend:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MILLWORK:

Upper Cabinets	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/> Standing Height Counter

Countertop: min. length (mm) 1800, finish Solid Surfacing

Washroom Vanity: min. length (mm) _____, finish _____

Reception, Transaction Counter, or Care Team Station Desk:

Patient Wardrobe:

Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	1
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend:

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks: _____

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control
Double Bowl	1	Counter	Gooseneck	Lever Blade

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	0
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: _____

VENTILATION: Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: Acoustic Tile (material), Pre-Finished (finish) Wall: GWB - Moisture and Mould Resistant (material), Paint (finish) Floor: Resilient (material), Non-Skid (finish) Base: Flash Cove (material)	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>KP-01</td> </tr> </tbody> </table>	type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	KP-01	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:30%;"> WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator </td> <td style="width:30%;"> WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature </td> <td style="width:30%;"> MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3 </td> <td style="width:30%;"> ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track </td> <td style="width:30%;"> HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws </td> </tr> </table>	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws
type	quantity	size	material	finish	Hardware Group														
A	1	914 x 2135	Solid Core	Plam	KP-01														
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws															

MILLWORK: Upper Cabinets: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/>	finish: _____ doors: <input type="checkbox"/> combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/>	Options: <input type="checkbox"/> Standing Height Counter	Countertop: min. length (mm) _____ finish _____ Washroom Vanity: min. length (mm) _____ finish _____ Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish _____ Patient Wardrobe: <input type="checkbox"/> finish _____ Mail Slots: <input type="checkbox"/> finish _____
--	---	--	---

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks: 10 Air changes per hour	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: _____

VENTILATION: Relative Pressure: Equal Positive Negative Other: _____
 Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks: _____

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Non-Skid
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	WR-03

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

MILLWORK:

Upper Cabinets	Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/> Standing Height Counter					

Countertop: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots: finish

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off

Headwall

Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

Upper Cabinets	Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/> Standing Height Counter					

Countertop: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots: finish

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Lavatory	1	Wall Hung	Gooseneck	Electronic Control

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: Shower

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	0
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>E</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CL-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	E	1	1065 x 2135	Solid Core	Plam	CL-01												
type	quantity	size	material	finish	Hardware Group																						
E	1	1065 x 2135	Solid Core	Plam	CL-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																						
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>2</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td>1</td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	2	Television Outlets 1A/1C/1NC	1	Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input checked="" type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	2																																					
Television Outlets 1A/1C/1NC	1																																					
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td>1</td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio	1	Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio	1																																					
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td>1</td> <td>Code Blue</td> <td>Code White</td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station	1	Code Blue	Code White			4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station	1	Code Blue	Code White																																			
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: Acoustic Tile (material), Washable (finish) Wall: GWB - Moisture and Mould Resistant (material), Washable (finish) Floor: Resilient (material), Slip Resistant (finish) Base: Rubber (material)	DOORS: type, quantity, size, material, finish, Hardware Group A, B, C, D, E, F, G, H Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight, <input type="checkbox"/> Integral Blinds, <input type="checkbox"/> Security Grille, <input type="checkbox"/> Laser Ready Integral Blinds	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards, <input type="checkbox"/> Hand Rails, <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails, <input checked="" type="checkbox"/> Sheet, <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds, <input type="checkbox"/> Roller Shade - Black Out, <input type="checkbox"/> Curtain Fabric, <input type="checkbox"/> Integral Blinds, <input type="checkbox"/> Roller Shade - Mesh, <input type="checkbox"/> Laser Ready Integral Blinds, <input type="checkbox"/> Vertical Blinds, <input type="checkbox"/> One Way Mirror, <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1, <input type="checkbox"/> EXT-2, <input type="checkbox"/> EXT-3, <input type="checkbox"/> INT-1, <input type="checkbox"/> INT-2, <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks, <input type="checkbox"/> Coat Hooks - Anti-ligature, <input type="checkbox"/> Mirror, <input type="checkbox"/> Mirror - Vandal Resistant, <input type="checkbox"/> Privacy Curtain, <input type="checkbox"/> Privacy Curtain - Anti-ligature, <input type="checkbox"/> Shower Seat, <input type="checkbox"/> Shower Curtain, <input type="checkbox"/> Shower Curtain - Anti-ligature, <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler, <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler, <input type="checkbox"/> Tamper proof screws and fittings, <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures, <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover, <input type="checkbox"/> Vandal resistant tamper proof and access panels, <input type="checkbox"/> Security-type ventilating grille, <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles, <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles, <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover, <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws
--	---	--	---	---	--	--

MILLWORK: Upper Cabinets: <input type="checkbox"/> finish, <input type="checkbox"/> doors, <input type="checkbox"/> combination doors & open, <input type="checkbox"/> lockable, <input type="checkbox"/> adjustable shelves, <input type="checkbox"/> microwave shelf Lower Cabinets/Drawers: <input type="checkbox"/> finish, <input type="checkbox"/> doors, <input type="checkbox"/> combination doors & open, <input type="checkbox"/> lockable, <input type="checkbox"/> adjustable shelves, <input type="checkbox"/> microwave shelf	Options: <input type="checkbox"/> Standing Height Counter	Countertop: min. length (mm), finish, Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: min. length (mm), finish, Patient Wardrobe: <input type="checkbox"/> finish, Mail Slots: <input type="checkbox"/> finish
--	---	---

MECHANICAL REQUIREMENTS

HVAC: Type: II Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table> Other Fixtures: <input type="checkbox"/> Urinal, <input type="checkbox"/> Instantaneous Hot Water, <input type="checkbox"/> Emergency Shower, <input type="checkbox"/> Macerator, <input type="checkbox"/> Eye Wash, <input type="checkbox"/> Floor Drain, <input type="checkbox"/> Water Closet	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control											
quantity	mounting type	faucet type	control type	plumbing remarks																	
1	Wall Hung	Gooseneck	Electronic Control																		

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout, Room Relative Humidity with Local Readout, Room Pressure Monitor with Local Readout, Room Control Remarks:

VENTILATION: Relative Pressure: Equal, Positive, Negative, Other: Exhaust Required: Yes, No, Dedicated Exhaust, Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	GFI	
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32, Remote Power Shut-Off, Headwall, Clock

LIGHTING:

Workstation Task Light, Bedside Staff Light, Visitor Light, Night Light, Vanity Light, In Use Light Laser and/or X-ray, Zone Controller, Colour Tunable, Reading Light, Hand Hygiene Sink Light, Examination Light, Shower Light, Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;	<input type="checkbox"/> Intercom Station
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack	<input type="checkbox"/> Video Intercom Station
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack	<input type="checkbox"/> Overhead Paging (Pub Address)
Patient Monitoring Outlets 2A Red Data Port		C – Coax	<input type="checkbox"/> Teleconferencing
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call	
		PM- Patient Monitoring Outlet	

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera, Panic Duress - Wired, Clinical Camera, Patient Wandering System, Clinical Camera Monitor, Security Camera Monitor, Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>WR-01</td> </tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	A	1	1065 x 2135	Solid Core	Plam	WR-01
GWB	Washable																						
GWB - Moisture and Mould Resistant	Washable																						
Resilient	Non-Skid																						
Flash Cove																							
type	quantity	size	material	finish	Hardware Group																		
A	1	1065 x 2135	Solid Core	Plam	WR-01																		
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input checked="" type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																					
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																					
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																							

MILLWORK:		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Countertop:	min. length (mm)	finish	Custom: Reception, Transaction Counter, or Care Team Station Desk:		<input type="checkbox"/>	finish		
Washroom Vanity:			Patient Wardrobe:		<input type="checkbox"/>			
			Mail Slots:		<input type="checkbox"/>			

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <input style="width:100%;" type="text"/>		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input type="checkbox"/>				quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Gooseneck	Electronic Control
quantity	mounting type	faucet type	control type	plumbing remarks											
Lavatory	1	Wall Hung	Gooseneck	Electronic Control											

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <input style="width:100%;" type="text"/>

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <input style="width:100%;" type="text"/> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <input style="width:100%;" type="text"/>

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock	LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input checked="" type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input checked="" type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks <input style="width:100%; height: 50px;" type="text"/>
--	---

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%;"> <tr> <th></th> <th>quantity</th> </tr> <tr><td>Telecommunication Outlets 2A/1I</td><td></td></tr> <tr><td>Television Outlets 1A/1C/1NC</td><td></td></tr> <tr><td>Patient Monitoring Outlets 2A Red Data Port</td><td></td></tr> <tr><td>Headwall Outlets 2PM/3A (per headwall)</td><td></td></tr> </table>		quantity	Telecommunication Outlets 2A/1I		Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing
	quantity											
Telecommunication Outlets 2A/1I												
Television Outlets 1A/1C/1NC												
Patient Monitoring Outlets 2A Red Data Port												
Headwall Outlets 2PM/3A (per headwall)												

NURSE CALL: <table border="1" style="width:100%;"> <tr> <th></th> <th>quantity</th> </tr> <tr><td>DS Duty Station</td><td></td></tr> <tr><td>MCS Full feature master control station</td><td></td></tr> <tr><td>EPCA Emergency Pull Cord station with Audio</td><td>1</td></tr> <tr><td>Other: _____</td><td></td></tr> </table>		quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio	1	Other: _____	
	quantity									
DS Duty Station										
MCS Full feature master control station										
EPCA Emergency Pull Cord station with Audio	1									
Other: _____										

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Infant Abduction System <input type="checkbox"/> Patient Wandering System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PA-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	PA-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	1065 x 2135	Solid Core	Plam	PA-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input checked="" type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>						
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 3000 finish Solid Surfacing Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	2	convenience
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

provide zone lighting controller.

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																						
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input checked="" type="checkbox"/> Intercom Station <input checked="" type="checkbox"/> Video Intercom Station <input checked="" type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	1																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td>1</td> <td>Code Blue</td> <td>Code White</td> <td>Code Pink</td> <td>Staff Assist</td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)	1	Code Blue	Code White	Code Pink	Staff Assist	VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)	1	Code Blue	Code White	Code Pink	Staff Assist																																	
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: Acoustic Tile (material), Washable (finish) Wall: GWB - Moisture and Mould Resistant (material), Washable (finish) Floor: Resilient (material), Slip Resistant (finish) Base: Rubber (material)	DOORS: type, quantity, size, material, finish, Hardware Group A, B, C, D, E, F, G, H Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws	

MILLWORK: Upper Cabinets: <input checked="" type="checkbox"/> Plastic Laminate Lower Cabinets/Drawers: <input checked="" type="checkbox"/> Plastic Laminate	finish, doors, combination doors & open, lockable, adjustable shelves, microwave shelf	Options: <input type="checkbox"/> Standing Height Counter
Countertop: 915 min. length (mm), Plastic Laminate finish Washroom Vanity:	Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>	finish

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: quantity, mounting type, faucet type, control type, plumbing remarks Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:
------------------------------------	---

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	pneumatic tube
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: provide nurse call connection to pneumatic tube

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	CR-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	1065 x 2135	Solid Core	Plam	CR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 7500 finish Solid Surfacing Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	2	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		2	charging stations
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

LIGHTING:
 Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks
 provide master zone lighting controller. Provide specialty lighting - LED under cabinet & cove lighting

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control	
quantity	mounting type	faucet type	control type	plumbing remarks							
1	Wall Hung	Gooseneck	Electronic Control								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:											

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port	2	C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	1
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)	1	Code Blue	Code White	Code Pink	Staff Assist
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: Paging system to annunciate a "Chime" to indicate the birth of a child. Locate Patient monitoring outlets in bulkhead.

SECURITY SYSTEM: <input checked="" type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Patient Wandering System <input checked="" type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input checked="" type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling Acoustic Tile Pre-Finished Wall GWB Paint Floor Resilient Slip Resistant Base Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	CR-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	1065 x 2135	Solid Core	Plam	CR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 7500 finish Solid Surfacing Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	2	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks										
quantity	mounting type	faucet type	control type	plumbing remarks												
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM:
 Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
B	1	1065 x 2135	Solid Core	Plam	KP-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	2
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)	1	Code Blue	Code White	Code Pink	
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: provide floor mounted outlets. Provide 1 data at entrance to room mounted at 1500mm AFF

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																																
type	quantity	size	material	finish	Hardware Group																																																				
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																																																							
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																																						
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td> </td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																															
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																																																		
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																																																		
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																																																			
Countertop: min. length (mm) finish 2,400 Solid Surfacing																																																									
Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patent Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																																																									

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																						
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th> </th> <th> </th> <th> </th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Medical Air</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Medical Vacuum</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Nitrous Oxide</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Nitrogen</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>CO2</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Scavenging</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Laser Smoke Evac.</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td> </td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td> </td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td> </td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																																			
	quantity																																														
Telecommunication Outlets 2A/1I	1																																														
Television Outlets 1A/1C/1NC																																															
Patient Monitoring Outlets 2A Red Data Port																																															
Headwall Outlets 2PM/3A (per headwall)																																															
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td> </td> </tr> <tr> <td>MCS Full feature master control station</td> <td> </td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td> </td> </tr> <tr> <td>Other: _____</td> <td> </td> </tr> </tbody> </table>		quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other: _____		<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td>Other</td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>		quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																														
DS Duty Station																																															
MCS Full feature master control station																																															
EPCA Emergency Pull Cord station with Audio																																															
Other: _____																																															
	quantity	feature 1	feature 2	feature 3	feature 4																																										
PS: Patient Station																																															
2/3B: 2/3 button station																																															
4B: 4 button station (single gang)																																															
VST: VoIP Staff Terminal/Station																																															
Other																																															
ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:																																															
VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:																																															
SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input checked="" type="checkbox"/> Infant Abduction System																																															

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>G</td> <td>1</td> <td>914 x 2135</td> <td>Aluminum</td> <td>Prefinished</td> <td>SL-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	G	1	914 x 2135	Aluminum	Prefinished	SL-01												
type	quantity	size	material	finish	Hardware Group																						
G	1	914 x 2135	Aluminum	Prefinished	SL-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		DOOR HARDWARE: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish 1500 Plastic Laminate Washroom Vanity: min. length (mm) finish Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/> finish																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks										
quantity	mounting type	faucet type	control type	plumbing remarks												
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;	
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack	<input type="checkbox"/> Intercom Station
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack	<input type="checkbox"/> Video Intercom Station
Patient Monitoring Outlets 2A Red Data Port		C – Coax	<input type="checkbox"/> Overhead Paging (Pub Address)
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call	<input type="checkbox"/> Teleconferencing
		PM- Patient Monitoring Outlet	

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM:
 Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling Acoustic Tile Pre-Finished Wall GWB Paint Floor Resilient Slip Resistant Base: Rubber	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PA-01</td> </tr> </tbody> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	type	quantity	size	material	finish	Hardware Group	B	1	914 x 2135	Solid Core	Plam	PA-01
type	quantity	size	material	finish	Hardware Group								
B	1	914 x 2135	Solid Core	Plam	PA-01								
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature												
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain- Anti-ligature <input type="checkbox"/> Ceiling IV Track												
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws													

MILLWORK: Upper Cabinets <input checked="" type="checkbox"/> Lower Cabinets/Drawers <input checked="" type="checkbox"/>	finish Plastic Laminate	doors <input type="checkbox"/>	combination doors & open <input checked="" type="checkbox"/>	lockable <input type="checkbox"/>	adjustable shelves <input checked="" type="checkbox"/>	microwave shelf <input type="checkbox"/>	Options: <input checked="" type="checkbox"/> Standing Height Counter
Countertop: min. length (mm) 3000 finish Plastic Laminate	Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Washroom Vanity: Mail Slots: <input type="checkbox"/>						

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control
--

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="text"/> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <input type="text"/>

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2	Duplex	1	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		2	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input checked="" type="checkbox"/> Clock
LIGHTING: <input checked="" type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks: <input type="text"/>

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>2</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td> </td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td> </td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td> </td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	2	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing
	quantity											
Telecommunication Outlets 2A/1I	2											
Television Outlets 1A/1C/1NC												
Patient Monitoring Outlets 2A Red Data Port												
Headwall Outlets 2PM/3A (per headwall)												

NURSE CALL: DS Duty Station MCS Full feature master control station EPCA Emergency Pull Cord station with Audio Other: <input type="text"/>	quantity
--	----------

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input checked="" type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																																	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input checked="" type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	
type	quantity	size	material	finish	Hardware Group																																																						
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																																					
MILLWORK: Upper Cabinets: <input type="checkbox"/> finish: doors: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/> finish: doors: <input type="checkbox"/> Combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/> Options: <input type="checkbox"/> Standing Height Counter		Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																																																									

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	15A/20A, 120V Housekeeping		3	crash cart
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting Legend:
 Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks:

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																					
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																							
MEDICAL GASES: (Quantity)		Headwall 1		Headwall 2		Overhead Booms		Other															
		Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																		
Oxygen																							
Medical Air																							
Medical Vacuum																							
Nitrous Oxide																							
Nitrogen																							
CO2																							
Scavenging																							
Laser Smoke Evac.																							
Medical Gas Remarks:																							

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>3</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>			quantity	Telecommunication Outlets 2A/1I	3	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet		<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																																					
	quantity																																																		
Telecommunication Outlets 2A/1I	3																																																		
Television Outlets 1A/1C/1NC																																																			
Patient Monitoring Outlets 2A Red Data Port																																																			
Headwall Outlets 2PM/3A (per headwall)																																																			
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>			quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:		<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td><td></td><td></td><td></td><td></td></tr> <tr> <td>2/3B: 2/3 button station</td> <td></td><td></td><td></td><td></td><td></td></tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td><td></td><td></td><td></td><td></td></tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td><td></td><td></td><td></td><td></td></tr> <tr> <td>Other</td> <td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																																		
DS Duty Station																																																			
MCS Full feature master control station																																																			
EPCA Emergency Pull Cord station with Audio																																																			
Other:																																																			
	quantity	feature 1	feature 2	feature 3	feature 4																																														
PS: Patient Station																																																			
2/3B: 2/3 button station																																																			
4B: 4 button station (single gang)																																																			
VST: VoIP Staff Terminal/Station																																																			
Other																																																			
IMIT Remarks:																																																			

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:	
VENTILATION: Relative Pressure: <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:	

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input checked="" type="checkbox"/> Infant Abduction System			
--	--	--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets <input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers <input type="checkbox"/>						

Countertop: Reception, Transaction Counter, or Care Team Station Desk:

Washroom Vanity: Patient Wardrobe:

Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout

Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust

Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
UPS	Vital	15A/20A, 120V Housekeeping	3	crash cart
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	3
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	OF-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

MILLWORK:

Upper Cabinets	Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/> Standing Height Counter					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

Upper Cabinets	Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/> Standing Height Counter					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	OF-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

MILLWORK:

Upper Cabinets	Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/> Standing Height Counter					

Countertop: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots: finish

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

Upper Cabinets	Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/> Standing Height Counter					

Countertop: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots: finish

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout

Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust

Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	OF-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
G	1	914 x 2135	Solid Core	Plam	SL-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout

Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust

Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: Acoustic Tile (material), Pre-Finished (finish) Wall: GWB (material), Paint (finish) Floor: Resilient (material), Slip Resistant (finish) Base: Rubber (material)	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	type	quantity	size	material	finish	Hardware Group																																																	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator
type	quantity	size	material	finish	Hardware Group																																																			
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																																					

MILLWORK: Upper Cabinets: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/>	finish: doors: combination doors & open: lockable: adjustable shelves: microwave shelf:	Options: <input type="checkbox"/> Standing Height Counter	Countertop: min. length (mm) 915, finish Solid Surfacing Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>
--	---	---	--

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <input type="text"/>
--

VENTILATION: Relative Pressure: <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="text"/> Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <input type="text"/>
--

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: <input type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other: <input type="text"/>					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input checked="" type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	Acoustic Tile	Washable
Wall	GWB	Washable
Floor	Resilient	Slip Resistant
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
H	1	1830 x 2135	Aluminum	Prefinished	SL-02

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: II

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
1	Wall Hung	Gooseneck	Electronic Control	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			
Oxygen	1	1					
Medical Air	1	1					
Medical Vacuum	1	1					
Nitrous Oxide	1						
Nitrogen							
CO2							
Scavenging	0	1					
Laser Smoke Evac.							

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex headwall & 1 duplex bed
	Duplex		3	2 duplex headwall & 1 duplex above bed right side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	0
Patient Monitoring Outlets 2A Red Data Port	1
Headwall Outlets 2PM/3A (per headwall)	1

Legend; Intercom Station Video Intercom Station
A – Active/Allocated Data Port or Data Jack Overhead Paging (Pub Address)
I – Inactive/Unallocated Data Port or Data Jack Teleconferencing
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Code White	Patient Assist	
2/3B: 2/3 button station	2	Code Blue	Code White	Code Pink	Patient Assist
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: Locate 1 x 2/3b at entrance to room c/w (code blue, code white) and 1 x 2/3b button at headwall c/w (code pink, staff assist).

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Waterproof Cover.</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>	GWB - Moisture and Mould Resistant	Washable	GWB - Moisture and Mould Resistant	Waterproof Cover.	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%;"><tr><th>type</th><th>quantity</th><th>size</th><th>material</th><th>finish</th><th>Hardware Group</th></tr><tr><td>A</td><td>1</td><td>1065 x 2135</td><td>Solid Core</td><td>Plam</td><td>WR-01</td></tr></table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight, <input type="checkbox"/> Integral Blinds, <input type="checkbox"/> Security Grille, <input type="checkbox"/> Laser Ready Integral Blinds	type	quantity	size	material	finish	Hardware Group	A	1	1065 x 2135	Solid Core	Plam	WR-01
GWB - Moisture and Mould Resistant	Washable																				
GWB - Moisture and Mould Resistant	Waterproof Cover.																				
Resilient	Non-Skid																				
Flash Cove																					
type	quantity	size	material	finish	Hardware Group																
A	1	1065 x 2135	Solid Core	Plam	WR-01																
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																				
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input checked="" type="checkbox"/> Shower Seat <input checked="" type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain- Anti-ligature <input type="checkbox"/> Ceiling IV Track																				
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																					

MILLWORK: Upper Cabinets <input type="checkbox"/> Lower Cabinets/Drawers <input type="checkbox"/>	finish <input type="checkbox"/> <input type="checkbox"/>	doors <input type="checkbox"/> <input type="checkbox"/>	combination doors & open <input type="checkbox"/> <input type="checkbox"/>	lockable <input type="checkbox"/> <input type="checkbox"/>	adjustable shelves <input type="checkbox"/> <input type="checkbox"/>	microwave shelf <input type="checkbox"/> <input type="checkbox"/>	Options: <input type="checkbox"/> Standing Height Counter	
Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr></table>	min. length (mm)	finish	Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/>	Patient Wardrobe: <input type="checkbox"/>	Mail Slots: <input type="checkbox"/>	Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr></table>	min. length (mm)	finish
min. length (mm)	finish							
min. length (mm)	finish							

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <table border="1" style="width:100%; height: 50px;"></table>	PLUMBING: <table border="1" style="width:100%;"><tr><th>quantity</th><th>mounting type</th><th>faucet type</th><th>control type</th><th>plumbing remarks</th></tr><tr><td>Lavatory</td><td>1</td><td>Wall Hung</td><td>Gooseneck</td><td>Electronic Control</td></tr></table>	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Gooseneck	Electronic Control
quantity	mounting type	faucet type	control type	plumbing remarks							
Lavatory	1	Wall Hung	Gooseneck	Electronic Control							
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Shower	plumbing remarks: <table border="1" style="width:100%; height: 50px;"></table>										

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <table border="1" style="width:100%; height: 20px;"></table>
--

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%; height: 20px;"></table> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%; height: 20px;"></table>

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock	LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input checked="" type="checkbox"/> Night Light <input checked="" type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input checked="" type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks: <table border="1" style="width:100%; height: 50px;"></table>
--	--

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	2
Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input checked="" type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: material: <input type="checkbox"/> Washable Wall: material: <input type="checkbox"/> Washable Floor: material: <input type="checkbox"/> Non-Skid Base: material: <input type="checkbox"/> Flash Cove	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>B</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>KP-01</td> </tr> </table>	type	quantity	size	material	finish	Hardware Group	B	1	1220 x 2135	Solid Core	Plam	KP-01	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws
type	quantity	size	material	finish	Hardware Group													
B	1	1220 x 2135	Solid Core	Plam	KP-01													

MILLWORK: Upper Cabinets: <input checked="" type="checkbox"/> Stainless Steel Lower Cabinets/Drawers: <input checked="" type="checkbox"/> Stainless Steel	finish: <input type="checkbox"/> Stainless Steel doors: <input type="checkbox"/> combination doors & open: <input checked="" type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input checked="" type="checkbox"/>	Options: <input checked="" type="checkbox"/> Standing Height Counter	Countertop: min. length (mm): 5000, finish: Stainless Steel Washroom Vanity: min. length (mm): _____, finish: _____	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>
--	--	---	--	---

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="checkbox"/> III Remarks: _____	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> <tr> <td>Double Bowl</td> <td>1</td> <td>Counter</td> <td>Gooseneck</td> <td>Lever Blade</td> </tr> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control	Double Bowl	1	Counter	Gooseneck	Lever Blade	Other Fixtures: <input type="checkbox"/> Urinal: <input checked="" type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>
quantity	mounting type	faucet type	control type	plumbing remarks													
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control													
Double Bowl	1	Counter	Gooseneck	Lever Blade													

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: _____

VENTILATION: Relative Pressure: Equal Positive Negative Other: _____
 Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2	30A, 208Volt, 3 Phase	1	4 wire connection / future retherm units
	Conditional 3	30A, 208Volt, 1 Phase	1	3 wire connection / future retherm units
	Delayed Vital			
Vital	Duplex		2	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks: _____

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: locate 2/3B button at door

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	Acoustic Tile	Washable
Wall	GWB - Impact Resistant	Washable
Floor	Resilient	Slip Resistant
Base:	Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
C	1	1220 x 2135	Solid Core	Plam	CR-01

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2	Quad	6	provide recep. on 1 m centers mounted at 1400mm AFF
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend; Intercom Station Video Intercom Station
A – Active/Allocated Data Port or Data Jack Overhead Paging (Pub Address)
I – Inactive/Unallocated Data Port or Data Jack Teleconferencing
C – Coax NC – Nurse Call
PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

DOORS:

type	quantity	size	material	finish	Hardware Group
G	2	1220 x 2135	Aluminum	Prefinished	AO-01

Door Hardware: Access Control

Other Features:
 Sidelight
 Integral Blinds
 Security Grille
 Laser Ready Integral Blinds

MILLWORK:

Upper Cabinets	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Countertop: min. length (mm) 3000 finish Solid Surfacing

Washroom Vanity: min. length (mm) finish

Reception, Transaction Counter, or Care Team Station Desk: finish

Patient Wardrobe: finish

Mail Slots: finish

MECHANICAL REQUIREMENTS

HVAC: Type: II

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene: 1	Wall Hung	Gooseneck	Electronic Control	

Other Fixtures:
 Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout

Room Control Remarks: BMS Monitor and Control

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust

Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off

Headwall

Clock

LIGHTING:

Workstation Task Light

Bedside Staff Light

Visitor Light

Night Light

Vanity Light

In Use Light Laser and/or X-ray

Zone Controller

Colour Tunable

Reading Light

Hand Hygiene Sink Light

Examination Light

Shower Light

Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack Intercom Station

I – Inactive/Unallocated Data Port or Data Jack Video Intercom Station

C – Coax Overhead Paging (Pub Address)

NC – Nurse Call Teleconferencing

PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White	Staff Assist	
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: locate 2/3B button at door

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System

Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB	Washable
Wall	GWB	Washable
Floor	Resilient	Slip Resistant
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
B	1	1220 x 2135	Solid Core	Plam	CR-01

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) 0 finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES: (Quantity)

	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack Intercom Station
I – Inactive/Unallocated Data Port or Data Jack Video Intercom Station
C – Coax Overhead Paging (Pub Address)
NC – Nurse Call Teleconferencing
PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>	GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>B</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CL-02</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	type	quantity	size	material	finish	Hardware Group	B	1	1220 x 2135	Solid Core	Plam	CL-02
GWB	Washable																				
GWB - Moisture and Mould Resistant	Washable																				
Resilient	Slip Resistant																				
Flash Cove																					
type	quantity	size	material	finish	Hardware Group																
B	1	1220 x 2135	Solid Core	Plam	CL-02																
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																				
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																				
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																					

MILLWORK: Upper Cabinets: <input checked="" type="checkbox"/> Stainless Steel Lower Cabinets/Drawers: <input type="checkbox"/>	finish doors combination doors & open lockable adjustable shelves microwave shelf	Options: <input type="checkbox"/> Standing Height Counter				
Countertop: <table border="1" style="width:100%;"><tr><td>2400</td><td>Stainless Steel</td></tr></table>	2400	Stainless Steel	Washroom Vanity: <table border="1" style="width:100%;"><tr><td></td><td></td></tr></table>			Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>
2400	Stainless Steel					

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>III</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td></td></tr></table>	III		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> <tr> <td>1</td> <td>Counter</td> <td>Gooseneck</td> <td>Lever Blade</td> <td></td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input checked="" type="checkbox"/> Macerator: <input checked="" type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control		1	Counter	Gooseneck	Lever Blade	
III																		
quantity	mounting type	faucet type	control type	plumbing remarks														
1	Wall Hung	Gooseneck	Electronic Control															
1	Counter	Gooseneck	Lever Blade															

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

--

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control
--

VENTILATION: Relative Pressure: <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%;"><tr><td></td></tr></table> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>		

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock	
LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input checked="" type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks: <table border="1" style="width:100%; height: 50px;"><tr><td></td></tr></table>	

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet
	quantity										
Telecommunication Outlets 2A/1I	1										
Television Outlets 1A/1C/1NC											
Patient Monitoring Outlets 2A Red Data Port											
Headwall Outlets 2PM/3A (per headwall)											

NURSE CALL: DS Duty Station MCS Full feature master control station EPCA Emergency Pull Cord station with Audio Other: <table border="1" style="width:100%;"><tr><td></td></tr></table>		quantity 1

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>	

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input checked="" type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																																	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input checked="" type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	
type	quantity	size	material	finish	Hardware Group																																																						
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																																					
MILLWORK: Upper Cabinets: <input type="checkbox"/> finish: doors: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/> finish: doors: <input type="checkbox"/> Combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/> Options: <input type="checkbox"/> Standing Height Counter		Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																																																									

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks:

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																					
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																							
MEDICAL GASES: (Quantity)		Headwall 1 Nursing Side Non-Nursing Side		Headwall 2 Nursing Side Non-Nursing Side		Overhead Booms _____		Other															
Oxygen																							
Medical Air																							
Medical Vacuum																							
Nitrous Oxide																							
Nitrogen																							
CO2																							
Scavenging																							
Laser Smoke Evac.																							

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: _____

VENTILATION: Relative Pressure: Equal Positive Negative Other: _____
 Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;	<input type="checkbox"/> Intercom Station
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack	<input type="checkbox"/> Video Intercom Station
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack	<input type="checkbox"/> Overhead Paging (Pub Address)
Patient Monitoring Outlets 2A Red Data Port		C – Coax	<input type="checkbox"/> Teleconferencing
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet	

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB - Impact & Moisture and Mould Resistant	Washable
Floor: Resilient	Non-Skid
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
C	1	1220 x 2135	Solid Core	Plam	CR-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	3	Locate HK outlets at 1400mm AFF
	Normal 2	Duplex	1	GFI
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control
Janitorial	1	Floor	Standard	Lever Blade

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: Detergent Dispenser

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB	Washable
Wall	GWB - Moisture and Mould Resistant	Washable
Floor	Resilient	Slip Resistant
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
C	1	1220 x 2135	Solid Core	Plam	CR-01

Door Hardware: Access Control

Other Features:
 Sidelight
 Integral Blinds
 Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
1	Wall Hung	Gooseneck	Electronic Control	

Other Fixtures:
 Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;
A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	0
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	0				
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>F</td> <td>1</td> <td>1530 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	F	1	1530 x 2135	Solid Core	Plam	PR-01												
type	quantity	size	material	finish	Hardware Group																						
F	1	1530 x 2135	Solid Core	Plam	PR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input checked="" type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input checked="" type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input checked="" type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 3000 finish Solid Surfacing Washroom Vanity: finish Plastic Laminate Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input checked="" type="checkbox"/> Plastic Laminate Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex at headwall & 1 duplex for bed
UPS	Duplex		3	2 duplex at headwall & 1 duplex above bed non-nursing side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input checked="" type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input checked="" type="checkbox"/> Headwall <input checked="" type="checkbox"/> Clock
LIGHTING: <input checked="" type="checkbox"/> Workstation Task Light <input checked="" type="checkbox"/> Bedside Staff Light <input checked="" type="checkbox"/> Visitor Light <input checked="" type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input checked="" type="checkbox"/> Colour Tunable <input checked="" type="checkbox"/> Reading Light <input checked="" type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting
lighting remarks provide bedside staff light in infant zone and headwall

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC	1	I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port	1	C – Coax
Headwall Outlets 2PM/3A (per headwall)	1	NC – Nurse Call PM- Patient Monitoring Outlet

MECHANICAL REQUIREMENTS

HVAC: Type: II Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control	
quantity	mounting type	faucet type	control type	plumbing remarks							
1	Wall Hung	Gooseneck	Electronic Control								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>											

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	2
Other: Family zone and sleeper chair	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Code White	Patient Assist	
2/3B: 2/3 button station					
4B: 4 button station (single gang)	1	Code Blue	Code White	Code Pink	Staff Assist
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White		
Other					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			
Oxygen	1	1	1	1			
Medical Air	1	1	1	1			
Medical Vacuum	1	1	1	1			
Nitrous Oxide		1					
Nitrogen							
CO2							
Scavenging		1					
Laser Smoke Evac.							

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

IMIT Remarks: Locate 2/3b at entrance to room. Provide 4B at bassinette

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: material: Washable Wall: material: Waterproof Cover. Floor: material: Resilient Base: material: Flash Cove	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PW-01</td> </tr> </table>	type	quantity	size	material	finish	Hardware Group	A	1	1065 x 2135	Solid Core	Plam	PW-01	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator									
type	quantity	size	material	finish	Hardware Group																		
A	1	1065 x 2135	Solid Core	Plam	PW-01																		
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input checked="" type="checkbox"/> Shower Seat <input checked="" type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain- Anti-ligature <input type="checkbox"/> Ceiling IV Track																					
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>					
finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																	
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																	
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																		
Countertop: min. length (mm): 914 finish: Solid Surfacing			HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																				

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	3	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Lighting: <input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input checked="" type="checkbox"/> Night Light <input checked="" type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input checked="" type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks:				

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Counter</td> <td>Gooseneck</td> <td>Lever Blade</td> </tr> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Counter	Gooseneck	Lever Blade
quantity	mounting type	faucet type	control type	plumbing remarks							
Lavatory	1	Counter	Gooseneck	Lever Blade							
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Bath tub & Shower											

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	2
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: Locate 1 EPCA between toilet and sink, 1 adjacent to shower, 1 next to tub

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB	Washable
Wall	GWB	Washable
Floor	Resilient	Slip Resistant
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
F	1	1530 x 2135	Solid Core	Plam	PR-01

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Countertop: min. length (mm) 3000 finish Solid Surfacing

Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: finish Plastic Laminate
Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: I

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
1	Wall Hung	Gooseneck	Electronic Control	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			
Oxygen	1	1	1	1			
Medical Air	1	1	1	1			
Medical Vacuum	1	1	1	1			
Nitrous Oxide		1					
Nitrogen							
CO2							
Scavenging		1					
Laser Smoke Evac.							

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex at headwall & 1 duplex for bed
	Duplex		3	2 duplex at HW & 1 duplex above bed non-nursing side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks
provide bedside staff light in infant zone and headwall

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	1
Patient Monitoring Outlets 2A Red Data Port	1
Headwall Outlets 2PM/3A (per headwall)	1

Legend;
A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	2
Other: Family zone and sleeper chair	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Code White	Patient Assist	
2/3B: 2/3 button station					
4B: 4 button station (single gang)	1	Code Blue	Code White	Code Pink	Staff Assist
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White		
Other					

IMIT Remarks: Locate 2/3b at entrance to room. Provide 4B at bassinette

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
C	2	1065 x 2135	Solid Core	Plam	PA-01

Access Control Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: I

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White	Code Pink	Staff Assist
Other					

IMIT Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Waterproof Cover.</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>	GWB - Moisture and Mould Resistant	Washable	GWB - Moisture and Mould Resistant	Waterproof Cover.	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%;"><tr><th>type</th><th>quantity</th><th>size</th><th>material</th><th>finish</th><th>Hardware Group</th></tr><tr><td>A</td><td>1</td><td>1065 x 2135</td><td>Solid Core</td><td>Plam</td><td>PW-01</td></tr></table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	type	quantity	size	material	finish	Hardware Group	A	1	1065 x 2135	Solid Core	Plam	PW-01
GWB - Moisture and Mould Resistant	Washable																				
GWB - Moisture and Mould Resistant	Waterproof Cover.																				
Resilient	Non-Skid																				
Flash Cove																					
type	quantity	size	material	finish	Hardware Group																
A	1	1065 x 2135	Solid Core	Plam	PW-01																
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																				
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input checked="" type="checkbox"/> Shower Seat <input checked="" type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain- Anti-ligature <input type="checkbox"/> Ceiling IV Track																				
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																					

MILLWORK: Upper Cabinets <input type="checkbox"/> Lower Cabinets/Drawers <input type="checkbox"/>	finish doors combination doors & open lockable adjustable shelves microwave shelf	Options: <input type="checkbox"/> Standing Height Counter	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>	min. length (mm) finish Custom: finish
Countertop:	914	Solid Surfacing		

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <input style="width:100%;" type="text"/>	PLUMBING: <table border="1" style="width:100%;"><tr><th>quantity</th><th>mounting type</th><th>faucet type</th><th>control type</th><th>plumbing remarks</th></tr><tr><td>Lavatory</td><td>1</td><td>Counter</td><td>Gooseneck</td><td>Lever Blade</td></tr></table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Bath tub & Shower	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Counter	Gooseneck	Lever Blade
quantity	mounting type	faucet type	control type	plumbing remarks							
Lavatory	1	Counter	Gooseneck	Lever Blade							

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	3	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	3
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>F</td> <td>1</td> <td>1530 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	F	1	1530 x 2135	Solid Core	Plam	PR-01												
type	quantity	size	material	finish	Hardware Group																						
F	1	1530 x 2135	Solid Core	Plam	PR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input checked="" type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input checked="" type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 600 finish Solid Surfacing Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Plastic Laminate Patient Wardrobe: <input checked="" type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex at headwall & 1 duplex for bed
	Duplex		3	2 duplex at HW & 1 duplex above bed non-nursing side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input checked="" type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input checked="" type="checkbox"/> Headwall <input checked="" type="checkbox"/> Clock
LIGHTING: <input checked="" type="checkbox"/> Workstation Task Light <input checked="" type="checkbox"/> Bedside Staff Light <input checked="" type="checkbox"/> Visitor Light <input checked="" type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input checked="" type="checkbox"/> Colour Tunable <input checked="" type="checkbox"/> Reading Light <input checked="" type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting
lighting remarks provide bedside staff light in infant zone and headwall

MECHANICAL REQUIREMENTS

HVAC: Type: II Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control	
quantity	mounting type	faucet type	control type	plumbing remarks							
1	Wall Hung	Gooseneck	Electronic Control								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>											

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen	1	1						
Medical Air	1	1						
Medical Vacuum	1	1						
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC	1	I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port	1	C – Coax
Headwall Outlets 2PM/3A (per headwall)	1	NC – Nurse Call PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other: Family zone	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Code White	Patient Assist	
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White		
Other					

IMIT Remarks: Locate 2/3b at entrance to room

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: material: <input type="checkbox"/> Washable Wall: material: <input type="checkbox"/> Waterproof Cover. Floor: material: <input type="checkbox"/> Non-Skid Base: material: <input type="checkbox"/> Flash Cove	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PW-01</td> </tr> </table>	type	quantity	size	material	finish	Hardware Group	A	1	1065 x 2135	Solid Core	Plam	PW-01	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator
type	quantity	size	material	finish	Hardware Group									
A	1	1065 x 2135	Solid Core	Plam	PW-01									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input checked="" type="checkbox"/> Shower Seat <input checked="" type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain- Anti-ligature <input type="checkbox"/> Ceiling IV Track												
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws														

MILLWORK: Upper Cabinets: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/>	finish: _____ doors: <input type="checkbox"/> combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input checked="" type="checkbox"/> microwave shelf: <input type="checkbox"/>	Options: <input type="checkbox"/> Standing Height Counter	Countertop: min. length (mm) _____ finish _____ Washroom Vanity: _____ Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> _____ finish _____ Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/> _____
--	--	--	---

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="checkbox"/> III Remarks: _____	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Lever Blade</td> </tr> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Gooseneck	Lever Blade
quantity	mounting type	faucet type	control type	plumbing remarks							
Lavatory	1	Wall Hung	Gooseneck	Lever Blade							
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Shower											

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: _____

VENTILATION: Relative Pressure: Equal Positive Negative Other: _____
 Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	3	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	2
Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

- SECURITY SYSTEM:**
- Security Camera
 - Clinical Camera Monitor
 - Panic Duress - Wired
 - Security Camera Monitor
 - Clinical Camera
 - Infant Abduction System
 - Patient Wandering System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>F</td> <td>1</td> <td>1530 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PR-01</td> </tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	F	1	1530 x 2135	Solid Core	Plam	PR-01		
GWB	Washable																								
GWB	Washable																								
Resilient	Slip Resistant																								
Flash Cove																									
type	quantity	size	material	finish	Hardware Group																				
F	1	1530 x 2135	Solid Core	Plam	PR-01																				
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input checked="" type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																							
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input checked="" type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input checked="" type="checkbox"/> Ceiling IV Track																							
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm): 600</td><td>finish: Solid Surfacing</td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm):</td><td>finish:</td></tr></table>		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Lower Cabinets/Drawers	<input type="checkbox"/>	min. length (mm): 600	finish: Solid Surfacing	min. length (mm):	finish:	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws					
finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																				
min. length (mm): 600	finish: Solid Surfacing																								
min. length (mm):	finish:																								
Options: <input type="checkbox"/> Standing Height Counter <input checked="" type="checkbox"/> Plastic Laminate <input type="checkbox"/> Mail Slots																									

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex at headwall & 1 duplex for bed
UPS	Duplex		3	2 duplex at HW & 1 duplex above bed non-nursing side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

provide bedside staff light in infant zone and headwall

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>I</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td></td></tr></table>	I		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>	quantity	mounting type	faucet type	control type	plumbing remarks	Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control										
I																							
quantity	mounting type	faucet type	control type	plumbing remarks																			
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control																			

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen	1	1						
Medical Air	1	1						
Medical Vacuum	1	1						
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

--

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout
 Room Relative Humidity with Local Readout
 Room Pressure Monitor with Local Readout
 Room Control Remarks:

--

VENTILATION: Relative Pressure: Equal Positive Negative Other:

--

 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

--

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC	1	I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port	1	C – Coax
Headwall Outlets 2PM/3A (per headwall)	1	NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other: Family zone	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Code White	Patient Assist	
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White		
Other					

IMIT Remarks:

Locate 2/3b at entrance to room

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
C	2	1065 x 2135	Solid Core	Plam	PA-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Lighting:				
<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input checked="" type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks				

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: I

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White	Code Pink	Staff Assist
Other					

IMIT Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: material: <input type="checkbox"/> Washable Wall: material: <input type="checkbox"/> Waterproof Cover. Floor: material: <input type="checkbox"/> Non-Skid Base: material: <input type="checkbox"/> Flash Cove	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PW-01</td> </tr> </table>	type	quantity	size	material	finish	Hardware Group	A	1	1065 x 2135	Solid Core	Plam	PW-01	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator									
type	quantity	size	material	finish	Hardware Group																		
A	1	1065 x 2135	Solid Core	Plam	PW-01																		
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input checked="" type="checkbox"/> Shower Seat <input checked="" type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain- Anti-ligature <input type="checkbox"/> Ceiling IV Track																					
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>					
finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																	
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																	
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																		
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: min. length (mm) finish Patient Wardrobe: <input type="checkbox"/> finish Mail Slots: <input type="checkbox"/> finish																							

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	3	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="checkbox"/> III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Lever Blade</td> </tr> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Gooseneck	Lever Blade
quantity	mounting type	faucet type	control type	plumbing remarks							
Lavatory	1	Wall Hung	Gooseneck	Lever Blade							
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Shower											

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	2
Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

DOORS:

type	quantity	size	material	finish	Hardware Group

Access Control Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	GFI
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Lighting:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

Upper Cabinets	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/> Standing Height Counter

Countertop: min. length (mm) 1800 finish Solid Surfacing
 Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: finish
 Patient Wardrobe:
 Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Double Bowl	1	Counter	Gooseneck	Lever Blade

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																																	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	
type	quantity	size	material	finish	Hardware Group																																																						
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																																					
MILLWORK: Upper Cabinets: <input type="checkbox"/> finish: doors: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/> finish: lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/> Options: <input type="checkbox"/> Standing Height Counter		Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																																																									

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks:

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																					
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																							
MEDICAL GASES: (Quantity)		Headwall 1 Nursing Side Non-Nursing Side		Headwall 2 Nursing Side Non-Nursing Side		Overhead Booms _____		Other															
Oxygen																							
Medical Air																							
Medical Vacuum																							
Nitrous Oxide																							
Nitrogen																							
CO2																							
Scavenging																							
Laser Smoke Evac.																							
Medical Gas Remarks:																							

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr><td>Telecommunication Outlets 2A/1I</td><td></td></tr> <tr><td>Television Outlets 1A/1C/1NC</td><td></td></tr> <tr><td>Patient Monitoring Outlets 2A Red Data Port</td><td></td></tr> <tr><td>Headwall Outlets 2PM/3A (per headwall)</td><td></td></tr> </tbody> </table>			quantity	Telecommunication Outlets 2A/1I		Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet		<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																																					
	quantity																																																		
Telecommunication Outlets 2A/1I																																																			
Television Outlets 1A/1C/1NC																																																			
Patient Monitoring Outlets 2A Red Data Port																																																			
Headwall Outlets 2PM/3A (per headwall)																																																			
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr><td>DS Duty Station</td><td></td></tr> <tr><td>MCS Full feature master control station</td><td></td></tr> <tr><td>EPCA Emergency Pull Cord station with Audio</td><td></td></tr> <tr><td>Other: _____</td><td></td></tr> </tbody> </table>			quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other: _____		<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr><td>PS: Patient Station</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>2/3B: 2/3 button station</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>4B: 4 button station (single gang)</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>VST: VoIP Staff Terminal/Station</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Other</td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																																		
DS Duty Station																																																			
MCS Full feature master control station																																																			
EPCA Emergency Pull Cord station with Audio																																																			
Other: _____																																																			
	quantity	feature 1	feature 2	feature 3	feature 4																																														
PS: Patient Station																																																			
2/3B: 2/3 button station																																																			
4B: 4 button station (single gang)																																																			
VST: VoIP Staff Terminal/Station																																																			
Other																																																			
ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:		IMIT Remarks:																																																	
VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:		SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input checked="" type="checkbox"/> Infant Abduction System																																																	

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: Acoustic Tile (material), Washable (finish) Wall: GWB - Impact Resistant (material), Washable (finish) Floor: Resilient (material), Slip Resistant (finish) Base: Rubber (material)	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	type	quantity	size	material	finish	Hardware Group																																											WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws
type	quantity	size	material	finish	Hardware Group																																																	

MILLWORK: Upper Cabinets: <input type="checkbox"/> finish: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/> finish: <input type="checkbox"/>	doors: <input type="checkbox"/> combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/>	Options: <input type="checkbox"/> Standing Height Counter	Countertop: min. length (mm) <input type="text"/> finish <input type="text"/> Washroom Vanity: min. length (mm) <input type="text"/> finish <input type="text"/>	Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish <input type="text"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/> finish <input type="text"/>
--	--	--	---	---

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks: <input style="width:100%;" type="text"/>	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>
quantity	mounting type	faucet type	control type	plumbing remarks																		

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks	
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF	
	Normal 2	Quad	4	Locate HK outlets at 1400mm AFF	
	Conditional 1				
	Conditional 2				
	Conditional 3				
	Delayed Vital				
Vital					
UPS					
Boom:	Normal				
	Conditional				
	Delayed Vital				
	Vital				
	UPS				
Boom:	Normal				
	Conditional				
	Delayed Vital				
	Vital				
	UPS				
Boom:	Normal				
	Conditional				
	Delayed Vital				
	Vital				
	UPS				

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: <input style="width:100%;" type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

- SECURITY SYSTEM:**
- Security Camera
 - Clinical Camera Monitor
 - Panic Duress - Wired
 - Security Camera Monitor
 - Clinical Camera
 - Infant Abduction System
 - Patient Wandering System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>	GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>WR-01</td> </tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	type	quantity	size	material	finish	Hardware Group	A	1	1065 x 2135	Solid Core	Plam	WR-01
GWB	Washable																				
GWB - Moisture and Mould Resistant	Washable																				
Resilient	Non-Skid																				
Flash Cove																					
type	quantity	size	material	finish	Hardware Group																
A	1	1065 x 2135	Solid Core	Plam	WR-01																
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																	

MILLWORK: Upper Cabinets: <input type="checkbox"/> finish: _____ Lower Cabinets/Drawers: <input type="checkbox"/> finish: _____	doors: <input type="checkbox"/> combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/>	Options: <input type="checkbox"/> Standing Height Counter	Countertop: min. length (mm) _____ finish _____ Washroom Vanity: _____	Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish _____ Patient Wardrobe: <input type="checkbox"/> _____ Mail Slots: <input type="checkbox"/> _____
--	--	--	---	--

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <div style="border: 1px solid black; height: 40px; width: 100%;"></div>	PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input type="checkbox"/> _____	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Gooseneck	Electronic Control
quantity	mounting type	faucet type	control type	plumbing remarks							
Lavatory	1	Wall Hung	Gooseneck	Electronic Control							

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: _____
 Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;	<input type="checkbox"/> Intercom Station
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack	<input type="checkbox"/> Video Intercom Station
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack	<input type="checkbox"/> Overhead Paging (Pub Address)
Patient Monitoring Outlets 2A Red Data Port		C – Coax	<input type="checkbox"/> Teleconferencing
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet	

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

locate EPCA between toilet and sink

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>	GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>WR-03</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	WR-03
GWB	Washable																				
GWB - Moisture and Mould Resistant	Washable																				
Resilient	Non-Skid																				
Flash Cove																					
type	quantity	size	material	finish	Hardware Group																
A	1	914 x 2135	Solid Core	Plam	WR-03																
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																	

MILLWORK: Upper Cabinets: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/>	finish doors combination doors & open lockable adjustable shelves microwave shelf	Options: <input type="checkbox"/> Standing Height Counter	Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr></table>	min. length (mm)	finish	Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>
min. length (mm)	finish					

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input type="checkbox"/>	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Gooseneck	Electronic Control
quantity	mounting type	faucet type	control type	plumbing remarks							
Lavatory	1	Wall Hung	Gooseneck	Electronic Control							

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: _____
--

VENTILATION: Relative Pressure: <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: _____ Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: _____
--

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock	LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input checked="" type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input checked="" type="checkbox"/> Circadian Lighting lighting remarks
--	---

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;	
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack	<input type="checkbox"/> Intercom Station
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack	<input type="checkbox"/> Video Intercom Station
Patient Monitoring Outlets 2A Red Data Port		C – Coax	<input type="checkbox"/> Overhead Paging (Pub Address)
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call	<input type="checkbox"/> Teleconferencing
		PM- Patient Monitoring Outlet	

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	0
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input checked="" type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>2</td> <td>1830 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>AO-12</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	2	1830 x 2135	Solid Core	Plam	AO-12												
type	quantity	size	material	finish	Hardware Group																						
B	2	1830 x 2135	Solid Core	Plam	AO-12																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Vital			
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks										
quantity	mounting type	faucet type	control type	plumbing remarks												
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB - Moisture and Mould Resistant Washable Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																																	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	
type	quantity	size	material	finish	Hardware Group																																																						
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																																					

MILLWORK:		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	
Upper Cabinets	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	
Lower Cabinets/Drawers	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Countertop:	min. length (mm)	finish	Custom:	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/>					finish
Washroom Vanity:				Patient Wardrobe: <input type="checkbox"/>					
				Mail Slots: <input type="checkbox"/>					

MECHANICAL REQUIREMENTS

HVAC: Type: II Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>				Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control													
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control																			
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																							

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other:
Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	GFI	
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock
LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input checked="" type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input checked="" type="checkbox"/> Circadian Lighting lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr><td>Telecommunication Outlets 2A/1I</td><td></td></tr> <tr><td>Television Outlets 1A/1C/1NC</td><td></td></tr> <tr><td>Patient Monitoring Outlets 2A Red Data Port</td><td></td></tr> <tr><td>Headwall Outlets 2PM/3A (per headwall)</td><td></td></tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I		Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing
	quantity											
Telecommunication Outlets 2A/1I												
Television Outlets 1A/1C/1NC												
Patient Monitoring Outlets 2A Red Data Port												
Headwall Outlets 2PM/3A (per headwall)												

NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr><td>DS Duty Station</td><td></td></tr> <tr><td>MCS Full feature master control station</td><td></td></tr> <tr><td>EPCA Emergency Pull Cord station with Audio</td><td></td></tr> <tr><td>Other:</td><td></td></tr> </tbody> </table>		quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:	
	quantity									
DS Duty Station										
MCS Full feature master control station										
EPCA Emergency Pull Cord station with Audio										
Other:										

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input checked="" type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	CR-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	1065 x 2135	Solid Core	Plam	CR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 9000 finish Solid Surfacing Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	2	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Vital	Duplex	2	charging stations
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

LIGHTING:
 Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks
 provide master zone lighting controller. Provide specialty lighting - LED under cabinet & cove lighting

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	2
Headwall Outlets 2PM/3A (per headwall)	

Legend;
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control	
quantity	mounting type	faucet type	control type	plumbing remarks							
1	Wall Hung	Gooseneck	Electronic Control								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:											

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:


NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	1
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)	1	Code Blue	Code White	Code Pink	Staff Assist
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: Locate Patient monitoring outlets in bulkhead.

SECURITY SYSTEM: <input checked="" type="checkbox"/> Security Camera <input checked="" type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Infant Abduction System <input type="checkbox"/> Patient Wandering System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Rubber		DOORS: type quantity size material finish Hardware Group  Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight, <input type="checkbox"/> Integral Blinds, <input type="checkbox"/> Security Grille, <input type="checkbox"/> Laser Ready Integral Blinds																									
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																									
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																									
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws		MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: min. length (mm) 915 finish Plastic Laminate Washroom Vanity: _____ Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> _____ finish Patient Wardrobe: <input type="checkbox"/> _____ Mail Slots: <input type="checkbox"/> _____			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																					

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Vital	Duplex		1
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks: _____		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </table>																																																																																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/> _____		MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="2">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th> </th> <th> </th> </tr> </thead> <tbody> <tr> <td>Oxygen</td> <td> </td> </tr> <tr> <td>Medical Air</td> <td> </td> </tr> <tr> <td>Medical Vacuum</td> <td> </td> </tr> <tr> <td>Nitrous Oxide</td> <td> </td> </tr> <tr> <td>Nitrogen</td> <td> </td> </tr> <tr> <td>CO2</td> <td> </td> </tr> <tr> <td>Scavenging</td> <td> </td> </tr> <tr> <td>Laser Smoke Evac.</td> <td> </td> </tr> </tbody> </table> Medical Gas Remarks: _____				(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			Oxygen								Medical Air								Medical Vacuum								Nitrous Oxide								Nitrogen								CO2								Scavenging								Laser Smoke Evac.							
(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other																																																																												
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																															
Oxygen																																																																																			
Medical Air																																																																																			
Medical Vacuum																																																																																			
Nitrous Oxide																																																																																			
Nitrogen																																																																																			
CO2																																																																																			
Scavenging																																																																																			
Laser Smoke Evac.																																																																																			

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: provide nurse call connection to pneumatic tube

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: _____

VENTILATION: Relative Pressure Equal Positive Negative Other: _____
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks: _____

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>	GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>G</td> <td>1</td> <td>1220 x 2135</td> <td>Aluminum</td> <td>Prefinished</td> <td>AO-01</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	type	quantity	size	material	finish	Hardware Group	G	1	1220 x 2135	Aluminum	Prefinished	AO-01
GWB	Washable																				
GWB - Moisture and Mould Resistant	Washable																				
Resilient	Slip Resistant																				
Flash Cove																					
type	quantity	size	material	finish	Hardware Group																
G	1	1220 x 2135	Aluminum	Prefinished	AO-01																
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input checked="" type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																	

MILLWORK: Upper Cabinets: <input checked="" type="checkbox"/> Plastic Laminate Lower Cabinets/Drawers: <input checked="" type="checkbox"/> Plastic Laminate	finish doors combination doors & open lockable adjustable shelves microwave shelf <input type="checkbox"/> <input type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/>	Options: <input checked="" type="checkbox"/> Standing Height Counter	Countertop: <table border="1" style="width:100%;"><tr><td>2400</td><td>Solid Surfacing</td></tr></table>	2400	Solid Surfacing	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>
2400	Solid Surfacing					

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>II</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td></td></tr></table>	II		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> <tr> <td>1</td> <td>Counter</td> <td>Gooseneck</td> <td>Lever Blade</td> <td></td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control		1	Counter	Gooseneck	Lever Blade	
II																		
quantity	mounting type	faucet type	control type	plumbing remarks														
1	Wall Hung	Gooseneck	Electronic Control															
1	Counter	Gooseneck	Lever Blade															

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

--

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: <input type="checkbox"/> Equal <input checked="" type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%;"><tr><td></td></tr></table> Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>		

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input checked="" type="checkbox"/> Clock	LIGHTING: <input checked="" type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input checked="" type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input checked="" type="checkbox"/> Circadian Lighting lighting remarks <table border="1" style="width:100%; height: 50px;"><tr><td></td></tr></table>	

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet
	quantity										
Telecommunication Outlets 2A/1I	1										
Television Outlets 1A/1C/1NC											
Patient Monitoring Outlets 2A Red Data Port											
Headwall Outlets 2PM/3A (per headwall)											

NURSE CALL: DS Duty Station MCS Full feature master control station EPCA Emergency Pull Cord station with Audio Other: <table border="1" style="width:100%;"><tr><td></td></tr></table>		<table border="1" style="width:100%;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>DS Duty Station</td> <td>1</td> </tr> </table>		quantity	DS Duty Station	1
	quantity					
DS Duty Station	1					

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White	Staff Assist	
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: locate 2/3B button at door
--

SECURITY SYSTEM: <input checked="" type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input checked="" type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PA-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	914 x 2135	Solid Core	Plam	PA-01
type	quantity	size	material	finish	Hardware Group										
B	1	914 x 2135	Solid Core	Plam	PA-01										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds													
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												

MILLWORK:		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Countertop:	min. length (mm)	finish	Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/>					
3000		Plastic Laminate	Patient Wardrobe: <input type="checkbox"/>					
Washroom Vanity:			Mail Slots: <input type="checkbox"/>					

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																		
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																			

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control
--

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="text"/> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <input type="text"/>

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2	Duplex	1	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		2	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input checked="" type="checkbox"/> Clock	LIGHTING: <input checked="" type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input checked="" type="checkbox"/> Circadian Lighting lighting remarks <input type="text"/>
---	---

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>2</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	2	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing
	quantity											
Telecommunication Outlets 2A/1I	2											
Television Outlets 1A/1C/1NC												
Patient Monitoring Outlets 2A Red Data Port												
Headwall Outlets 2PM/3A (per headwall)												

NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other: <input type="text"/></td> <td></td> </tr> </tbody> </table>		quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other: <input type="text"/>	
	quantity									
DS Duty Station										
MCS Full feature master control station										
EPCA Emergency Pull Cord station with Audio										
Other: <input type="text"/>										

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: <input type="text"/>

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input checked="" type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>G</td> <td>1</td> <td>914 x 2135</td> <td>Aluminum</td> <td>Prefinished</td> <td>SL-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	G	1	914 x 2135	Aluminum	Prefinished	SL-01												
type	quantity	size	material	finish	Hardware Group																						
G	1	914 x 2135	Aluminum	Prefinished	SL-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 1500 finish Plastic Laminate Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/> finish																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																												
quantity	mounting type	faucet type	control type	plumbing remarks																																																																														
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																																																																																		
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="2">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			Oxygen								Medical Air								Medical Vacuum								Nitrous Oxide								Nitrogen								CO2								Scavenging								Laser Smoke Evac.							
(Quantity)	Headwall 1		Headwall 2			Overhead Booms		Other																																																																										
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																														
Oxygen																																																																																		
Medical Air																																																																																		
Medical Vacuum																																																																																		
Nitrous Oxide																																																																																		
Nitrogen																																																																																		
CO2																																																																																		
Scavenging																																																																																		
Laser Smoke Evac.																																																																																		
Medical Gas Remarks:																																																																																		

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	1																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

DOORS:

type	quantity	size	material	finish	Hardware Group

Access Control Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Vital	Duplex		1
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets <input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers <input checked="" type="checkbox"/>	Plastic Laminate <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		

Countertop: min. length (mm) 1800 finish Solid Surfacing
 Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: finish
 Patient Wardrobe:
 Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Utility	1	Counter	Gooseneck	Lever Blade

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
H	1	1830 x 2135	Aluminum	Prefinished	SL-02

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets: Plastic Laminate <input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers: Plastic Laminate <input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		

Countertop: min. length (mm) 1500 finish Solid Surfacing

Washroom Vanity: min. length (mm) finish Reception, Transaction Counter, or Care Team Station Desk: finish Plastic Laminate

Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: I

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene: 1	Wall Hung	Gooseneck	Electronic Control	
Other: 1	Counter	Gooseneck	Lever Blade	

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: Baby bathing

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			
Oxygen	2	2	2	2			
Medical Air	2	2	2	2			
Medical Vacuum	2	2	2	2			
Nitrous Oxide							
Nitrogen							
CO2							
Scavenging							
Laser Smoke Evac.							

Medical Gas Remarks: 2nd headwall in 3 rooms only, closest to Care Station

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex at headwall & 1 duplex for bed
	Duplex		3	2 duplex at headwall & 1 duplex above bed non-nursing side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off

Headwall

Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

provide bedside staff light in infant zone and headwall

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	0
Patient Monitoring Outlets 2A Red Data Port	1
Headwall Outlets 2PM/3A (per headwall)	1

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other: Family zone	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist	Code Pink
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: Locate 2/3b at entrance to room. Provide 4B at Bassinette. 3 rooms will have 2 headwalls requiring 2 x electrical/data and 4B button NC devices

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
H	1	1830 x 2135	Aluminum	Prefinished	SL-02

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

Upper Cabinets	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter

Countertop: min. length (mm) 1500 finish Solid Surfacing

Washroom Vanity: min. length (mm) finish Reception, Transaction Counter, or Care Team Station Desk: finish Plastic Laminate

Patient Wardrobe: finish Plastic Laminate

Mail Slots: finish

MECHANICAL REQUIREMENTS

HVAC: Type: I

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene: 1	Wall Hung	Gooseneck	Electronic Control	
Other: 1	Counter	Gooseneck	Lever Blade	

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: Baby bathing

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			
Oxygen	2	2	2	2			
Medical Air	2	2	2	2			
Medical Vacuum	2	2	2	2			
Nitrous Oxide							
Nitrogen							
CO2							
Scavenging							
Laser Smoke Evac.							

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex at headwall & 1 duplex for bed
	Duplex		3	2 duplex at headwall & 1 duplex above bed non-nursing side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off

Headwall

Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

provide bedside staff light in infant zone and headwall

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	0
Patient Monitoring Outlets 2A Red Data Port	1
Headwall Outlets 2PM/3A (per headwall)	1

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other: Family zone	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)	2	Code Blue	Code White	Staff Assist	Code Pink
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: Locate 2/3b at entrance to room. Provide 4B at Bassinettes.

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
C	2	1065 x 2135	Solid Core	Plam	PA-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: I

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White	Code Pink	Staff Assist
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout

Room Control Remarks: BMS Monitor and Control

VENTILATION:

Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust

Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																		
type	quantity	size	material	finish	Hardware Group																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input checked="" type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>											
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish 1500 Plastic Laminate Washroom Vanity: min. length (mm) finish Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/> finish																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port	1	C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist	Code Pink
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: <input type="checkbox"/> GWB - Moisture and Mould Resistant	Washable
Wall: <input type="checkbox"/> GWB - Moisture and Mould Resistant	Washable
Floor: <input type="checkbox"/> Resilient	Non-Skid
Base: <input type="checkbox"/> Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	1065 x 2135	Solid Core	Plam	WR-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting Legend:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend:

A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Lavatory	1	Wall Hung	Gooseneck	Electronic Control

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: Shower

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other: Locate EPCA between toilet and sink	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: locate between toilet and sink

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: Acoustic Tile (material), Washable (finish) Wall: GWB - Moisture and Mould Resistant (material), Washable (finish) Floor: Resilient (material), Slip Resistant (finish) Base: Flash Cove (material)	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </table>	type	quantity	size	material	finish	Hardware Group							WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator
type	quantity	size	material	finish	Hardware Group									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track												
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws			Door Hardware: <input type="checkbox"/> Access Control	Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds										

MILLWORK: Upper Cabinets: <input type="checkbox"/> finish, <input type="checkbox"/> doors, <input type="checkbox"/> combination doors & open, <input type="checkbox"/> lockable, <input type="checkbox"/> adjustable shelves, <input type="checkbox"/> microwave shelf Lower Cabinets/Drawers: <input checked="" type="checkbox"/> Plastic Laminate, <input type="checkbox"/> doors, <input checked="" type="checkbox"/> combination doors & open, <input checked="" type="checkbox"/> lockable, <input type="checkbox"/> adjustable shelves, <input type="checkbox"/> microwave shelf	Options: <input checked="" type="checkbox"/> Standing Height Counter	Countertop: min. length (mm) 1800, finish Solid Surfacing Washroom Vanity: min. length (mm) , finish Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> finish Mail Slots: <input type="checkbox"/> finish
---	--	--

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks										
quantity	mounting type	faucet type	control type	plumbing remarks												
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: <input type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

- SECURITY SYSTEM:**
- Security Camera
 - Clinical Camera Monitor
 - Panic Duress - Wired
 - Security Camera Monitor
 - Clinical Camera
 - Infant Abduction System
 - Patient Wandering System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																		
type	quantity	size	material	finish	Hardware Group																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Vital	Duplex		1
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																						
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th> </th> <th> </th> <th> </th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td></td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I		Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I																																						
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other: _____</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other: _____																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other: _____																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																																	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input checked="" type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	
type	quantity	size	material	finish	Hardware Group																																																						
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																																					
MILLWORK: Upper Cabinets: <input type="checkbox"/> finish: doors: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/> finish: doors: <input type="checkbox"/> Combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/> Options: <input type="checkbox"/> Standing Height Counter		Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																																																									

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2	Quad	4	Locate HK outlets at 1400mm AFF
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks:

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																					
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																							
MEDICAL GASES: (Quantity)		Headwall 1 Nursing Side Non-Nursing Side		Headwall 2 Nursing Side Non-Nursing Side		Overhead Booms _____		Other															
Oxygen																							
Medical Air																							
Medical Vacuum																							
Nitrous Oxide																							
Nitrogen																							
CO2																							
Scavenging																							
Laser Smoke Evac.																							
Medical Gas Remarks:																							

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:		quantity		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet		<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing					
Telecommunication Outlets 2A/1I											
Television Outlets 1A/1C/1NC											
Patient Monitoring Outlets 2A Red Data Port											
Headwall Outlets 2PM/3A (per headwall)											
NURSE CALL:		quantity									
DS Duty Station											
MCS Full feature master control station											
EPCA Emergency Pull Cord station with Audio											
Other: _____											
		quantity		feature 1		feature 2		feature 3		feature 4	
PS: Patient Station											
2/3B: 2/3 button station											
4B: 4 button station (single gang)											
VST: VoIP Staff Terminal/Station											
Other											
IMIT Remarks:											

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:	
VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:	

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input checked="" type="checkbox"/> Infant Abduction System	
--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

DOORS:

type	quantity	size	material	finish	Hardware Group

Access Control Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	Acoustic Tile	Washable
Wall	GWB - Impact Resistant	Washable
Floor	Resilient	Slip Resistant
Base:	Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
C	1	1220 x 2135	Solid Core	Plam	CR-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2	Quad	6	provide recep. on 1 m centers mounted at 1400mm AFF
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;
A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </tbody> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	B	1	1220 x 2135	Solid Core	Plam	CR-01				
GWB	Washable																										
GWB	Washable																										
Resilient	Slip Resistant																										
Flash Cove																											
type	quantity	size	material	finish	Hardware Group																						
B	1	1220 x 2135	Solid Core	Plam	CR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																									
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																									
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table> Countertop: min. length (mm) <input type="text" value="0"/> finish <input type="text"/> Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish <input type="text"/> Washroom Vanity: <input type="text"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <div style="border: 1px solid black; height: 40px; width: 100%;"></div>	PLUMBING: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <input type="text" value="BMS Monitor and Control"/>

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input checked="" type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="text"/> Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <div style="border: 1px solid black; width: 100%; height: 20px;"></div>
--

NURSE CALL:	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input checked="" type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>	GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>B</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CL-02</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	type	quantity	size	material	finish	Hardware Group	B	1	1220 x 2135	Solid Core	Plam	CL-02
GWB	Washable																				
GWB - Moisture and Mould Resistant	Washable																				
Resilient	Slip Resistant																				
Flash Cove																					
type	quantity	size	material	finish	Hardware Group																
B	1	1220 x 2135	Solid Core	Plam	CL-02																
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																	

MILLWORK: Upper Cabinets: <input checked="" type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/>	finish: <table border="1" style="width:100%;"><tr><td>Stainless Steel</td></tr></table>	Stainless Steel	doors: <input type="checkbox"/>	combination doors & open: <input type="checkbox"/>	lockable: <input type="checkbox"/>	adjustable shelves: <input type="checkbox"/>	microwave shelf: <input type="checkbox"/>	Options: <input type="checkbox"/> Standing Height Counter	
Stainless Steel									
Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm): 2400</td><td>finish: Stainless Steel</td></tr></table>	min. length (mm): 2400	finish: Stainless Steel	Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish: _____ Patient Wardrobe: <input type="checkbox"/> finish: _____ Mail Slots: <input type="checkbox"/> finish: _____						
min. length (mm): 2400	finish: Stainless Steel								

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>III</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td></td></tr></table>	III		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> <tr> <td>Utility</td> <td>1</td> <td>Counter</td> <td>Gooseneck</td> <td>Lever Blade</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input checked="" type="checkbox"/> Macerator: <input checked="" type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/> _____	quantity	mounting type	faucet type	control type	plumbing remarks	Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control	Utility	1	Counter	Gooseneck	Lever Blade
III																		
quantity	mounting type	faucet type	control type	plumbing remarks														
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control														
Utility	1	Counter	Gooseneck	Lever Blade														

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

--

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control
--

VENTILATION: Relative Pressure: <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: _____ Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>	

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock	LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input checked="" type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input checked="" type="checkbox"/> Circadian Lighting lighting remarks: <table border="1" style="width:100%; height: 50px;"><tr><td></td></tr></table>	

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>	

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input checked="" type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>	GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>WR-03</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	WR-03
GWB	Washable																				
GWB - Moisture and Mould Resistant	Washable																				
Resilient	Non-Skid																				
Flash Cove																					
type	quantity	size	material	finish	Hardware Group																
A	1	914 x 2135	Solid Core	Plam	WR-03																
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																	

MILLWORK: Upper Cabinets: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/>	finish doors combination doors & open lockable adjustable shelves microwave shelf	Options: <input type="checkbox"/> Standing Height Counter	Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td> </td><td> </td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td> </td><td> </td></tr></table> Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>	min. length (mm)	finish			min. length (mm)	finish		
min. length (mm)	finish										
min. length (mm)	finish										

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>III</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td> </td></tr></table>	III		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input type="checkbox"/>	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Gooseneck	Electronic Control
III													
quantity	mounting type	faucet type	control type	plumbing remarks									
Lavatory	1	Wall Hung	Gooseneck	Electronic Control									

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

--

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

--

VENTILATION: Relative Pressure: Equal Positive Negative Other:

--

 Exhaust Required: Yes No Dedicated Exhaust Remarks:

--

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks:

--

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

- Intercom Station
- Video Intercom Station
- Overhead Paging (Pub Address)
- Teleconferencing

NURSE CALL:	quantity	
DS Duty Station		
MCS Full feature master control station		
EPCA Emergency Pull Cord station with Audio		
Other: <table border="1" style="width:100%;"><tr><td> </td></tr></table>		

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

--

- SECURITY SYSTEM:**
- Security Camera
 - Clinical Camera Monitor
 - Panic Duress - Wired
 - Security Camera Monitor
 - Clinical Camera
 - Infant Abduction System
 - Patient Wandering System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>H</td> <td>1</td> <td>1830 x 2135</td> <td>Aluminum</td> <td>Prefinished</td> <td>SL-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	H	1	1830 x 2135	Aluminum	Prefinished	SL-01												
type	quantity	size	material	finish	Hardware Group																						
H	1	1830 x 2135	Aluminum	Prefinished	SL-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input checked="" type="checkbox"/> Bed Bumper / Locator		DOOR HARDWARE: <input type="checkbox"/> Access Control OTHER FEATURES: <input type="checkbox"/> Sidelight <input checked="" type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input checked="" type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input checked="" type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
COUNTERTOPS: Countertop: min. length (mm) 750 finish Solid Surfacing Washroom Vanity: _____ finish _____ Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish _____ Patient Wardrobe: <input type="checkbox"/> finish _____ Mail Slots: <input type="checkbox"/> finish _____																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex at headwall & 1 duplex for bed
	Duplex		3	2 duplex at headwall & 1 duplex above bed non-nursing side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
 - Remote Power Shut-Off
 - Headwall
 - Clock
- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks
- provide bedside staff light in infant zone and headwall

MECHANICAL REQUIREMENTS

HVAC: Type: I Remarks: _____	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control	
quantity	mounting type	faucet type	control type	plumbing remarks							
1	Wall Hung	Gooseneck	Electronic Control								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/> _____											

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen	2	2						
Medical Air	2	2						
Medical Vacuum	2	2						
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: _____

VENTILATION: Relative Pressure: Equal Positive Negative Other: _____
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks: _____

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC	0	I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port	1	C – Coax
Headwall Outlets 2PM/3A (per headwall)	1	NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist	Code Pink
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Countertop: min. length (mm) 750 finish Solid Surfacing

Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: finish Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: I

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: 1 for every 3 bays

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen	1	1						
Medical Air	1	1						
Medical Vacuum	1	1						
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex at headwall & 1 duplex for bed
UPS	Duplex		3	2 duplex at headwall & 1 duplex above bed non-nursing side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off

Headwall

Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

provide bedside staff light in infant zone and headwall

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	0
Patient Monitoring Outlets 2A Red Data Port	1
Headwall Outlets 2PM/3A (per headwall)	1

Legend;

A – Active/Allocated Data Port or Data Jack Intercom Station

I – Inactive/Unallocated Data Port or Data Jack Video Intercom Station

C – Coax Overhead Paging (Pub Address)

NC – Nurse Call Teleconferencing

PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist	Code Pink
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB - Moisture and Mould Resistant Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																											WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	
type	quantity	size	material	finish	Hardware Group																																																
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input checked="" type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																															
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td> </td> </tr> </tbody> </table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		Countertop: min. length (mm) finish 5000 Solid Surfacing		Custom: Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																									
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																																														
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																																														
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																																															

MECHANICAL REQUIREMENTS

HVAC: Type: II Remarks:		PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td rowspan="2"> </td> </tr> <tr> <td>Other</td> <td>1</td> <td>Counter</td> <td>Gooseneck</td> <td>Lever Blade</td> </tr> </tbody> </table>					quantity	mounting type	faucet type	control type	plumbing remarks	Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control		Other	1	Counter	Gooseneck	Lever Blade
	quantity	mounting type	faucet type	control type	plumbing remarks																	
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control																		
Other	1	Counter	Gooseneck	Lever Blade																		
Other Fixtures:		<input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Baby bathing																				

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								1
Medical Air								1
Medical Vacuum								1
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: Beside Baby Bath

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:
--

VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other:
Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	GFI
	Normal 2	Duplex	2	
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		2	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port	4	C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	0
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)	1	Code Blue	Code White	Code Pink	Staff Assist
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: Locate 4B beside baby bath.

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input checked="" type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	OF-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

MILLWORK:

Upper Cabinets	Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/> Standing Height Counter					

Countertop: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots: finish

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

Upper Cabinets	Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/> Standing Height Counter					

Countertop: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots: finish

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust Remarks:

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>WR-03</td> </tr> </tbody> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	WR-03												
GWB	Washable																																		
GWB - Moisture and Mould Resistant	Washable																																		
Resilient	Non-Skid																																		
Flash Cove																																			
type	quantity	size	material	finish	Hardware Group																														
A	1	914 x 2135	Solid Core	Plam	WR-03																														
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																																	
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																																	
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		min. length (mm)	finish			min. length (mm)	finish			HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																												
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																												
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																													
min. length (mm)	finish																																		
min. length (mm)	finish																																		

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>III</td></tr></table> Remarks: <div style="border: 1px solid black; height: 40px; width: 100%;"></div>	III	PLUMBING: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> </tbody> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Shower	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Gooseneck	Electronic Control
III												
quantity	mounting type	faucet type	control type	plumbing remarks								
Lavatory	1	Wall Hung	Gooseneck	Electronic Control								

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust Remarks:

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	0
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	KP-01

Access Control Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Lighting:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

Upper Cabinets	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/> Standing Height Counter

Countertop: min. length (mm) 1800 finish Solid Surfacing
 Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: finish
 Patient Wardrobe:
 Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	1
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend:

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene: 1	Wall Hung	Gooseneck	Electronic Control	
Double Bowl: 1	Counter	Gooseneck	Lever Blade	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB - Moisture and Mould Resistant Paint Floor: Resilient Non-Skid Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>KP-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	KP-01
type	quantity	size	material	finish	Hardware Group										
A	1	914 x 2135	Solid Core	Plam	KP-01										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds													
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												

MILLWORK:		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	
Upper Cabinets	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	
Lower Cabinets/Drawers	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Countertop:	min. length (mm)	finish	Custom:	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/>					finish
Washroom Vanity:				Patient Wardrobe: <input type="checkbox"/>					
				Mail Slots: <input type="checkbox"/>					

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks: 10 air changes per hour	PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																		
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																			

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <input type="text"/>
--

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="text"/> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <input type="text"/>

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: <input type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

- SECURITY SYSTEM:**
- Security Camera
 - Clinical Camera Monitor
 - Panic Duress - Wired
 - Security Camera Monitor
 - Clinical Camera
 - Infant Abduction System
 - Patient Wandering System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Non-Skid
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	WR-03

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting Legend:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend:

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Lavatory	1	Wall Hung	Gooseneck	Electronic Control

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: Shower

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	0
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling Acoustic Tile Pre-Finished Wall GWB - Abuse Resistant Paint Floor Resilient Slip Resistant Base Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>E</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CL-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	E	1	1065 x 2135	Solid Core	Plam	CL-01												
type	quantity	size	material	finish	Hardware Group																						
E	1	1065 x 2135	Solid Core	Plam	CL-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks										
quantity	mounting type	faucet type	control type	plumbing remarks												
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	2	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC	1	I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Slip Resistant
Base: Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

DOORS:

type	quantity	size	material	finish	Hardware Group

Door Hardware: Access Control

Other Features:

Sidelight
 Integral Blinds
 Security Grille
 Laser Ready Integral Blinds

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets <input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers <input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: II

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene: 1	Wall Hung	Anti-Ligature	Electronic Control	

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	GFI	
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off

Headwall

Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: material <input type="text" value="GWB"/> finish <input type="text" value="Washable"/> Wall: material <input type="text" value="GWB - Impact & Moisture and Mould Resistant"/> finish <input type="text" value="Washable"/> Floor: material <input type="text" value="Resilient"/> finish <input type="text" value="Non-Skid"/> Base: material <input type="text" value="Flash Cove"/>	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>WR-01</td> </tr> </table>	type	quantity	size	material	finish	Hardware Group	A	1	1065 x 2135	Solid Core	Plam	WR-01	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:30%;"> WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator </td> <td style="width:30%;"> WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature </td> <td style="width:30%;"> MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3 </td> <td style="width:30%;"> ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input checked="" type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track </td> <td style="width:30%;"> HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws </td> </tr> </table>	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input checked="" type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws
type	quantity	size	material	finish	Hardware Group														
A	1	1065 x 2135	Solid Core	Plam	WR-01														
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input checked="" type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws															

MILLWORK: Upper Cabinets <input type="checkbox"/> Lower Cabinets/Drawers <input type="checkbox"/>	finish <input type="text"/> doors <input type="checkbox"/> combination doors & open <input type="checkbox"/> lockable <input type="checkbox"/> adjustable shelves <input type="checkbox"/> microwave shelf <input type="checkbox"/>	Options: <input type="checkbox"/> Standing Height Counter	Countertop: min. length (mm) <input type="text"/> finish <input type="text"/> Washroom Vanity: min. length (mm) <input type="text"/> finish <input type="text"/> Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish <input type="text"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>
--	--	--	--

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <input style="width:100%;" type="text"/>	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Anti-Ligature</td> <td>Electronic Control</td> </tr> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Anti-Ligature	Electronic Control	Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input type="checkbox"/>
quantity	mounting type	faucet type	control type	plumbing remarks								
Lavatory	1	Wall Hung	Anti-Ligature	Electronic Control								

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout	Room Control Remarks: <input style="width:100%;" type="text"/>
---	--

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="text"/>	Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <input style="width:100%;" type="text"/>
--	--

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock	LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input checked="" type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input checked="" type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks: <input style="width:100%;" type="text"/>
--	---

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;	
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack	<input type="checkbox"/> Intercom Station
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack	<input type="checkbox"/> Video Intercom Station
Patient Monitoring Outlets 2A Red Data Port		C – Coax	<input type="checkbox"/> Overhead Paging (Pub Address)
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call	<input type="checkbox"/> Teleconferencing
		PM- Patient Monitoring Outlet	

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other: <u>Locate EPCA between toilet and sink</u>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	IMIT Remarks: <input style="width:100%;" type="text"/>
--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PA-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	PA-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	1065 x 2135	Solid Core	Plam	PA-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>																						
Countertop: min. length (mm) finish 2400 Solid Surfacing Washroom Vanity: min. length (mm) finish Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input checked="" type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	2	convenience
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

provide zone lighting controller.

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																						
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input checked="" type="checkbox"/> Intercom Station <input checked="" type="checkbox"/> Video Intercom Station <input checked="" type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	1																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td>1</td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station	1	EPCA Emergency Pull Cord station with Audio		Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station	1																																					
EPCA Emergency Pull Cord station with Audio																																						
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

SECURITY SYSTEM:
 Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
B	1	914 x 2135	Solid Core	Plam	PA-01

Access Control Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets: <input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers: <input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Countertop: min. length (mm) 3000 finish Plastic Laminate

Washroom Vanity: _____

Reception, Transaction Counter, or Care Team Station Desk: _____ finish _____

Patient Wardrobe: _____

Mail Slots: _____

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks: _____

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: _____

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout

Room Control Remarks: BMS Monitor and Control

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust

Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2	Duplex	1	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		2	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	2
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

DOORS:

type	quantity	size	material	finish	Hardware Group

Access Control Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	15A/20A, 120V Housekeeping		3	crash cart
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

MILLWORK:

Upper Cabinets	Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/> Standing Height Counter					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

Upper Cabinets	Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/> Standing Height Counter					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	3
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

DOORS:

type	quantity	size	material	finish	Hardware Group
G	2	1220 x 2135	Aluminum	Prefinished	AO-01

Door Hardware: Access Control
 Other Features:
 Sidelight
 Integral Blinds
 Security Grille
 Laser Ready Integral Blinds

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
Boom:	Normal			
Boom:	Normal			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

Upper Cabinets	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Countertop: min. length (mm) 3000 finish Solid Surfacing
 Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: finish
 Patient Wardrobe:
 Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: II

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White	Staff Assist	
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: locate 2/3B button at door

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION:

Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	KP-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets: <input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers: <input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		

Countertop: min. length (mm) 1800 finish Plastic Laminate

Washroom Vanity: _____

Reception, Transaction Counter, or Care Team Station Desk: _____ finish _____

Patient Wardrobe: _____

Mail Slots: _____

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks: _____

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: _____

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: _____

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		2	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks: _____

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	2
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB - Abuse Resistant Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>OF-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	OF-01
type	quantity	size	material	finish	Hardware Group										
A	1	914 x 2135	Solid Core	Plam	OF-01										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		DOOR HARDWARE: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds													
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												

MILLWORK:		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	
Upper Cabinets	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	
Lower Cabinets/Drawers	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Countertop:	min. length (mm)	finish	Custom:	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/>					finish
Washroom Vanity:				Patient Wardrobe: <input type="checkbox"/>					
				Mail Slots: <input type="checkbox"/>					

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																		
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																			

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <input type="text"/>
--

VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="text"/> Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <input type="text"/>

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	
Telecommunication Outlets 2A/1I	1	
Television Outlets 1A/1C/1NC		
Patient Monitoring Outlets 2A Red Data Port		
Headwall Outlets 2PM/3A (per headwall)		

Legend;

- A – Active/Allocated Data Port or Data Jack
- I – Inactive/Unallocated Data Port or Data Jack
- C – Coax
- NC – Nurse Call
- PM- Patient Monitoring Outlet

- Intercom Station
- Video Intercom Station
- Overhead Paging (Pub Address)
- Teleconferencing

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: <input type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: Acoustic Tile (material), Pre-Finished (finish) Wall: GWB - Abuse Resistant (material), Paint (finish) Floor: Resilient (material), Slip Resistant (finish) Base: Rubber (material)	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>OF-01</td> </tr> </table>	type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	OF-01	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator
type	quantity	size	material	finish	Hardware Group									
A	1	914 x 2135	Solid Core	Plam	OF-01									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track												
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws			DOOR HARDWARE: <input type="checkbox"/> Access Control	OTHER FEATURES: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds										

MILLWORK: Upper Cabinets: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/>	finish: _____ doors: <input type="checkbox"/> combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/>	Options: <input type="checkbox"/> Standing Height Counter	Countertop: min. length (mm) _____ finish _____ Washroom Vanity: min. length (mm) _____ finish _____ Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish _____ Patient Wardrobe: <input type="checkbox"/> finish _____ Mail Slots: <input type="checkbox"/> finish _____
--	---	--	---

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks: _____	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/> _____																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout	Room Control Remarks: _____
---	-----------------------------

VENTILATION: Relative Pressure: <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: _____ Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust	Remarks: _____
---	----------------

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input checked="" type="checkbox"/> Clock	LIGHTING: <input checked="" type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks: _____
---	---

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td> </td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td> </td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td> </td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet
	quantity										
Telecommunication Outlets 2A/1I	1										
Television Outlets 1A/1C/1NC											
Patient Monitoring Outlets 2A Red Data Port											
Headwall Outlets 2PM/3A (per headwall)											

NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td> </td> </tr> <tr> <td>MCS Full feature master control station</td> <td> </td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td> </td> </tr> <tr> <td>Other: _____</td> <td> </td> </tr> </tbody> </table>		quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other: _____	
	quantity									
DS Duty Station										
MCS Full feature master control station										
EPCA Emergency Pull Cord station with Audio										
Other: _____										

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: Acoustic Tile (material), Pre-Finished (finish) Wall: GWB - Abuse Resistant (material), Paint (finish) Floor: Resilient (material), Slip Resistant (finish) Base: Rubber (material)	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>OF-01</td> </tr> </table>	type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	OF-01	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator
type	quantity	size	material	finish	Hardware Group									
A	1	914 x 2135	Solid Core	Plam	OF-01									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track												
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws														

MILLWORK: Upper Cabinets: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/>	finish: _____ doors: <input type="checkbox"/> combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/>	Options: <input type="checkbox"/> Standing Height Counter	Countertop: min. length (mm) _____ finish _____ Washroom Vanity: _____ Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish _____ Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>
--	---	--	---

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks: _____	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: _____

VENTILATION: Relative Pressure: Equal Positive Negative Other: _____
 Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks: _____

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB - Abuse Resistant	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	OF-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Non-Skid
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	WR-03

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Lavatory	1	Wall Hung	Gooseneck	Electronic Control

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	0
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Impact Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB - Impact Resistant	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CL-01</td> </tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight, <input checked="" type="checkbox"/> Integral Blinds, <input type="checkbox"/> Security Grille, <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	CL-01								
GWB	Washable																														
GWB - Impact Resistant	Washable																														
Resilient	Slip Resistant																														
Flash Cove																															
type	quantity	size	material	finish	Hardware Group																										
B	1	1065 x 2135	Solid Core	Plam	CL-01																										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																													
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																													
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td></td> <td></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm): 1800</td><td>finish: Plastic Laminate</td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm):</td><td>finish:</td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			min. length (mm): 1800	finish: Plastic Laminate	min. length (mm):	finish:	HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																								
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																								
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>																										
min. length (mm): 1800	finish: Plastic Laminate																														
min. length (mm):	finish:																														

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	3	
	Normal 2			
	Conditional 1	Duplex	3	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	2	
UPS				
Lighting: <input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input checked="" type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input checked="" type="checkbox"/> Clock <input checked="" type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input checked="" type="checkbox"/> Zone Controller <input checked="" type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks:				

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>II</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td></td></tr></table>	II		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:	quantity	mounting type	faucet type	control type	plumbing remarks															
II																							
quantity	mounting type	faucet type	control type	plumbing remarks																			

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

--

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

--

VENTILATION: Relative Pressure: Equal Positive Negative Other:

--

 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

--

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC	1	I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White	Staff Assist	
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

provide remote shutdown of power. Provide tamper proof, ligature proof devices
--

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB - Abuse Resistant	Paint
Wall: GWB - Impact Resistant	Paint
Floor: Resilient	Slip Resistant
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
E	1	1220 x 2135	Solid Core	Plam	CL-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Lighting:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other: <input style="width:100%;" type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB - Abuse Resistant	Washable
Wall	GWB - Impact Resistant	Washable
Floor	Resilient	Slip Resistant
Base:	Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
B	1	914 x 2135	Solid Core	Plam	IA-01
B	1	914 x 2135	Solid Core	Plam	IA-01

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WALL PROTECTION:
 Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:
 Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:
 EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:
 Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:
 Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	2	
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;
A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: II

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
1	Wall Hung	Anti-Ligature	Electronic Control	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB - Impact Resistant	Washable
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
B	1	914 x 2135	Solid Core	Plam	IA-01
B	1	914 x 2135	Solid Core	Plam	IA-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets: Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers: Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		

Countertop: min. length (mm) 1500, finish Plastic Laminate

Washroom Vanity: min. length (mm) _____, finish _____

Reception, Transaction Counter, or Care Team Station Desk: finish _____

Patient Wardrobe: finish _____

Mail Slots: finish _____

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	1
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: II

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: _____

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side	_____	_____	_____	
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout

Room Control Remarks: _____

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust

Remarks: _____

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Impact & Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>	GWB	Washable	GWB - Impact & Moisture and Mould Resistant	Washable	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>WR-01</td> </tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	type	quantity	size	material	finish	Hardware Group	A	1	1065 x 2135	Solid Core	Plam	WR-01
GWB	Washable																				
GWB - Impact & Moisture and Mould Resistant	Washable																				
Resilient	Non-Skid																				
Flash Cove																					
type	quantity	size	material	finish	Hardware Group																
A	1	1065 x 2135	Solid Core	Plam	WR-01																
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input checked="" type="checkbox"/> Anti-Ligature																				
MENTAL HEALTH GLASS TYPES: <input checked="" type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input checked="" type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																				
HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																					

MILLWORK: Upper Cabinets <input type="checkbox"/> Lower Cabinets/Drawers <input type="checkbox"/>	finish doors combination doors & open lockable adjustable shelves microwave shelf	Options: <input type="checkbox"/> Standing Height Counter	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>						
Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr></table>	min. length (mm)	finish	Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr></table>	min. length (mm)	finish	Custom: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr></table>		min. length (mm)	finish
min. length (mm)	finish								
min. length (mm)	finish								
min. length (mm)	finish								

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>III</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"></table>	III	PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Anti-Ligature</td> <td>Electronic Control</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input type="checkbox"/>	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Anti-Ligature	Electronic Control
III												
quantity	mounting type	faucet type	control type	plumbing remarks								
Lavatory	1	Wall Hung	Anti-Ligature	Electronic Control								

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <table border="1" style="width:100%; height: 20px;"></table>

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%; height: 20px;"></table> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%; height: 20px;"></table>

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock	LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input checked="" type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input checked="" type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks: <table border="1" style="width:100%; height: 50px;"></table>
--	---

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other: <u>Locate EPCA between toilet and sink</u>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB - Abuse Resistant	Washable
Wall: GWB - Impact Resistant	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	IA-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain- Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Lighting:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

Upper Cabinets	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter

Countertop: min. length (mm) 2400, finish Plastic Laminate

Washroom Vanity: min. length (mm) _____, finish _____

Reception, Transaction Counter, or Care Team Station Desk: finish _____

Patient Wardrobe: finish _____

Mail Slots: finish _____

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: II

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Anti-Ligature	Electronic Control
Double Bowl	1	Counter	Anti-Ligature	Electronic Control

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: Bath tub & Shower

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout

Room Control Remarks:

IMIT Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust

Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	Acoustic Tile	Washable
Wall	GWB - Impact Resistant	Washable
Floor	Resilient	Slip Resistant
Base:	Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
C	1	1220 x 2135	Solid Core	Plam	CR-01

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2	Quad	6	provide recep. on 1 m centers mounted at 1400mm AFF
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		

Countertop: min. length (mm) 1220 finish Stainless Steel

Washroom Vanity: min. length (mm) finish

Reception, Transaction Counter, or Care Team Station Desk: finish
Patient Wardrobe:
Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB - Moisture and Mould Resistant	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>B</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>KP-01</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight, <input type="checkbox"/> Integral Blinds, <input checked="" type="checkbox"/> Security Grille, <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	B	1	1220 x 2135	Solid Core	Plam	KP-01												
GWB - Moisture and Mould Resistant	Washable																																		
GWB - Moisture and Mould Resistant	Washable																																		
Resilient	Non-Skid																																		
Flash Cove																																			
type	quantity	size	material	finish	Hardware Group																														
B	1	1220 x 2135	Solid Core	Plam	KP-01																														
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																																	
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																																	
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws		MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Stainless Steel</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> <td></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>5000</td><td>finish</td><td>Stainless Steel</td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td></td><td>finish</td><td></td></tr></table> Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Stainless Steel	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			min. length (mm)	5000	finish	Stainless Steel	min. length (mm)		finish	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																												
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																												
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Stainless Steel	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																														
min. length (mm)	5000	finish	Stainless Steel																																
min. length (mm)		finish																																	

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2	30A, 208Volt, 3 Phase	1	4 wire connection / future retherm units
	Conditional 3	30A, 208Volt, 1 Phase	1	3 wire connection / future retherm units
	Delayed Vital			
Vital	Duplex		2	
UPS				
Lighting Legend: <input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input checked="" type="checkbox"/> Clock LIGHTING: <input checked="" type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input checked="" type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks				

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> <tr> <td>Double Bowl</td> <td>1</td> <td>Counter</td> <td>Gooseneck</td> <td>Lever Blade</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input checked="" type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>				quantity	mounting type	faucet type	control type	plumbing remarks	Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control	Double Bowl	1	Counter	Gooseneck	Lever Blade
quantity	mounting type	faucet type	control type	plumbing remarks																
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control																
Double Bowl	1	Counter	Gooseneck	Lever Blade																
MEDICAL GASES: (Quantity)		Headwall 1		Headwall 2		Overhead Booms		Other												
		Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side															
Oxygen																				
Medical Air																				
Medical Vacuum																				
Nitrous Oxide																				
Nitrogen																				
CO2																				
Scavenging																				
Laser Smoke Evac.																				


TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;																																														
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack																																														
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack																																														
Patient Monitoring Outlets 2A Red Data Port		C – Coax																																														
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call																																														
		PM- Patient Monitoring Outlet																																														
NURSE CALL: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>DS Duty Station</td> <td>1</td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </table> <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td>1</td> <td>Code Blue</td> <td>Code White</td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>				quantity	DS Duty Station	1	MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station	1	Code Blue	Code White			4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																															
DS Duty Station	1																																															
MCS Full feature master control station																																																
EPCA Emergency Pull Cord station with Audio																																																
Other:																																																
	quantity	feature 1	feature 2	feature 3	feature 4																																											
PS: Patient Station																																																
2/3B: 2/3 button station	1	Code Blue	Code White																																													
4B: 4 button station (single gang)																																																
VST: VoIP Staff Terminal/Station																																																
Other																																																

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:	
VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:	

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	
--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB - Impact Resistant Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: type quantity size material finish Hardware Group 	
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain- Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws
MILLWORK: finish doors combination doors & open lockable adjustable shelves microwave shelf Options: Upper Cabinets <input type="checkbox"/> Standing Height Counter Lower Cabinets/Drawers <input type="checkbox"/>			
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>			

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2	Duplex	2	
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Lighting Legend: <input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input checked="" type="checkbox"/> Clock LIGHTING: <input checked="" type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input checked="" type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks				

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Anti-Ligature</td> <td>Electronic Control</td> <td></td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </table>	Hand Hygiene	1	Wall Hung	Anti-Ligature	Electronic Control																																																																									
Hand Hygiene	1	Wall Hung	Anti-Ligature	Electronic Control																																																																											
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																																																																															
MEDICAL GASES: (Quantity) <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2"></th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="2">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>			Headwall 1		Headwall 2		Overhead Booms		Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			Oxygen								Medical Air								Medical Vacuum								Nitrous Oxide								Nitrogen								CO2								Scavenging								Laser Smoke Evac.							
	Headwall 1		Headwall 2		Overhead Booms		Other																																																																								
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																											
Oxygen																																																																															
Medical Air																																																																															
Medical Vacuum																																																																															
Nitrous Oxide																																																																															
Nitrogen																																																																															
CO2																																																																															
Scavenging																																																																															
Laser Smoke Evac.																																																																															
Medical Gas Remarks:																																																																															

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input checked="" type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	1																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td>1</td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio	1	Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio	1																																					
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control
VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB - Moisture and Mould Resistant Washable Floor: Resilient Non-Skid Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>E</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PA-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	E	1	914 x 2135	Solid Core	Plam	PA-01												
type	quantity	size	material	finish	Hardware Group																						
E	1	914 x 2135	Solid Core	Plam	PA-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>																						
Countertop: min. length (mm) 1800 finish Solid Surfacing Washroom Vanity: min. length (mm) finish Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	GFI
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting

 lighting remarks
 MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Counter</td> <td>Anti-Ligature</td> <td>Electronic Control</td> <td></td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Counter	Anti-Ligature	Electronic Control	
quantity	mounting type	faucet type	control type	plumbing remarks							
1	Counter	Anti-Ligature	Electronic Control								
Other Fixtures: <input type="checkbox"/> Urinal: <input checked="" type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>											

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

 Medical Gas Remarks:
 ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:
 VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust Remarks:
 TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

- Intercom Station
- Video Intercom Station
- Overhead Paging (Pub Address)
- Teleconferencing

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

 IMIT Remarks:
 SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>SR-01</td> </tr> </tbody> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	SR-01												
GWB	Washable																																		
GWB	Washable																																		
Resilient	Slip Resistant																																		
Flash Cove																																			
type	quantity	size	material	finish	Hardware Group																														
B	1	1065 x 2135	Solid Core	Plam	SR-01																														
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																																	
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																																	
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		min. length (mm)	finish			min. length (mm)	finish			HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																												
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																												
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																													
min. length (mm)	finish																																		
min. length (mm)	finish																																		

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>III</td></tr></table> Remarks: <div style="border: 1px solid black; height: 60px; width: 100%;"></div>	III	PLUMBING: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>	quantity	mounting type	faucet type	control type	plumbing remarks															
III																						
quantity	mounting type	faucet type	control type	plumbing remarks																		

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust Remarks:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <input type="text" value="GWB"/> <input type="text" value="Paint"/> Wall: <input type="text" value="GWB"/> <input type="text" value="Paint"/> Floor: <input type="text" value="Resilient"/> <input type="text" value="Slip Resistant"/> Base: <input type="text" value="Flash Cove"/>		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>SR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	1	1220 x 2135	Solid Core	Plam	SR-01												
type	quantity	size	material	finish	Hardware Group																						
A	1	1220 x 2135	Solid Core	Plam	SR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>																						
Countertop: min. length (mm) <input type="text" value="5000"/> finish <input type="text" value="Plastic Laminate"/> Washroom Vanity: <input type="text"/> finish <input type="text"/> Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish <input type="text"/> Patient Wardrobe: <input type="checkbox"/> finish <input type="text"/> Mail Slots: <input type="checkbox"/> finish <input type="text"/>																											

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <input type="text"/>	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	0	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: <input type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

- SECURITY SYSTEM:**
- Security Camera
 - Clinical Camera Monitor
 - Panic Duress - Wired
 - Security Camera Monitor
 - Clinical Camera
 - Infant Abduction System
 - Patient Wandering System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Washable
Wall: GWB - Impact Resistant	Washable
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
C	1	1220 x 2135	Solid Core	Plam	CR-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2	Quad	6	provide recep. on 1 m centers mounted at 1400mm AFF
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

MILLWORK:

Upper Cabinets	Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/> Standing Height Counter					

Countertop: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: finish

Mail Slots: finish

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

Upper Cabinets	Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/> Standing Height Counter					

Countertop: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: finish

Mail Slots: finish

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout

Room Control Remarks: BMS Monitor and Control

VENTILATION:

Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust

Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB - Impact & Moisture and Mould Resistant Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PA-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	PA-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	1065 x 2135	Solid Core	Plam	PA-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish 1800 Solid Surfacing Washroom Vanity: min. length (mm) finish Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/> finish																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Vital			
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>Utility</td> <td>1</td> <td>Counter</td> <td>Gooseneck</td> <td>Lever Blade</td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	Utility	1	Counter	Gooseneck	Lever Blade
quantity	mounting type	faucet type	control type	plumbing remarks							
Utility	1	Counter	Gooseneck	Lever Blade							
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:											

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	0	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB	Washable
Wall	GWB - Impact & Moisture and Mould Resistant	Washable
Floor	Resilient	Non-Skid
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
C	1	1220 x 2135	Solid Core	Plam	CR-01

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT: Horizontal Blinds, Roller Shade - Black Out, Curtain Fabric, Integral Blinds, Roller Shade - Mesh, Laser Ready Integral Blinds, Vertical Blinds, One Way Mirror, Anti-Ligature

MENTAL HEALTH GLASS TYPES: EXT-1, EXT-2, EXT-3, INT-1, INT-2, INT-3

ROOM ACCESSORIES: Coat Hooks, Coat Hooks - Anti-ligature, Mirror, Mirror - Vandal Resistant, Privacy Curtain, Privacy Curtain - Anti-ligature, Shower Seat, Shower Curtain, Shower Curtain - Anti-ligature, Ceiling IV Track

HARM PREVENTION: Industrial anti-ligature tamper-resistant sprinkler, Concealed pendant quick response sprinkler, Tamper proof screws and fittings, Vandal resistant anti-ligature plumbing fixtures, Vandal resistant tamper proof pipe and valve cover, Vandal resistant tamper proof and access panels, Security-type ventilating grille, Vandal resistant lighting fixtures and tamper resistant receptacles, Tamper resistant lighting fixtures and tamper resistant receptacles, Tamper Proof and Anti ligature Breakaway Smoke Detector Cover, Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:

PLUMBING:

	quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control	
Janitorial	1	Floor	Standard	Lever Blade	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: Detergent Dispenser

MEDICAL GASES: (Quantity)

	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	3	Locate HK outlets at 1400mm AFF
	Normal 2	Duplex	1	GFI
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend; Intercom Station Video Intercom Station
A – Active/Allocated Data Port or Data Jack Overhead Paging (Pub Address)
I – Inactive/Unallocated Data Port or Data Jack Teleconferencing
C – Coax NC – Nurse Call
PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
C	1	1220 x 2135	Solid Core	Plam	CR-01

Door Hardware: Access Control

Other Features:

Sidelight
 Integral Blinds
 Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets <input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers <input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene: 1	Wall Hung	Gooseneck	Electronic Control	

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	0
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	0				
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling Acoustic Tile Pre-Finished Wall GWB Paint Floor Resilient Slip Resistant Base Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	CR-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	1065 x 2135	Solid Core	Plam	CR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 6000 finish Solid Surfacing Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	2	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		2	charging stations
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks
 provide master zone lighting controller. Provide specialty lighting - LED under cabinet & cove lighting

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	2
Headwall Outlets 2PM/3A (per headwall)	

Legend;
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control	
quantity	mounting type	faucet type	control type	plumbing remarks							
1	Wall Hung	Gooseneck	Electronic Control								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:											

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	1
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist	
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: locate Patient monitoring outlets in bulkhead

SECURITY SYSTEM: <input checked="" type="checkbox"/> Security Camera <input checked="" type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Infant Abduction System <input checked="" type="checkbox"/> Patient Wandering System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	CR-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	1065 x 2135	Solid Core	Plam	CR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 4500 finish Solid Surfacing Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: _____

VENTILATION: Relative Pressure: Equal Positive Negative Other: _____
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	2	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

- SECURITY SYSTEM:**
- Security Camera
 - Clinical Camera Monitor
 - Panic Duress - Wired
 - Security Camera Monitor
 - Clinical Camera
 - Infant Abduction System
 - Patient Wandering System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																																	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	
type	quantity	size	material	finish	Hardware Group																																																						
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																																					
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td> </td> <td> </td> </tr> </tbody> </table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			Countertop: min. length (mm) finish 2400 Solid Surfacing		Washroom Vanity: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																															
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																																																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																																																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																																																						

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>				quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																					
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																									

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control
--

VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="text"/> Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <input type="text"/>

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: <input type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

- SECURITY SYSTEM:**
- Security Camera
 - Clinical Camera Monitor
 - Panic Duress - Wired
 - Security Camera Monitor
 - Clinical Camera
 - Infant Abduction System
 - Patient Wandering System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>G</td> <td>1</td> <td>914 x 2135</td> <td>Aluminum</td> <td>Prefinished</td> <td>SL-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	G	1	914 x 2135	Aluminum	Prefinished	SL-01												
type	quantity	size	material	finish	Hardware Group																						
G	1	914 x 2135	Aluminum	Prefinished	SL-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 1500 finish Plastic Laminate Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/> finish																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;	
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack	<input type="checkbox"/> Intercom Station
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack	<input type="checkbox"/> Video Intercom Station
Patient Monitoring Outlets 2A Red Data Port		C – Coax	<input type="checkbox"/> Overhead Paging (Pub Address)
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call	<input type="checkbox"/> Teleconferencing
		PM- Patient Monitoring Outlet	

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB - Abuse Resistant Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>2</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>IA-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	2	914 x 2135	Solid Core	Plam	IA-01												
type	quantity	size	material	finish	Hardware Group																						
A	2	914 x 2135	Solid Core	Plam	IA-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input checked="" type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2	Duplex	2	
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: II Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																						
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input checked="" type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	1																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td>1</td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio	1	Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio	1																																					
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks: provide remote shutdown of power																																						

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB - Abuse Resistant</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Impact Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB - Abuse Resistant	Washable	GWB - Impact Resistant	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>B</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PR-02</td> </tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input checked="" type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	B	1	1220 x 2135	Solid Core	Plam	PR-02								
GWB - Abuse Resistant	Washable																														
GWB - Impact Resistant	Washable																														
Resilient	Slip Resistant																														
Flash Cove																															
type	quantity	size	material	finish	Hardware Group																										
B	1	1220 x 2135	Solid Core	Plam	PR-02																										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input checked="" type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input checked="" type="checkbox"/> Anti-Ligature																													
MENTAL HEALTH GLASS TYPES: <input checked="" type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input checked="" type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																													
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm): 1500</td><td>finish: Solid Surfacing</td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm):</td><td>finish:</td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		min. length (mm): 1500	finish: Solid Surfacing	min. length (mm):	finish:	HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																								
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																								
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																									
min. length (mm): 1500	finish: Solid Surfacing																														
min. length (mm):	finish:																														

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	
UPS	Duplex		3	
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

LIGHTING:
 Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks
 Beside light switchable outside door

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>II</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td></td></tr></table>	II		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>	quantity	mounting type	faucet type	control type	plumbing remarks										
II																		
quantity	mounting type	faucet type	control type	plumbing remarks														

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

--

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other:

--

 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

--

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Staff Assist	Patient Assist	
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: 2/3B mounted outside the door in the hallway. Provide tamper proof ceiling mounted 2 way Audio nurse call device to be monitored from care station master station. Pullcord provided but can be removed based on patients acuity.

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: material: Washable Wall: material: Waterproof Cover. Floor: Resilient Base: Flash Cove	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PW-01</td> </tr> </table>	type	quantity	size	material	finish	Hardware Group	A	1	1065 x 2135	Solid Core	Plam	PW-01	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator
type	quantity	size	material	finish	Hardware Group									
A	1	1065 x 2135	Solid Core	Plam	PW-01									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input checked="" type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input checked="" type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input checked="" type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input checked="" type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input checked="" type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track												
MILLWORK: Upper Cabinets: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/> Countertop: min. length (mm): 914 finish: Solid Surfacing Washroom Vanity: 914 finish: Solid Surfacing			HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Lighting: <input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input checked="" type="checkbox"/> Night Light <input checked="" type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input checked="" type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks:				

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>1</td> <td>Counter</td> <td>Anti-Ligature</td> <td>Electronic Control</td> <td>Provide remote water supply shut off by staff through BMS</td> </tr> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Counter	Anti-Ligature	Electronic Control	Provide remote water supply shut off by staff through BMS																																																																				
quantity	mounting type	faucet type	control type	plumbing remarks																																																																											
1	Counter	Anti-Ligature	Electronic Control	Provide remote water supply shut off by staff through BMS																																																																											
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="2">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> </tr> <tr> <td>Oxygen</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Medical Air</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Medical Vacuum</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Nitrous Oxide</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Nitrogen</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>CO2</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Scavenging</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Laser Smoke Evac.</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>		(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			Oxygen								Medical Air								Medical Vacuum								Nitrous Oxide								Nitrogen								CO2								Scavenging								Laser Smoke Evac.							
(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other																																																																								
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																											
Oxygen																																																																															
Medical Air																																																																															
Medical Vacuum																																																																															
Nitrous Oxide																																																																															
Nitrogen																																																																															
CO2																																																																															
Scavenging																																																																															
Laser Smoke Evac.																																																																															

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	2
Other: Locate 1 EPCA between toilet and sink, 1 adjacent to shower	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:
VENTILATION: Relative Pressure: <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Dedicated Exhaust Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB - Abuse Resistant</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Impact Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB - Abuse Resistant	Washable	GWB - Impact Resistant	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>F</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PR-01</td> </tr> </tbody> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input checked="" type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	F	1	1220 x 2135	Solid Core	Plam	PR-01								
GWB - Abuse Resistant	Washable																														
GWB - Impact Resistant	Washable																														
Resilient	Slip Resistant																														
Flash Cove																															
type	quantity	size	material	finish	Hardware Group																										
F	1	1220 x 2135	Solid Core	Plam	PR-01																										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input checked="" type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input checked="" type="checkbox"/> Anti-Ligature																													
MENTAL HEALTH GLASS TYPES: <input checked="" type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input checked="" type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																													
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm): 1500</td><td>finish: Solid Surfacing</td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm):</td><td>finish:</td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		min. length (mm): 1500	finish: Solid Surfacing	min. length (mm):	finish:	HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																								
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																								
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																									
min. length (mm): 1500	finish: Solid Surfacing																														
min. length (mm):	finish:																														

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	
UPS	Duplex		3	
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input checked="" type="checkbox"/> Patient Care Area Designation as per CSA Z32	<input checked="" type="checkbox"/> Remote Power Shut-Off	<input checked="" type="checkbox"/> Headwall	<input checked="" type="checkbox"/> Clock
LIGHTING:			
<input checked="" type="checkbox"/> Workstation Task Light	<input type="checkbox"/> Bedside Staff Light	<input type="checkbox"/> Visitor Light	<input checked="" type="checkbox"/> Night Light
<input type="checkbox"/> Vanity Light	<input type="checkbox"/> In Use Light Laser and/or X-ray	<input type="checkbox"/> Zone Controller	<input type="checkbox"/> Colour Tunable
<input checked="" type="checkbox"/> Reading Light	<input type="checkbox"/> Hand Hygiene Sink Light	<input type="checkbox"/> Examination Light	<input type="checkbox"/> Shower Light
<input type="checkbox"/> Circadian Lighting	lighting remarks		

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>II</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"></table>		II	PLUMBING: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>		quantity	mounting type	faucet type	control type	plumbing remarks																																																																																		
II																																																																																											
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																							
MEDICAL GASES: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table> Medical Gas Remarks: <table border="1" style="width:100%;"></table>		(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.									ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control	
(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																							
Oxygen																																																																																											
Medical Air																																																																																											
Medical Vacuum																																																																																											
Nitrous Oxide																																																																																											
Nitrogen																																																																																											
CO2																																																																																											
Scavenging																																																																																											
Laser Smoke Evac.																																																																																											

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>			quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet																																					
	quantity																																																
Telecommunication Outlets 2A/1I	1																																																
Television Outlets 1A/1C/1NC																																																	
Patient Monitoring Outlets 2A Red Data Port																																																	
Headwall Outlets 2PM/3A (per headwall)																																																	
NURSE CALL: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>			quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:		<table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td>1</td> <td>Code Blue</td> <td>Staff Assist</td> <td>Patient Assist</td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td>1</td> <td>Code Blue</td> <td>Code White</td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station	1	Code Blue	Staff Assist	Patient Assist		2/3B: 2/3 button station	1	Code Blue	Code White			4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																																
DS Duty Station																																																	
MCS Full feature master control station																																																	
EPCA Emergency Pull Cord station with Audio																																																	
Other:																																																	
	quantity	feature 1	feature 2	feature 3	feature 4																																												
PS: Patient Station	1	Code Blue	Staff Assist	Patient Assist																																													
2/3B: 2/3 button station	1	Code Blue	Code White																																														
4B: 4 button station (single gang)																																																	
VST: VoIP Staff Terminal/Station																																																	
Other																																																	

IMIT Remarks: 2/3B mounted outside the door in the hallway. Provide tamper proof ceiling mounted 2 way Audio nurse call device to be monitored from care station master station. Pullcord provided but can be removed based on patients acuity.

VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%;"></table> Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"></table>		SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	
---	--	---	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: material: <input type="checkbox"/> Washable Wall: material: <input type="checkbox"/> Waterproof Cover. Floor: material: <input type="checkbox"/> Non-Skid Base: material: <input type="checkbox"/> Flash Cove	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>F</td> <td>1</td> <td>1530 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PW-01</td> </tr> </table>	type	quantity	size	material	finish	Hardware Group	F	1	1530 x 2135	Solid Core	Plam	PW-01	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator													
type	quantity	size	material	finish	Hardware Group																						
F	1	1530 x 2135	Solid Core	Plam	PW-01																						
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input checked="" type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input checked="" type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input checked="" type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input checked="" type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input checked="" type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																									
HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																											
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>						
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) <input type="text"/> finish <input type="text"/> Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish <input type="text"/> Washroom Vanity: 914 Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI. Provide Tamper proof anti-ligature device
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Lighting: <input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input checked="" type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input checked="" type="checkbox"/> Night Light <input checked="" type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input checked="" type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks: <input style="width:100%;" type="text"/>				
Boom:	Normal			
Boom:	Normal			
Boom:	Normal			

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text"/> III Remarks: <input style="width:100%;" type="text"/>	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Counter</td> <td>Anti-Ligature</td> <td>Electronic Control</td> </tr> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Counter	Anti-Ligature	Electronic Control																																																																																	
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Lavatory	1	Counter	Anti-Ligature	Electronic Control																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Shower																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> <tr> <td>Oxygen</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Medical Air</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Medical Vacuum</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Nitrous Oxide</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Nitrogen</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>CO2</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Scavenging</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Laser Smoke Evac.</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;																																				
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack																																				
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack																																				
Patient Monitoring Outlets 2A Red Data Port		C – Coax																																				
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet																																				
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td>2</td> </tr> <tr> <td>Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u></td> <td></td> </tr> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio	2	Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u>																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio	2																																					
Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u>																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <input style="width:100%;" type="text"/>
VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <input style="width:100%;" type="text"/> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Dedicated Exhaust Remarks: <input style="width:100%;" type="text"/>

IMIT Remarks: EPCA to be anti-ligature. 2/3B Button to be located outside door in hallway. provide remote shutdown of power to all patient rooms and secure rooms. Provide tamper [proof, ligature proof devices]
SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB - Abuse Resistant	Paint
Wall: GWB - Impact & Moisture and Mould Resistant	Paint
Floor: Resilient	Cushioned
Base: Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

DOORS:

type	quantity	size	material	finish	Hardware Group
C	1	1220 x 2135	Hollow Metal	Paint	SPR-01

DOOR HARDWARE: Access Control

Other Features:

Sidelight
 Integral Blinds
 Security Grille
 Laser Ready Integral Blinds

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets <input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers <input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: II

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
				Combination water closet and lavatory penal fixture

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: Water closet/lavatory

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	provide anti-ligature and tamper proof devices
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off

Headwall

Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: Provide tamper proof ceiling mounted 2 way Audio nurse call device to be monitored from care station master station. provide remote shutdown of power to all patient rooms and secure rooms. Provide tamper proof, ligature proof devices

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <input type="checkbox"/> GWB - Abuse Resistant <input type="checkbox"/> Washable Wall: <input type="checkbox"/> GWB - Impact Resistant <input type="checkbox"/> Washable Floor: <input type="checkbox"/> Resilient <input type="checkbox"/> Slip Resistant Base: <input type="checkbox"/> Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>C</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>SPR-02</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	C	1	1065 x 2135	Solid Core	Plam	SPR-02
type	quantity	size	material	finish	Hardware Group										
C	1	1065 x 2135	Solid Core	Plam	SPR-02										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds													
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input checked="" type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input checked="" type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input checked="" type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input checked="" type="checkbox"/> INT-3													
ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws													

MILLWORK:		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	
Upper Cabinets	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	
Lower Cabinets/Drawers	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Countertop:	min. length (mm)	finish	Custom:	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/>					finish
Washroom Vanity:				Patient Wardrobe: <input type="checkbox"/>					
				Mail Slots: <input type="checkbox"/>					

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <input style="width:100%;" type="text"/>		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Anti-Ligature</td> <td>Electronic Control</td> <td></td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </table>				Hand Hygiene	1	Wall Hung	Anti-Ligature	Electronic Control													
Hand Hygiene	1	Wall Hung	Anti-Ligature	Electronic Control																			
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> <input type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Concealed hose bib																							

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <input style="width:100%;" type="text" value="BMS Monitor and Control"/>

VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: <input style="width:100%;" type="text"/> Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <input style="width:100%;" type="text"/>

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input checked="" type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock
LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input checked="" type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks: <input style="width:100%;" type="text"/>

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td></td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I		Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing
	quantity											
Telecommunication Outlets 2A/1I												
Television Outlets 1A/1C/1NC												
Patient Monitoring Outlets 2A Red Data Port												
Headwall Outlets 2PM/3A (per headwall)												

NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other: <input style="width:100%;" type="text"/></td> <td></td> </tr> </tbody> </table>		quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other: <input style="width:100%;" type="text"/>	
	quantity									
DS Duty Station										
MCS Full feature master control station										
EPCA Emergency Pull Cord station with Audio										
Other: <input style="width:100%;" type="text"/>										

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White	Code Pink	Staff Assist
Other					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: material: Washable, finish: Washable Wall: material: Washable, finish: Waterproof Cover. Floor: Resilient, finish: Non-Skid Base: Flash Cove	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>F</td> <td>1</td> <td>1530 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PW-01</td> </tr> </table>	type	quantity	size	material	finish	Hardware Group	F	1	1530 x 2135	Solid Core	Plam	PW-01	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator
type	quantity	size	material	finish	Hardware Group									
F	1	1530 x 2135	Solid Core	Plam	PW-01									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input checked="" type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input checked="" type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input checked="" type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input checked="" type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input checked="" type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track												
MILLWORK: Upper Cabinets: <input type="checkbox"/> finish: doors: <input type="checkbox"/> combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/> finish: doors: <input type="checkbox"/> combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/>			HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws											
Countertop: min. length (mm): finish: Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish:		Options: <input type="checkbox"/> Standing Height Counter Washroom Vanity: 914 finish: Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>												

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI. Provide Tamper proof anti-ligature device
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Lighting: <input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input checked="" type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input checked="" type="checkbox"/> Night Light <input checked="" type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input checked="" type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks:				

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Counter</td> <td>Anti-Ligature</td> <td>Electronic Control</td> </tr> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Counter	Anti-Ligature	Electronic Control
quantity	mounting type	faucet type	control type	plumbing remarks							
Lavatory	1	Counter	Anti-Ligature	Electronic Control							
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Shower											

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	2
Other: Locate 1 EPCA between toilet and sink, 1 adjacent to shower	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: EPCA to be anti-ligature. 2/3B Button to be located outside door in hallway. provide remote shutdown of power to all patient rooms and secure rooms. Provide tamper [proof, ligature proof devices

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </tbody> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	B	1	1220 x 2135	Solid Core	Plam	CR-01				
GWB	Washable																										
GWB	Washable																										
Resilient	Slip Resistant																										
Flash Cove																											
type	quantity	size	material	finish	Hardware Group																						
B	1	1220 x 2135	Solid Core	Plam	CR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																									
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																									
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table> Countertop: min. length (mm) <input type="text" value="0"/> finish <input type="text"/> Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish <input type="text"/> Washroom Vanity: <input type="text"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks:

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <input style="width:100%; height:40px;" type="text"/>		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>				quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																					
MEDICAL GASES: (Quantity)		Headwall 1 Nursing Side Non-Nursing Side		Headwall 2 Nursing Side Non-Nursing Side		Overhead Booms		Other																	
Oxygen																									
Medical Air																									
Medical Vacuum																									
Nitrous Oxide																									
Nitrogen																									
CO2																									
Scavenging																									
Laser Smoke Evac.																									
Medical Gas Remarks: <input style="width:100%; height:20px;" type="text"/>																									

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>			quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet																																					
	quantity																																																
Telecommunication Outlets 2A/1I	1																																																
Television Outlets 1A/1C/1NC																																																	
Patient Monitoring Outlets 2A Red Data Port																																																	
Headwall Outlets 2PM/3A (per headwall)																																																	
NURSE CALL: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td>1</td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other: _____</td> <td></td> </tr> </tbody> </table>			quantity	DS Duty Station	1	MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other: _____		<table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																																
DS Duty Station	1																																																
MCS Full feature master control station																																																	
EPCA Emergency Pull Cord station with Audio																																																	
Other: _____																																																	
	quantity	feature 1	feature 2	feature 3	feature 4																																												
PS: Patient Station																																																	
2/3B: 2/3 button station																																																	
4B: 4 button station (single gang)																																																	
VST: VoIP Staff Terminal/Station																																																	
Other																																																	
IMIT Remarks: <input style="width:100%; height:20px;" type="text"/>																																																	

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control	
VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input checked="" type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="text"/> Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <input style="width:100%; height:20px;" type="text"/>	

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System			
--	--	--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
B	1	1220 x 2135	Solid Core	Plam	CR-01

Door Hardware: Access Control Other Features: Sidelight, Integral Blinds, Security Grille, Laser Ready Integral Blinds

WINDOW TREATMENT: Horizontal Blinds, Roller Shade - Black Out, Curtain Fabric, Integral Blinds, Roller Shade - Mesh, Laser Ready Integral Blinds, Vertical Blinds, One Way Mirror, Anti-Ligature

MENTAL HEALTH GLASS TYPES: EXT-1, EXT-2, EXT-3, INT-1, INT-2, INT-3

ROOM ACCESSORIES: Coat Hooks, Coat Hooks - Anti-ligature, Mirror, Mirror - Vandal Resistant, Privacy Curtain, Privacy Curtain - Anti-ligature, Shower Seat, Shower Curtain, Shower Curtain - Anti-ligature, Ceiling IV Track

HARM PREVENTION: Industrial anti-ligature tamper-resistant sprinkler, Concealed pendant quick response sprinkler, Tamper proof screws and fittings, Vandal resistant anti-ligature plumbing fixtures, Vandal resistant tamper proof pipe and valve cover, Vandal resistant tamper proof and access panels, Security-type ventilating grille, Vandal resistant lighting fixtures and tamper resistant receptacles, Tamper resistant lighting fixtures and tamper resistant receptacles, Tamper Proof and Anti ligature Breakaway Smoke Detector Cover, Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

Upper Cabinets	Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	<input type="checkbox"/>	Stainless Steel	<input type="checkbox"/> Standing Height Counter					

Countertop: min. length (mm) 2400, finish Stainless Steel

Washroom Vanity: min. length (mm) _____, finish _____

Reception, Transaction Counter, or Care Team Station Desk: _____ finish _____

Patient Wardrobe: _____ finish _____

Mail Slots: _____ finish _____

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks: _____

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene: 1	Wall Hung	Gooseneck	Electronic Control	
Utility: 1	Counter	Gooseneck	Lever Blade	

Other Fixtures: Urinal, Instantaneous Hot Water, Emergency Shower, Macerator, Eye Wash, Floor Drain, Water Closet

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout, Room Relative Humidity with Local Readout, Room Pressure Monitor with Local Readout, Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal, Positive, Negative, Other: _____

Exhaust Required: Yes, No, Dedicated Exhaust, Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off

Headwall

Clock

LIGHTING:

Workstation Task Light

Bedside Staff Light

Visitor Light

Night Light

Vanity Light

In Use Light Laser and/or X-ray

Zone Controller

Colour Tunable

Reading Light

Hand Hygiene Sink Light

Examination Light

Shower Light

Circadian Lighting

lighting remarks: _____

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend; Intercom Station, Video Intercom Station, Overhead Paging (Pub Address), Teleconferencing

A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM: Security Camera, Panic Duress - Wired, Clinical Camera, Patient Wandering System, Clinical Camera Monitor, Security Camera Monitor, Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Impact & Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>	GWB	Washable	GWB - Impact & Moisture and Mould Resistant	Washable	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>WR-01</td> </tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	type	quantity	size	material	finish	Hardware Group	A	1	1065 x 2135	Solid Core	Plam	WR-01
GWB	Washable																				
GWB - Impact & Moisture and Mould Resistant	Washable																				
Resilient	Non-Skid																				
Flash Cove																					
type	quantity	size	material	finish	Hardware Group																
A	1	1065 x 2135	Solid Core	Plam	WR-01																
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input checked="" type="checkbox"/> Anti-Ligature																				
MENTAL HEALTH GLASS TYPES: <input checked="" type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input checked="" type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																				
HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																					

MILLWORK: Upper Cabinets: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/>	finish doors combination doors & open lockable adjustable shelves microwave shelf	Options: <input type="checkbox"/> Standing Height Counter	Countertop: <table border="1" style="width:100%;"><tr><td> </td><td> </td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td> </td><td> </td></tr></table>					Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>	finish

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>III</td></tr></table> Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>	III		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Anti-Ligature</td> <td>Electronic Control</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input type="checkbox"/>	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Anti-Ligature	Electronic Control
III													
quantity	mounting type	faucet type	control type	plumbing remarks									
Lavatory	1	Wall Hung	Anti-Ligature	Electronic Control									

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

--

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>	

VENTILATION: Relative Pressure: <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%;"><tr><td> </td></tr></table> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>		

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input checked="" type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock	
LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input checked="" type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>	

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other: <u>Locate EPCA between toilet and sink</u>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>	

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>WR-03</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	WR-03												
GWB	Washable																																		
GWB - Moisture and Mould Resistant	Washable																																		
Resilient	Non-Skid																																		
Flash Cove																																			
type	quantity	size	material	finish	Hardware Group																														
A	1	914 x 2135	Solid Core	Plam	WR-03																														
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																																	
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																																	
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		min. length (mm)	finish			min. length (mm)	finish			HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																												
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																												
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																													
min. length (mm)	finish																																		
min. length (mm)	finish																																		

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Lighting Legend: <input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input checked="" type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks				

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td></td></tr></table>			PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input type="checkbox"/>		quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Gooseneck	Electronic Control																																																																				
quantity	mounting type	faucet type	control type	plumbing remarks																																																																														
Lavatory	1	Wall Hung	Gooseneck	Electronic Control																																																																														
MEDICAL GASES: <table border="1" style="width:100%; text-align: center;"> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="2">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> </tr> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </table>		(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			Oxygen								Medical Air								Medical Vacuum								Nitrous Oxide								Nitrogen								CO2								Scavenging								Laser Smoke Evac.								Medical Gas Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>		
(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other																																																																											
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																														
Oxygen																																																																																		
Medical Air																																																																																		
Medical Vacuum																																																																																		
Nitrous Oxide																																																																																		
Nitrogen																																																																																		
CO2																																																																																		
Scavenging																																																																																		
Laser Smoke Evac.																																																																																		

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>Telecommunication Outlets 2A/1I</td> <td></td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </table>			quantity	Telecommunication Outlets 2A/1I		Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend: A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet																																					
	quantity																																																
Telecommunication Outlets 2A/1I																																																	
Television Outlets 1A/1C/1NC																																																	
Patient Monitoring Outlets 2A Red Data Port																																																	
Headwall Outlets 2PM/3A (per headwall)																																																	
NURSE CALL: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td>0</td> </tr> <tr> <td>Other: _____</td> <td></td> </tr> </table>			quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio	0	Other: _____		<table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																																
DS Duty Station																																																	
MCS Full feature master control station																																																	
EPCA Emergency Pull Cord station with Audio	0																																																
Other: _____																																																	
	quantity	feature 1	feature 2	feature 3	feature 4																																												
PS: Patient Station																																																	
2/3B: 2/3 button station																																																	
4B: 4 button station (single gang)																																																	
VST: VoIP Staff Terminal/Station																																																	
Other																																																	

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>		
VENTILATION: Relative Pressure: <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: _____ Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>		

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	
---	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	CR-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	1065 x 2135	Solid Core	Plam	CR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 4500 finish Solid Surfacing Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	2	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		2	charging stations
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks
 provide master zone lighting controller. Provide specialty lighting - LED under cabinet & cove lighting

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	2
Headwall Outlets 2PM/3A (per headwall)	

Legend;
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control	
quantity	mounting type	faucet type	control type	plumbing remarks							
1	Wall Hung	Gooseneck	Electronic Control								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:											

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:


NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	1
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist	
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: locate Patient monitoring outlets in bulkhead.

SECURITY SYSTEM: <input checked="" type="checkbox"/> Security Camera <input checked="" type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Infant Abduction System <input checked="" type="checkbox"/> Patient Wandering System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: type quantity size material finish Hardware Group  Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight, <input type="checkbox"/> Integral Blinds, <input type="checkbox"/> Security Grille, <input type="checkbox"/> Laser Ready Integral Blinds																									
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																									
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																									
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws		MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> <td></td> </tr> </table> Countertop: min. length (mm) 2400 finish Solid Surfacing Washroom Vanity: _____ Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																						

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																		

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: _____

VENTILATION: Relative Pressure Equal Positive Negative Other: _____
 Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>G</td> <td>1</td> <td>914 x 2135</td> <td>Aluminum</td> <td>Prefinished</td> <td>SL-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	G	1	914 x 2135	Aluminum	Prefinished	SL-01												
type	quantity	size	material	finish	Hardware Group																						
G	1	914 x 2135	Aluminum	Prefinished	SL-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 1500 finish Plastic Laminate Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/> finish																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks										
quantity	mounting type	faucet type	control type	plumbing remarks												
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;	
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack	<input type="checkbox"/> Intercom Station
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack	<input type="checkbox"/> Video Intercom Station
Patient Monitoring Outlets 2A Red Data Port		C – Coax	<input type="checkbox"/> Overhead Paging (Pub Address)
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call	<input type="checkbox"/> Teleconferencing
		PM- Patient Monitoring Outlet	

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
G	1	1220 x 2135	Aluminum	Prefinished	AO-01

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2
 EXT-3 INT-1
 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets: <input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers: <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		

Countertop: min. length (mm) 3000 finish Solid Surfacing Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene: 1	Wall Hung	Gooseneck	Electronic Control	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

- LIGHTING:**
- Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend; Intercom Station Video Intercom Station
A – Active/Allocated Data Port or Data Jack Overhead Paging (Pub Address)
I – Inactive/Unallocated Data Port or Data Jack Teleconferencing
C – Coax NC – Nurse Call
PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White	Staff Assist	
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: locate 2/3B button at door

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB - Impact Resistant	Washable
Floor: Resilient	Slip Resistant
Base: Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

DOORS:

type	quantity	size	material	finish	Hardware Group
B	1	914 x 2135	Solid Core	Plam	IA-01
B	1	914 x 2135	Solid Core	Plam	IA-01

Door Hardware: Access Control

Other Features:

Sidelight
 Integral Blinds
 Security Grille
 Laser Ready Integral Blinds

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		

Countertop: min. length (mm) 1500, finish Plastic Laminate

Washroom Vanity: min. length (mm) _____, finish _____

Reception, Transaction Counter, or Care Team Station Desk: finish _____

Patient Wardrobe: finish _____

Mail Slots: finish _____

MECHANICAL REQUIREMENTS

HVAC: Type: II

Remarks: _____

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: _____

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side	_____	_____	_____	
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout

Room Control Remarks: _____

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust

Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks: _____

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	1
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB - Impact Resistant Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: type quantity size material finish Hardware Group Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input checked="" type="checkbox"/> Anti-Ligature	
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	
HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws			

MILLWORK:		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Countertop:	min. length (mm)	finish	Custom: Reception, Transaction Counter, or Care Team Station Desk:		<input type="checkbox"/>	finish		
Washroom Vanity:			Patient Wardrobe:		<input type="checkbox"/>			
			Mail Slots:		<input type="checkbox"/>			

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Anti-Ligature</td> <td>Electronic Control</td> <td></td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </table>				Hand Hygiene	1	Wall Hung	Anti-Ligature	Electronic Control													
Hand Hygiene	1	Wall Hung	Anti-Ligature	Electronic Control																			
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																							

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS monitor and control

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2	Duplex	2	
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB - Abuse Resistant</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Impact Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB - Abuse Resistant	Washable	GWB - Impact Resistant	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>F</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PR-01</td> </tr> </tbody> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input checked="" type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	F	1	1220 x 2135	Solid Core	Plam	PR-01												
GWB - Abuse Resistant	Washable																																		
GWB - Impact Resistant	Washable																																		
Resilient	Slip Resistant																																		
Flash Cove																																			
type	quantity	size	material	finish	Hardware Group																														
F	1	1220 x 2135	Solid Core	Plam	PR-01																														
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input checked="" type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input checked="" type="checkbox"/> Anti-Ligature																																	
MENTAL HEALTH GLASS TYPES: <input checked="" type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input checked="" type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																																	
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		min. length (mm)	finish			min. length (mm)	finish			HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																												
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																												
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																													
min. length (mm)	finish																																		
min. length (mm)	finish																																		
Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Patient Wardrobe: <input checked="" type="checkbox"/> Mail Slots: <input type="checkbox"/>		finish <input type="checkbox"/> Plastic Laminate																																	

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	
UPS	Duplex		3	
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks
 Beside light switchable outside door

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="II"/> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td></td></tr></table>			PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%;"><tr><td></td><td></td><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td><td></td><td></td></tr></table>																																																																															
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																																																																																		
MEDICAL GASES: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="2">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>		(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			Oxygen								Medical Air								Medical Vacuum								Nitrous Oxide								Nitrogen								CO2								Scavenging								Laser Smoke Evac.								Medical Gas Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>		
(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other																																																																											
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																														
Oxygen																																																																																		
Medical Air																																																																																		
Medical Vacuum																																																																																		
Nitrous Oxide																																																																																		
Nitrogen																																																																																		
CO2																																																																																		
Scavenging																																																																																		
Laser Smoke Evac.																																																																																		

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>			quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet																																					
	quantity																																																
Telecommunication Outlets 2A/1I	1																																																
Television Outlets 1A/1C/1NC																																																	
Patient Monitoring Outlets 2A Red Data Port																																																	
Headwall Outlets 2PM/3A (per headwall)																																																	
NURSE CALL: <table border="1" style="width:100%;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other: _____</td> <td></td> </tr> </tbody> </table>			quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other: _____		<table border="1" style="width:100%;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td>1</td> <td>Staff Assist</td> <td>Patient Assist</td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td>1</td> <td>Code Blue</td> <td>Code White</td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station	1	Staff Assist	Patient Assist			2/3B: 2/3 button station	1	Code Blue	Code White			4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																																
DS Duty Station																																																	
MCS Full feature master control station																																																	
EPCA Emergency Pull Cord station with Audio																																																	
Other: _____																																																	
	quantity	feature 1	feature 2	feature 3	feature 4																																												
PS: Patient Station	1	Staff Assist	Patient Assist																																														
2/3B: 2/3 button station	1	Code Blue	Code White																																														
4B: 4 button station (single gang)																																																	
VST: VoIP Staff Terminal/Station																																																	
Other																																																	

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS monitor and control		
VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: _____ Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>		

IMIT Remarks: 2/3B mounted outside the door in the hallway. Provide tamper proof ceiling mounted 2 way Audio nurse call device to be monitored from care station master station. Pullcord provided but can be removed based on patients acuity.

<input type="checkbox"/> Security Camera	<input type="checkbox"/> Panic Duress - Wired	<input type="checkbox"/> Clinical Camera	<input checked="" type="checkbox"/> Patient Wandering System
<input type="checkbox"/> Clinical Camera Monitor	<input type="checkbox"/> Security Camera Monitor	<input type="checkbox"/> Infant Abduction System	

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB - Impact & Moisture Resistant</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Impact & Moisture Resistant</td><td>Waterproof Cover.</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB - Impact & Moisture Resistant	Washable	GWB - Impact & Moisture Resistant	Waterproof Cover.	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>WR-01</td> </tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight, <input type="checkbox"/> Integral Blinds, <input type="checkbox"/> Security Grille, <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	A	1	1065 x 2135	Solid Core	Plam	WR-01																
GWB - Impact & Moisture Resistant	Washable																																						
GWB - Impact & Moisture Resistant	Waterproof Cover.																																						
Resilient	Non-Skid																																						
Flash Cove																																							
type	quantity	size	material	finish	Hardware Group																																		
A	1	1065 x 2135	Solid Core	Plam	WR-01																																		
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds, <input type="checkbox"/> Roller Shade - Black Out, <input type="checkbox"/> Curtain Fabric, <input type="checkbox"/> Integral Blinds, <input type="checkbox"/> Roller Shade - Mesh, <input type="checkbox"/> Laser Ready Integral Blinds, <input type="checkbox"/> Vertical Blinds, <input type="checkbox"/> One Way Mirror, <input checked="" type="checkbox"/> Anti-Ligature MENTAL HEALTH GLASS TYPES: <input checked="" type="checkbox"/> EXT-1, <input type="checkbox"/> EXT-2, <input type="checkbox"/> EXT-3, <input type="checkbox"/> INT-1, <input type="checkbox"/> INT-2, <input type="checkbox"/> INT-3																																					
ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks, <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature, <input type="checkbox"/> Mirror, <input checked="" type="checkbox"/> Mirror - Vandal Resistant, <input type="checkbox"/> Privacy Curtain, <input type="checkbox"/> Privacy Curtain - Anti-ligature, <input checked="" type="checkbox"/> Shower Seat, <input type="checkbox"/> Shower Curtain, <input checked="" type="checkbox"/> Shower Curtain - Anti-ligature, <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler, <input type="checkbox"/> Concealed pendant quick response sprinkler, <input checked="" type="checkbox"/> Tamper proof screws and fittings, <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures, <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover, <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels, <input checked="" type="checkbox"/> Security-type ventilating grille, <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles, <input checked="" type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles, <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover, <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																					
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td>914</td><td>Solid Surfacing</td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td>914</td><td>Solid Surfacing</td></tr></table> Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> <table border="1" style="width:100%;"><tr><td>finish</td></tr><tr><td></td></tr></table> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/> <table border="1" style="width:100%;"><tr><td>finish</td></tr><tr><td></td></tr></table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		min. length (mm)	finish	914	Solid Surfacing	min. length (mm)	finish	914	Solid Surfacing	finish		finish												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																																
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																																
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																																	
min. length (mm)	finish																																						
914	Solid Surfacing																																						
min. length (mm)	finish																																						
914	Solid Surfacing																																						
finish																																							
finish																																							

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI. Provide Tamper proof anti-ligature device
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input checked="" type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input checked="" type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks				
Boom:	Normal			
Boom:	Normal			
Boom:	Normal			

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Counter</td> <td>Anti-Ligature</td> <td>Electronic Control</td> </tr> </table> Provide remote water supply shut off by staff through BMS Other Fixtures: <input type="checkbox"/> Urinal, <input type="checkbox"/> Instantaneous Hot Water, <input type="checkbox"/> Emergency Shower, <input type="checkbox"/> Macerator, <input type="checkbox"/> Eye Wash, <input checked="" type="checkbox"/> Floor Drain, <input checked="" type="checkbox"/> Water Closet, <input checked="" type="checkbox"/> Shower				quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Counter	Anti-Ligature	Electronic Control																																																																			
quantity	mounting type	faucet type	control type	plumbing remarks																																																																														
Lavatory	1	Counter	Anti-Ligature	Electronic Control																																																																														
MEDICAL GASES: <table border="1" style="width:100%; text-align: center;"> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="2">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> </tr> <tr> <td>Oxygen</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Medical Air</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Medical Vacuum</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Nitrous Oxide</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Nitrogen</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>CO2</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Scavenging</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Laser Smoke Evac.</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table> Medical Gas Remarks:					(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			Oxygen								Medical Air								Medical Vacuum								Nitrous Oxide								Nitrogen								CO2								Scavenging								Laser Smoke Evac.							
(Quantity)	Headwall 1		Headwall 2			Overhead Booms		Other																																																																										
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																														
Oxygen																																																																																		
Medical Air																																																																																		
Medical Vacuum																																																																																		
Nitrous Oxide																																																																																		
Nitrogen																																																																																		
CO2																																																																																		
Scavenging																																																																																		
Laser Smoke Evac.																																																																																		

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;																																														
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack																																														
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack																																														
Patient Monitoring Outlets 2A Red Data Port		C – Coax																																														
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call																																														
		PM- Patient Monitoring Outlet																																														
NURSE CALL: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td>2</td> </tr> <tr> <td>Other: Locate 1 EPCA between toilet and sink, 1 adjacent to shower</td> <td></td> </tr> </table> <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio	2	Other: Locate 1 EPCA between toilet and sink, 1 adjacent to shower			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																															
DS Duty Station																																																
MCS Full feature master control station																																																
EPCA Emergency Pull Cord station with Audio	2																																															
Other: Locate 1 EPCA between toilet and sink, 1 adjacent to shower																																																
	quantity	feature 1	feature 2	feature 3	feature 4																																											
PS: Patient Station																																																
2/3B: 2/3 button station																																																
4B: 4 button station (single gang)																																																
VST: VoIP Staff Terminal/Station																																																
Other																																																

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:	
VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Dedicated Exhaust Remarks:	

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	
--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB - Abuse Resistant	Washable
Wall: GWB - Impact Resistant	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
C	1	1065 x 2135	Solid Core	Plam	SPR-02

Access Control Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Lighting:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Anti-Ligature	Electronic Control

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: Concealed hose bib

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White	Code Pink	Staff Assist
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: material: Washable Wall: material: Waterproof Cover. Floor: Resilient Base: Flash Cove	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>F</td> <td>1</td> <td>1530 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PW-01</td> </tr> </table>	type	quantity	size	material	finish	Hardware Group	F	1	1530 x 2135	Solid Core	Plam	PW-01	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator
type	quantity	size	material	finish	Hardware Group									
F	1	1530 x 2135	Solid Core	Plam	PW-01									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input checked="" type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input checked="" type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input checked="" type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input checked="" type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input checked="" type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track												
MILLWORK: Upper Cabinets: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/> Countertop: min. length (mm): 914 finish: Solid Surfacing Washroom Vanity: 914 finish: Solid Surfacing			HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI. Provide Tamper proof anti-ligature device
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Counter</td> <td>Anti-Ligature</td> <td>Electronic Control</td> </tr> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Counter	Anti-Ligature	Electronic Control	Provide remote water supply shut off by staff through BMS																																																																				
quantity	mounting type	faucet type	control type	plumbing remarks																																																																												
Lavatory	1	Counter	Anti-Ligature	Electronic Control																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="2">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> </tr> <tr> <td>Oxygen</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Medical Air</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Medical Vacuum</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Nitrous Oxide</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Nitrogen</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>CO2</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Scavenging</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Laser Smoke Evac.</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>			(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			Oxygen								Medical Air								Medical Vacuum								Nitrous Oxide								Nitrogen								CO2								Scavenging								Laser Smoke Evac.							
(Quantity)	Headwall 1			Headwall 2		Overhead Booms		Other																																																																								
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																												
Oxygen																																																																																
Medical Air																																																																																
Medical Vacuum																																																																																
Nitrous Oxide																																																																																
Nitrogen																																																																																
CO2																																																																																
Scavenging																																																																																
Laser Smoke Evac.																																																																																

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	2
Other: Locate 1 EPCA between toilet and sink, 1 adjacent to shower	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

IMIT Remarks: EPCA to be anti-ligature. 2/3B Button to be located outside door in hallway. provide remote shutdown of power to all patient rooms and secure rooms. Provide tamper [proof, ligature proof devices

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: material <input type="text" value="GWB"/> finish <input type="text" value="Washable"/> Wall: material <input type="text" value="GWB"/> finish <input type="text" value="Washable"/> Floor: material <input type="text" value="Resilient"/> finish <input type="text" value="Slip Resistant"/> Base: material <input type="text" value="Flash Cove"/>	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>B</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </table>	type	quantity	size	material	finish	Hardware Group	B	1	1220 x 2135	Solid Core	Plam	CR-01	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:30%;"> WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator </td> <td style="width:30%;"> WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature </td> <td style="width:30%;"> MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3 </td> <td style="width:30%;"> ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track </td> <td style="width:30%;"> HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws </td> </tr> </table>	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws
type	quantity	size	material	finish	Hardware Group														
B	1	1220 x 2135	Solid Core	Plam	CR-01														
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws															

MILLWORK: Upper Cabinets: <input checked="" type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/>	finish: <input type="text" value="Stainless Steel"/> doors: <input type="checkbox"/> combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/>	Options: <input type="checkbox"/> Standing Height Counter	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>	Countertop: min. length (mm) <input type="text" value="2400"/> finish <input type="text" value="Stainless Steel"/> Washroom Vanity: min. length (mm) <input type="text"/> finish <input type="text"/>
---	--	--	---	--

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <input style="width:100%;" type="text"/>	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> <tr> <td>Utility</td> <td>1</td> <td>Counter</td> <td>Gooseneck</td> <td>Lever Blade</td> </tr> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control	Utility	1	Counter	Gooseneck	Lever Blade	Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input checked="" type="checkbox"/> Macerator: <input checked="" type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>
quantity	mounting type	faucet type	control type	plumbing remarks													
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control													
Utility	1	Counter	Gooseneck	Lever Blade													

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: <input style="width:100%;" type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Impact & Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB - Impact & Moisture and Mould Resistant	Washable	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>WR-01</td> </tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	A	1	1065 x 2135	Solid Core	Plam	WR-01									
GWB	Washable																															
GWB - Impact & Moisture and Mould Resistant	Washable																															
Resilient	Non-Skid																															
Flash Cove																																
type	quantity	size	material	finish	Hardware Group																											
A	1	1065 x 2135	Solid Core	Plam	WR-01																											
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input checked="" type="checkbox"/> Anti-Ligature																														
MENTAL HEALTH GLASS TYPES: <input checked="" type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input checked="" type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																														
HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws		MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table> Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		min. length (mm)	finish			min. length (mm)	finish											
finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																										
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																										
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																											
min. length (mm)	finish																															
min. length (mm)	finish																															

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI. Provide Tamper proof anti-ligature device
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; text-align: center;"> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Anti-Ligature</td> <td>Electronic Control</td> <td></td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet:				Lavatory	1	Wall Hung	Anti-Ligature	Electronic Control	
Lavatory	1	Wall Hung	Anti-Ligature	Electronic Control							
MEDICAL GASES: (Quantity)		Headwall 1		Headwall 2		Overhead Booms		Other			
		Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side						
Oxygen											
Medical Air											
Medical Vacuum											
Nitrous Oxide											
Nitrogen											
CO2											
Scavenging											
Laser Smoke Evac.											

Medical Gas Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other: Locate EPCA between toilet and sink	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: provide remote shutdown of power to all patient rooms and secure rooms. Provide tamper [proof, ligature proof devices

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>	GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>WR-03</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	WR-03
GWB	Washable																				
GWB - Moisture and Mould Resistant	Washable																				
Resilient	Non-Skid																				
Flash Cove																					
type	quantity	size	material	finish	Hardware Group																
A	1	914 x 2135	Solid Core	Plam	WR-03																
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																	

MILLWORK: Upper Cabinets: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/>	finish doors combination doors & open lockable adjustable shelves microwave shelf	Options: <input type="checkbox"/> Standing Height Counter	Countertop: <table border="1" style="width:100%;"><tr><td> </td><td> </td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td> </td><td> </td></tr></table>					Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>	finish

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>III</td></tr></table> Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>	III		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input type="checkbox"/>	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Gooseneck	Electronic Control
III													
quantity	mounting type	faucet type	control type	plumbing remarks									
Lavatory	1	Wall Hung	Gooseneck	Electronic Control									

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

--

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout	Room Control Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>	

VENTILATION: Relative Pressure: <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%;"><tr><td> </td></tr></table>		Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust	Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>	

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock	LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input checked="" type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting	lighting remarks <table border="1" style="width:100%;"><tr><td> </td></tr></table>	

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	<table border="1" style="width:100%;"> <tr> <th> </th> <th>quantity</th> </tr> <tr><td>Telecommunication Outlets 2A/1I</td><td></td></tr> <tr><td>Television Outlets 1A/1C/1NC</td><td></td></tr> <tr><td>Patient Monitoring Outlets 2A Red Data Port</td><td></td></tr> <tr><td>Headwall Outlets 2PM/3A (per headwall)</td><td></td></tr> </table>		quantity	Telecommunication Outlets 2A/1I		Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing
	quantity												
Telecommunication Outlets 2A/1I													
Television Outlets 1A/1C/1NC													
Patient Monitoring Outlets 2A Red Data Port													
Headwall Outlets 2PM/3A (per headwall)													

NURSE CALL:	<table border="1" style="width:100%;"> <tr> <th> </th> <th>quantity</th> </tr> <tr><td>DS Duty Station</td><td></td></tr> <tr><td>MCS Full feature master control station</td><td></td></tr> <tr><td>EPCA Emergency Pull Cord station with Audio</td><td></td></tr> <tr><td>Other: <table border="1" style="width:100%;"><tr><td> </td></tr></table></td><td></td></tr> </table>		quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other: <table border="1" style="width:100%;"><tr><td> </td></tr></table>		
	quantity											
DS Duty Station												
MCS Full feature master control station												
EPCA Emergency Pull Cord station with Audio												
Other: <table border="1" style="width:100%;"><tr><td> </td></tr></table>												

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>	

SECURITY SYSTEM:	<input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System	<input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
-------------------------	--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB - Moisture and Mould Resistant Washable Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																											WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	
type	quantity	size	material	finish	Hardware Group																																																
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																															

MILLWORK:		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	
Upper Cabinets	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	
Lower Cabinets/Drawers	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Countertop:	min. length (mm)	finish	Custom:	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/>					finish
Washroom Vanity:				Patient Wardrobe: <input type="checkbox"/>					
				Mail Slots: <input type="checkbox"/>					

MECHANICAL REQUIREMENTS

HVAC: Type: II Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>				Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control													
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control																			
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																							

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:
--

VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	GFI	
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	
Telecommunication Outlets 2A/1I		
Television Outlets 1A/1C/1NC		
Patient Monitoring Outlets 2A Red Data Port		
Headwall Outlets 2PM/3A (per headwall)		

Legend;

- A – Active/Allocated Data Port or Data Jack
- I – Inactive/Unallocated Data Port or Data Jack
- C – Coax
- NC – Nurse Call
- PM- Patient Monitoring Outlet

- Intercom Station
- Video Intercom Station
- Overhead Paging (Pub Address)
- Teleconferencing

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	1

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets: Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers: Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Countertop: min. length (mm) 1800 finish Solid Surfacing

Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: finish

Patent Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	1
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene: 1	Wall Hung	Gooseneck	Electronic Control	
Double Bowl: 1	Counter	Gooseneck	Lever Blade	

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>WR-03</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	WR-03												
GWB	Washable																																		
GWB - Moisture and Mould Resistant	Washable																																		
Resilient	Non-Skid																																		
Flash Cove																																			
type	quantity	size	material	finish	Hardware Group																														
A	1	914 x 2135	Solid Core	Plam	WR-03																														
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																																	
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																																	
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		min. length (mm)	finish			min. length (mm)	finish			HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																												
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																												
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																													
min. length (mm)	finish																																		
min. length (mm)	finish																																		

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <div style="border: 1px solid black; height: 40px; width: 100%;"></div>	PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Shower	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Gooseneck	Electronic Control
quantity	mounting type	faucet type	control type	plumbing remarks							
Lavatory	1	Wall Hung	Gooseneck	Electronic Control							

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust Remarks:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	0
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB - Abuse Resistant Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>E</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CL-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	E	1	1065 x 2135	Solid Core	Plam	CL-01
type	quantity	size	material	finish	Hardware Group										
E	1	1065 x 2135	Solid Core	Plam	CL-01										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds													
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3													
ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws													

MILLWORK: finish doors combination doors & open lockable adjustable shelves microwave shelf Upper Cabinets <input type="checkbox"/> Lower Cabinets/Drawers <input type="checkbox"/>		Options: <input type="checkbox"/> Standing Height Counter	
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>			

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																		
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																				

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control
--

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input checked="" type="checkbox"/> Clock
LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet
Telecommunication Outlets 2A/1I	quantity: 2	<input type="checkbox"/> Intercom Station
Television Outlets 1A/1C/1NC	quantity: 1	<input type="checkbox"/> Video Intercom Station
Patient Monitoring Outlets 2A Red Data Port		<input checked="" type="checkbox"/> Overhead Paging (Pub Address)
Headwall Outlets 2PM/3A (per headwall)		<input type="checkbox"/> Teleconferencing

NURSE CALL:		quantity
DS Duty Station		
MCS Full feature master control station		
EPCA Emergency Pull Cord station with Audio		1
Other:		

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PA-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	914 x 2135	Solid Core	Plam	PA-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	914 x 2135	Solid Core	Plam	PA-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																						
Countertop: min. length (mm) 2400 finish Solid Surfacing Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Rubber		DOORS: type quantity size material finish Hardware Group A B C D E F G H Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																									
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																									
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws		MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: min. length (mm) 915 finish Plastic Laminate Washroom Vanity: _____ Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> _____ finish Patient Wardrobe: <input type="checkbox"/> _____ Mail Slots: <input type="checkbox"/> _____			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																					

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks: _____	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/> _____	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: _____

VENTILATION: Relative Pressure Equal Positive Negative Other: _____
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
	Vital	Duplex	1	pneumatic tube
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: provide nurse call connection to pneumatic tube.

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PA-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	914 x 2135	Solid Core	Plam	PA-01
type	quantity	size	material	finish	Hardware Group										
B	1	914 x 2135	Solid Core	Plam	PA-01										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds													
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												

MILLWORK:		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Countertop:	min. length (mm)	finish	Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/>					
3000		Plastic Laminate	Patient Wardrobe: <input type="checkbox"/>					
Washroom Vanity:			Mail Slots: <input type="checkbox"/>					

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																		
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																			

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control
--

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="text"/> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <input type="text"/>

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2	Duplex	1	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		2	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	
Telecommunication Outlets 2A/1I	2	
Television Outlets 1A/1C/1NC		
Patient Monitoring Outlets 2A Red Data Port		
Headwall Outlets 2PM/3A (per headwall)		

Legend;
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other: <input type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>C</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>SR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	C	1	1065 x 2135	Solid Core	Plam	SR-01												
type	quantity	size	material	finish	Hardware Group																						
C	1	1065 x 2135	Solid Core	Plam	SR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input checked="" type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks										
quantity	mounting type	faucet type	control type	plumbing remarks												
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	0
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB - Abuse Resistant	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	CR-01
A	1	914 x 2135	Solid Core	Plam	CR-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: II

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	CR-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	1065 x 2135	Solid Core	Plam	CR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input checked="" type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input checked="" type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Wall Hung</td> <td>Anti-Ligature</td> <td>Electronic Control</td> <td></td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Anti-Ligature	Electronic Control	
quantity	mounting type	faucet type	control type	plumbing remarks							
1	Wall Hung	Anti-Ligature	Electronic Control								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:											

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB - Abuse Resistant	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
B	1	914 x 2135	Solid Core	Plam	IA-01
B	1	914 x 2135	Solid Core	Plam	IA-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: II

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB - Moisture and Mould Resistant Washable Floor: Resilient Non-Skid Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>E</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PA-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	E	1	914 x 2135	Solid Core	Plam	PA-01
type	quantity	size	material	finish	Hardware Group										
E	1	914 x 2135	Solid Core	Plam	PA-01										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds													
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												

MILLWORK:		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input checked="" type="checkbox"/>	Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input checked="" type="checkbox"/>	Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Countertop:	min. length (mm)	finish	Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/>					
1800		Solid Surfacing	Patient Wardrobe: <input type="checkbox"/>					
Washroom Vanity:			Mail Slots: <input type="checkbox"/>					

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Counter</td> <td>Anti-Ligature</td> <td>Electronic Control</td> <td></td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Counter	Anti-Ligature	Electronic Control	
quantity	mounting type	faucet type	control type	plumbing remarks							
1	Counter	Anti-Ligature	Electronic Control								
Other Fixtures: <input type="checkbox"/> Urinal: <input checked="" type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>											

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	GFI
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB - Abuse Resistant	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	OF-01
A	1	914 x 2135	Solid Core	Plam	OF-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting Checklist:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend:

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Code White	Patient Assist	
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: Acoustic Tile (material), Pre-Finished (finish) Wall: GWB - Abuse Resistant (material), Paint (finish) Floor: Resilient (material), Slip Resistant (finish) Base: Rubber (material)	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>OF-01</td> </tr> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>OF-01</td> </tr> </tbody> </table>	type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	OF-01	A	1	914 x 2135	Solid Core	Plam	OF-01	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator
type	quantity	size	material	finish	Hardware Group															
A	1	914 x 2135	Solid Core	Plam	OF-01															
A	1	914 x 2135	Solid Core	Plam	OF-01															
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																		
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws			Door Hardware: <input type="checkbox"/> Access Control	Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																

MILLWORK: Upper Cabinets: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/>	finish: _____ doors: <input type="checkbox"/> combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/>	lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/>	Options: <input type="checkbox"/> Standing Height Counter	Countertop: min. length (mm) _____ finish _____ Washroom Vanity: min. length (mm) _____ finish _____ Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish _____ Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>
--	---	---	--	---

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks: _____	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/> _____																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout	Room Control Remarks: _____
---	-----------------------------

VENTILATION: Relative Pressure: <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: _____ Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust	Remarks: _____
---	----------------

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Code White	Patient Assist	
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

- SECURITY SYSTEM:**
- Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 - Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	KP-01

Door Hardware: Access Control
 Other Features: Sidelight
 Integral Blinds
 Security Grille
 Laser Ready Integral Blinds

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets: Plastic Laminate <input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers: Plastic Laminate <input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Countertop: min. length (mm) 1800 finish Solid Surfacing
 Washroom Vanity: min. length (mm) Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
 Patient Wardrobe:
 Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	1
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III
 Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene: 1	Wall Hung	Gooseneck	Electronic Control	
Double Bowl: 1	Counter	Gooseneck	Lever Blade	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>WR-03</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	WR-03												
GWB	Washable																																		
GWB - Moisture and Mould Resistant	Washable																																		
Resilient	Non-Skid																																		
Flash Cove																																			
type	quantity	size	material	finish	Hardware Group																														
A	1	914 x 2135	Solid Core	Plam	WR-03																														
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																																	
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																																	
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		min. length (mm)	finish			min. length (mm)	finish			HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																												
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																												
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																													
min. length (mm)	finish																																		
min. length (mm)	finish																																		

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td></td></tr></table>			PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; text-align: center;"> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>		Lavatory	1	Wall Hung	Gooseneck	Electronic Control							
Lavatory	1	Wall Hung	Gooseneck	Electronic Control												
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input type="checkbox"/>																

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

--

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

--

VENTILATION: Relative Pressure Equal Positive Negative Other:

--

 Exhaust Required: Yes No Dedicated Exhaust Remarks:

--

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity	
DS Duty Station		
MCS Full feature master control station		
EPCA Emergency Pull Cord station with Audio	0	
Other: <table border="1" style="width:100%;"><tr><td></td></tr></table>		

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

--

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <input type="checkbox"/> GWB - Abuse Resistant <input type="checkbox"/> Paint Wall: <input type="checkbox"/> GWB - Impact Resistant <input type="checkbox"/> Paint Floor: <input type="checkbox"/> Resilient <input type="checkbox"/> Slip Resistant Base: <input type="checkbox"/> Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>ST-02</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	ST-02												
type	quantity	size	material	finish	Hardware Group																						
A	1	914 x 2135	Solid Core	Plam	ST-02																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks										
quantity	mounting type	faucet type	control type	plumbing remarks												
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;	
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack	<input type="checkbox"/> Intercom Station
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack	<input type="checkbox"/> Video Intercom Station
Patient Monitoring Outlets 2A Red Data Port		C – Coax	<input type="checkbox"/> Overhead Paging (Pub Address)
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call	<input type="checkbox"/> Teleconferencing
		PM- Patient Monitoring Outlet	

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White	Code Pink	Staff Assist
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	CR-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	1065 x 2135	Solid Core	Plam	CR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 3000 finish Solid Surfacing Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2		2	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		2	charging stations
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

LIGHTING:
 Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks
 provide master zone lighting controller. Provide specialty lighting - LED under cabinet & cove lighting

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control	
quantity	mounting type	faucet type	control type	plumbing remarks							
1	Wall Hung	Gooseneck	Electronic Control								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:											

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port	2	C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	1
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist	
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: locate Patient monitoring outlets in bulkhead.

SECURITY SYSTEM: <input checked="" type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input checked="" type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Impact Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB - Impact Resistant	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group																			
GWB	Washable																																			
GWB - Impact Resistant	Washable																																			
Resilient	Slip Resistant																																			
Flash Cove																																				
type	quantity	size	material	finish	Hardware Group																															
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																																		
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																																		
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws		MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets <input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers <input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td> </td><td> </td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td> </td><td> </td></tr></table> Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> <table border="1" style="width:100%;"><tr><td> </td><td> </td></tr></table> Patient Wardrobe: <input type="checkbox"/> <table border="1" style="width:100%;"><tr><td> </td><td> </td></tr></table> Mail Slots: <input type="checkbox"/> <table border="1" style="width:100%;"><tr><td> </td><td> </td></tr></table>		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets <input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers <input type="checkbox"/>		min. length (mm)	finish																				
finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																														
Upper Cabinets <input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																														
Lower Cabinets/Drawers <input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																															
min. length (mm)	finish																																			

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks:

--

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks: 10 air changes		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%;"><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr></table>																		
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																				
MEDICAL GASES: (Quantity)		Headwall 1		Headwall 2		Overhead Booms		Other												
		Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side															
Oxygen																				
Medical Air																				
Medical Vacuum																				
Nitrous Oxide																				
Nitrogen																				
CO2																				
Scavenging																				
Laser Smoke Evac.																				
Medical Gas Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>																				

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%;"><tr><th> </th><th>quantity</th></tr><tr><td>Telecommunication Outlets 2A/1I</td><td> </td></tr><tr><td>Television Outlets 1A/1C/1NC</td><td> </td></tr><tr><td>Patient Monitoring Outlets 2A Red Data Port</td><td> </td></tr><tr><td>Headwall Outlets 2PM/3A (per headwall)</td><td> </td></tr></table>			quantity	Telecommunication Outlets 2A/1I		Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet																																					
	quantity																																																
Telecommunication Outlets 2A/1I																																																	
Television Outlets 1A/1C/1NC																																																	
Patient Monitoring Outlets 2A Red Data Port																																																	
Headwall Outlets 2PM/3A (per headwall)																																																	
NURSE CALL: <table border="1" style="width:100%;"><tr><th> </th><th>quantity</th></tr><tr><td>DS Duty Station</td><td> </td></tr><tr><td>MCS Full feature master control station</td><td> </td></tr><tr><td>EPCA Emergency Pull Cord station with Audio</td><td> </td></tr><tr><td>Other: _____</td><td> </td></tr></table>			quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other: _____		<table border="1" style="width:100%;"><tr><th> </th><th>quantity</th><th>feature 1</th><th>feature 2</th><th>feature 3</th><th>feature 4</th></tr><tr><td>PS: Patient Station</td><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td>2/3B: 2/3 button station</td><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td>4B: 4 button station (single gang)</td><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td>VST: VoIP Staff Terminal/Station</td><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td>Other</td><td> </td><td> </td><td> </td><td> </td><td> </td></tr></table>			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																																
DS Duty Station																																																	
MCS Full feature master control station																																																	
EPCA Emergency Pull Cord station with Audio																																																	
Other: _____																																																	
	quantity	feature 1	feature 2	feature 3	feature 4																																												
PS: Patient Station																																																	
2/3B: 2/3 button station																																																	
4B: 4 button station (single gang)																																																	
VST: VoIP Staff Terminal/Station																																																	
Other																																																	
IMIT Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>																																																	

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>			
VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%;"><tr><td> </td></tr></table> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>			

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	
--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling Acoustic Tile Pre-Finished Wall GWB Paint Floor Resilient Slip Resistant Base Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PA-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	914 x 2135	Solid Core	Plam	PA-01
type	quantity	size	material	finish	Hardware Group										
B	1	914 x 2135	Solid Core	Plam	PA-01										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds													
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												

MILLWORK:		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Countertop:	min. length (mm)	finish	Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/>					
Washroom Vanity:	3000	Plastic Laminate	Patient Wardrobe: <input type="checkbox"/>					
			Mail Slots: <input type="checkbox"/>					

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																		
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																			

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control
--

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="text"/> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <input type="text"/>

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2	Duplex	1	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		2	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input checked="" type="checkbox"/> Clock	LIGHTING: <input checked="" type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks
---	--

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>2</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	2	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing
	quantity											
Telecommunication Outlets 2A/1I	2											
Television Outlets 1A/1C/1NC												
Patient Monitoring Outlets 2A Red Data Port												
Headwall Outlets 2PM/3A (per headwall)												

NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td>1</td> </tr> <tr> <td>Other: <input type="text"/></td> <td></td> </tr> </tbody> </table>		quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio	1	Other: <input type="text"/>	
	quantity									
DS Duty Station										
MCS Full feature master control station										
EPCA Emergency Pull Cord station with Audio	1									
Other: <input type="text"/>										

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: <input type="text"/>

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: material <input type="text" value="GWB"/> finish <input type="text" value="Washable"/> Wall: material <input type="text" value="GWB - Moisture and Mould Resistant"/> finish <input type="text" value="Washable"/> Floor: material <input type="text" value="Resilient"/> finish <input type="text" value="Slip Resistant"/> Base: material <input type="text" value="Flash Cove"/> finish <input type="text"/>	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>G</td> <td>1</td> <td>1220 x 2135</td> <td>Aluminum</td> <td>Prefinished</td> <td>AO-01</td> </tr> </table>	type	quantity	size	material	finish	Hardware Group	G	1	1220 x 2135	Aluminum	Prefinished	AO-01	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:30%;"> WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator </td> <td style="width:30%;"> WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature </td> <td style="width:30%;"> MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3 </td> <td style="width:30%;"> ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input checked="" type="checkbox"/> Ceiling IV Track </td> <td style="width:30%;"> HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws </td> </tr> </table>	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input checked="" type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws
type	quantity	size	material	finish	Hardware Group														
G	1	1220 x 2135	Aluminum	Prefinished	AO-01														
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input checked="" type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws															

MILLWORK: Upper Cabinets: <input checked="" type="checkbox"/> Plastic Laminate Lower Cabinets/Drawers: <input checked="" type="checkbox"/> Plastic Laminate	finish: <input type="text" value="Plastic Laminate"/> doors: <input type="checkbox"/> combination doors & open: <input checked="" type="checkbox"/> lockable: <input checked="" type="checkbox"/> adjustable shelves: <input checked="" type="checkbox"/> microwave shelf: <input type="checkbox"/>	Options: <input checked="" type="checkbox"/> Standing Height Counter	Countertop: min. length (mm) <input type="text" value="2400"/> finish <input type="text" value="Solid Surfacing"/> Washroom Vanity: <input type="text"/> finish <input type="text"/>	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish <input type="text"/> Patient Wardrobe: <input type="checkbox"/> finish <input type="text"/> Mail Slots: <input type="checkbox"/> finish <input type="text"/>
--	--	---	---	---

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="II"/> Remarks: <input type="text"/>	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control		Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>
quantity	mounting type	faucet type	control type	plumbing remarks								
1	Wall Hung	Gooseneck	Electronic Control									

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout	Room Control Remarks: <input type="text" value="BMS Monitor and Control"/>
--	--

VENTILATION: Relative Pressure: <input type="checkbox"/> Equal <input checked="" type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="text"/>	Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <input type="text"/>
---	--

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input checked="" type="checkbox"/> Clock	LIGHTING: <input checked="" type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input checked="" type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks: <input type="text"/>
---	---

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet
	quantity										
Telecommunication Outlets 2A/1I	1										
Television Outlets 1A/1C/1NC											
Patient Monitoring Outlets 2A Red Data Port											
Headwall Outlets 2PM/3A (per headwall)											

NURSE CALL: DS Duty Station MCS Full feature master control station EPCA Emergency Pull Cord station with Audio Other: <input type="text"/>	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>DS Duty Station</td> <td>1</td> </tr> </table>		quantity	DS Duty Station	1
	quantity				
DS Duty Station	1				

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White	Staff Assist	
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: <input type="text" value="locate 2/3B button at door"/>
--

SECURITY SYSTEM: <input checked="" type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System	<input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
---	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>WR-03</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	WR-03												
GWB	Washable																																		
GWB - Moisture and Mould Resistant	Washable																																		
Resilient	Non-Skid																																		
Flash Cove																																			
type	quantity	size	material	finish	Hardware Group																														
A	1	914 x 2135	Solid Core	Plam	WR-03																														
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																																	
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																																	
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		min. length (mm)	finish			min. length (mm)	finish			HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																												
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																												
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																													
min. length (mm)	finish																																		
min. length (mm)	finish																																		

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock				
LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input checked="" type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td></td></tr></table>			PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input type="checkbox"/>		quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Gooseneck	Electronic Control																																																																														
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Lavatory	1	Wall Hung	Gooseneck	Electronic Control																																																																																								
MEDICAL GASES: <table border="1" style="width:100%; text-align: center;"> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> <tr> <td>Oxygen</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Medical Air</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Medical Vacuum</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Nitrous Oxide</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Nitrogen</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>CO2</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Scavenging</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Laser Smoke Evac.</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>		(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.									Medical Gas Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>		
(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other																																																																																				
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>Telecommunication Outlets 2A/1I</td> <td></td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </table>			quantity	Telecommunication Outlets 2A/1I		Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet																																					
	quantity																																																
Telecommunication Outlets 2A/1I																																																	
Television Outlets 1A/1C/1NC																																																	
Patient Monitoring Outlets 2A Red Data Port																																																	
Headwall Outlets 2PM/3A (per headwall)																																																	
NURSE CALL: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td>0</td> </tr> <tr> <td>Other: _____</td> <td></td> </tr> </table>			quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio	0	Other: _____		<table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																																
DS Duty Station																																																	
MCS Full feature master control station																																																	
EPCA Emergency Pull Cord station with Audio	0																																																
Other: _____																																																	
	quantity	feature 1	feature 2	feature 3	feature 4																																												
PS: Patient Station																																																	
2/3B: 2/3 button station																																																	
4B: 4 button station (single gang)																																																	
VST: VoIP Staff Terminal/Station																																																	
Other																																																	
ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>			IMIT Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>																																														

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%;"><tr><td></td></tr></table> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>			

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	
--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB - Abuse Resistant</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Impact Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB - Abuse Resistant	Washable	GWB - Impact Resistant	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PR-02</td> </tr> </tbody> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input checked="" type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	B	1	1220 x 2135	Solid Core	Plam	PR-02								
GWB - Abuse Resistant	Washable																														
GWB - Impact Resistant	Washable																														
Resilient	Slip Resistant																														
Flash Cove																															
type	quantity	size	material	finish	Hardware Group																										
B	1	1220 x 2135	Solid Core	Plam	PR-02																										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input checked="" type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input checked="" type="checkbox"/> Anti-Ligature																													
MENTAL HEALTH GLASS TYPES: <input checked="" type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input checked="" type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																													
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm): 1500</td><td>finish: Solid Surfacing</td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm):</td><td>finish:</td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		min. length (mm): 1500	finish: Solid Surfacing	min. length (mm):	finish:	HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																								
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																								
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																									
min. length (mm): 1500	finish: Solid Surfacing																														
min. length (mm):	finish:																														

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	
UPS	Duplex		3	
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting:	<input checked="" type="checkbox"/> Patient Care Area Designation as per CSA Z32
<input checked="" type="checkbox"/> Remote Power Shut-Off	<input checked="" type="checkbox"/> Headwall
<input checked="" type="checkbox"/> Clock	LIGHTING:
<input checked="" type="checkbox"/> Workstation Task Light	<input type="checkbox"/> Bedside Staff Light
<input type="checkbox"/> Bedside Staff Light	<input type="checkbox"/> Visitor Light
<input type="checkbox"/> Visitor Light	<input checked="" type="checkbox"/> Night Light
<input type="checkbox"/> Night Light	<input type="checkbox"/> Vanity Light
<input type="checkbox"/> Vanity Light	<input type="checkbox"/> In Use Light Laser and/or X-ray
<input type="checkbox"/> In Use Light Laser and/or X-ray	<input type="checkbox"/> Zone Controller
<input type="checkbox"/> Zone Controller	<input type="checkbox"/> Colour Tunable
<input type="checkbox"/> Colour Tunable	<input checked="" type="checkbox"/> Reading Light
<input checked="" type="checkbox"/> Reading Light	<input type="checkbox"/> Hand Hygiene Sink Light
<input type="checkbox"/> Hand Hygiene Sink Light	<input type="checkbox"/> Examination Light
<input type="checkbox"/> Examination Light	<input type="checkbox"/> Shower Light
<input type="checkbox"/> Shower Light	<input type="checkbox"/> Circadian Lighting
<input type="checkbox"/> Circadian Lighting	lighting remarks
Beside light switchable outside door	

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>II</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"></table>		II	PLUMBING: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>		quantity	mounting type	faucet type	control type	plumbing remarks																																																																																			
II																																																																																												
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
MEDICAL GASES: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table> Medical Gas Remarks: <table border="1" style="width:100%; height: 20px;"></table>		(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.									ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <table border="1" style="width:100%;"><tr><td>BMS Monitor and Control</td></tr></table>		BMS Monitor and Control
(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other																																																																																				
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
BMS Monitor and Control																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>			quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet																																			
	quantity																																														
Telecommunication Outlets 2A/1I	1																																														
Television Outlets 1A/1C/1NC																																															
Patient Monitoring Outlets 2A Red Data Port																																															
Headwall Outlets 2PM/3A (per headwall)																																															
NURSE CALL: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table> <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td>1</td> <td>Code Blue</td> <td>Staff Assist</td> <td>Patient Assist</td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td>1</td> <td>Code Blue</td> <td>Code White</td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>			quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station	1	Code Blue	Staff Assist	Patient Assist		2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station	1	Code Blue	Code White			Other					
	quantity																																														
DS Duty Station																																															
MCS Full feature master control station																																															
EPCA Emergency Pull Cord station with Audio																																															
Other:																																															
	quantity	feature 1	feature 2	feature 3	feature 4																																										
PS: Patient Station	1	Code Blue	Staff Assist	Patient Assist																																											
2/3B: 2/3 button station																																															
4B: 4 button station (single gang)																																															
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White																																												
Other																																															
IMIT Remarks: <table border="1" style="width:100%;"><tr><td>2/3B mounted outside the door in the hallway. Provide tamper proof ceiling mounted 2 way Audio nurse call device to be monitored from care station master station. Pullcord provided but can be removed based on patients acuity.</td></tr></table>		2/3B mounted outside the door in the hallway. Provide tamper proof ceiling mounted 2 way Audio nurse call device to be monitored from care station master station. Pullcord provided but can be removed based on patients acuity.																																													
2/3B mounted outside the door in the hallway. Provide tamper proof ceiling mounted 2 way Audio nurse call device to be monitored from care station master station. Pullcord provided but can be removed based on patients acuity.																																															

VENTILATION: Relative Pressure: <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%;"><tr><td> </td></tr></table> Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%; height: 20px;"></table>		

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	
--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: material: <input type="checkbox"/> Washable Wall: material: <input type="checkbox"/> Waterproof Cover. Floor: material: <input type="checkbox"/> Non-Skid Base: material: <input type="checkbox"/> Flash Cove	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PW-01</td> </tr> </table>	type	quantity	size	material	finish	Hardware Group	A	1	1065 x 2135	Solid Core	Plam	PW-01	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input checked="" type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input checked="" type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input checked="" type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input checked="" type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input checked="" type="checkbox"/> Shower Curtain- Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																				
type	quantity	size	material	finish	Hardware Group																																	
A	1	1065 x 2135	Solid Core	Plam	PW-01																																	
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>Upper Cabinets</th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td><input type="checkbox"/></td> <td></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <th>Lower Cabinets/Drawers</th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td><input type="checkbox"/></td> <td></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> </table>							Upper Cabinets	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	<input type="checkbox"/>		<input type="checkbox"/> Standing Height Counter					
Upper Cabinets	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																															
<input type="checkbox"/>		<input type="checkbox"/> Standing Height Counter																																				
Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																															
<input type="checkbox"/>		<input type="checkbox"/> Standing Height Counter																																				
Countertop: min. length (mm) <input type="text"/> finish <input type="text"/> Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish <input type="text"/> Washroom Vanity: 914 Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																																						

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock				
LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input checked="" type="checkbox"/> Night Light <input checked="" type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input checked="" type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks				
Boom:	Normal			
Boom:	Normal			
Boom:	Normal			

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text"/> III Remarks: <input style="width:100%;" type="text"/>	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>1</td> <td>Counter</td> <td>Anti-Ligature</td> <td>Electronic Control</td> <td>Provide remote water supply shut off by staff through BMS</td> </tr> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Counter	Anti-Ligature	Electronic Control	Provide remote water supply shut off by staff through BMS	Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Shower																																																																				
quantity	mounting type	faucet type	control type	plumbing remarks																																																																												
1	Counter	Anti-Ligature	Electronic Control	Provide remote water supply shut off by staff through BMS																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="2">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> </tr> <tr> <td>Oxygen</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Medical Air</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Medical Vacuum</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Nitrous Oxide</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Nitrogen</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>CO2</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Scavenging</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Laser Smoke Evac.</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>			(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			Oxygen								Medical Air								Medical Vacuum								Nitrous Oxide								Nitrogen								CO2								Scavenging								Laser Smoke Evac.							
(Quantity)	Headwall 1			Headwall 2		Overhead Booms		Other																																																																								
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																												
Oxygen																																																																																
Medical Air																																																																																
Medical Vacuum																																																																																
Nitrous Oxide																																																																																
Nitrogen																																																																																
CO2																																																																																
Scavenging																																																																																
Laser Smoke Evac.																																																																																

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;																																				
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack																																				
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack																																				
Patient Monitoring Outlets 2A Red Data Port		C – Coax																																				
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call																																				
		PM- Patient Monitoring Outlet																																				
		<input type="checkbox"/> Intercom Station																																				
		<input type="checkbox"/> Video Intercom Station																																				
		<input type="checkbox"/> Overhead Paging (Pub Address)																																				
		<input type="checkbox"/> Teleconferencing																																				
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td>2</td> </tr> <tr> <td>Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u></td> <td></td> </tr> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio	2	Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u>																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio	2																																					
Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u>																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <input style="width:100%;" type="text"/>
VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <input style="width:100%;" type="text"/> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Dedicated Exhaust Remarks: <input style="width:100%;" type="text"/>

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB - Abuse Resistant</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Impact Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB - Abuse Resistant	Washable	GWB - Impact Resistant	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>C</td> <td>1</td> <td>1220 x 2135</td> <td>Hollow Metal</td> <td>Paint</td> <td>SPR-01</td> </tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight, <input checked="" type="checkbox"/> Integral Blinds, <input type="checkbox"/> Security Grille, <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	C	1	1220 x 2135	Hollow Metal	Paint	SPR-01
GWB - Abuse Resistant	Washable																						
GWB - Impact Resistant	Washable																						
Resilient	Slip Resistant																						
Flash Cove																							
type	quantity	size	material	finish	Hardware Group																		
C	1	1220 x 2135	Hollow Metal	Paint	SPR-01																		
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input checked="" type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input checked="" type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input checked="" type="checkbox"/> Anti-Ligature																					
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input checked="" type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input checked="" type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																					
HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																							

MILLWORK:		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	
Upper Cabinets	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	
Lower Cabinets/Drawers	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Countertop:	min. length (mm)	finish	Custom:	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/>					finish
Washroom Vanity:				Patient Wardrobe: <input type="checkbox"/>					
				Mail Slots: <input type="checkbox"/>					

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="II"/> Remarks: <div style="border: 1px solid black; height: 50px; width: 100%;"></div>		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%;"><tr><td></td><td></td><td></td><td></td><td>Combination water closet and lavatory penal fixture</td></tr><tr><td></td><td></td><td></td><td></td><td></td></tr><tr><td></td><td></td><td></td><td></td><td></td></tr></table>						Combination water closet and lavatory penal fixture										
				Combination water closet and lavatory penal fixture														
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Water closet/lavatory																		

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control
--

VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="text"/> Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <div style="border: 1px solid black; width: 100%; height: 20px;"></div>
--

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex headwall & 1 duplex bed
UPS	Duplex		3	2 duplex headwall & 1 duplex above bed right side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input checked="" type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input checked="" type="checkbox"/> Remote Power Shut-Off <input checked="" type="checkbox"/> Headwall <input checked="" type="checkbox"/> Clock LIGHTING: <input checked="" type="checkbox"/> Workstation Task Light <input checked="" type="checkbox"/> Bedside Staff Light <input checked="" type="checkbox"/> Visitor Light <input checked="" type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input checked="" type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks Beside light switchable outside door
--

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;	<input type="checkbox"/> Intercom Station
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack	<input type="checkbox"/> Video Intercom Station
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack	<input type="checkbox"/> Overhead Paging (Pub Address)
Patient Monitoring Outlets 2A Red Data Port		C – Coax	<input type="checkbox"/> Teleconferencing
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call	
		PM- Patient Monitoring Outlet	

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Code White	Patient Assist	Staff Assist
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

Locate 2/3b at entrance to room. Provide tamper proof ceiling mounted 2 way Audio nurse call device to be monitored from care station master station. Pullcord provided but can be removed based on patients acuity.

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input checked="" type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB - Abuse Resistant	Washable
Wall: GWB - Impact Resistant	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
C	1	1065 x 2135	Solid Core	Plam	SPR-02

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain- Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Anti-Ligature	Electronic Control

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: Concealed hose bib

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White	Code Pink	Staff Assist
Other					

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB - Moisture and Mould Resistant Washable Floor: Resilient Non-Skid Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>E</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PA-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	E	1	914 x 2135	Solid Core	Plam	PA-01
type	quantity	size	material	finish	Hardware Group										
E	1	914 x 2135	Solid Core	Plam	PA-01										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds													
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												

MILLWORK:							
Upper Cabinets	<input checked="" type="checkbox"/>	Plastic Laminate	<input checked="" type="checkbox"/>	lockable	<input checked="" type="checkbox"/>	adjustable shelves	<input checked="" type="checkbox"/>
Lower Cabinets/Drawers	<input checked="" type="checkbox"/>	Plastic Laminate	<input checked="" type="checkbox"/>	lockable	<input checked="" type="checkbox"/>	adjustable shelves	<input checked="" type="checkbox"/>
Options:	<input checked="" type="checkbox"/> Standing Height Counter						
Countertop:	min. length (mm)	1800	finish	Solid Surfacing			
Washroom Vanity:	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/>						
	Patient Wardrobe: <input type="checkbox"/>						
	Mail Slots: <input type="checkbox"/>						

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Counter</td> <td>Anti-Ligature</td> <td>Electronic Control</td> <td></td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Counter	Anti-Ligature	Electronic Control	
quantity	mounting type	faucet type	control type	plumbing remarks							
1	Counter	Anti-Ligature	Electronic Control								
Other Fixtures: <input type="checkbox"/> Urinal: <input checked="" type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>											

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:
--

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	GFI
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td></td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I		Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing
	quantity											
Telecommunication Outlets 2A/1I												
Television Outlets 1A/1C/1NC												
Patient Monitoring Outlets 2A Red Data Port												
Headwall Outlets 2PM/3A (per headwall)												


NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>		quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:	
	quantity									
DS Duty Station										
MCS Full feature master control station										
EPCA Emergency Pull Cord station with Audio										
Other:										

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Infant Abduction System <input checked="" type="checkbox"/> Patient Wandering System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB - Impact Resistant Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: type quantity size material finish Hardware Group  Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight, <input type="checkbox"/> Integral Blinds, <input type="checkbox"/> Security Grille, <input type="checkbox"/> Laser Ready Integral Blinds	
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input checked="" type="checkbox"/> Anti-Ligature	
MENTAL HEALTH GLASS TYPES: <input checked="" type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input checked="" type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	
HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input checked="" type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input checked="" type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws		MILLWORK: Upper Cabinets <input type="checkbox"/> Lower Cabinets/Drawers <input type="checkbox"/> finish doors combination doors & open lockable adjustable shelves microwave shelf Options: <input type="checkbox"/> Standing Height Counter Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>	

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2	Duplex	2	
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Lighting: <input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input checked="" type="checkbox"/> Clock <input checked="" type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input checked="" type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks				

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Anti-Ligature</td> <td>Electronic Control</td> <td></td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </table>				Hand Hygiene	1	Wall Hung	Anti-Ligature	Electronic Control																																																																									
Hand Hygiene	1	Wall Hung	Anti-Ligature	Electronic Control																																																																															
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:		MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="2">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>				(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			Oxygen								Medical Air								Medical Vacuum								Nitrous Oxide								Nitrogen								CO2								Scavenging								Laser Smoke Evac.							
(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other																																																																												
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																															
Oxygen																																																																																			
Medical Air																																																																																			
Medical Vacuum																																																																																			
Nitrous Oxide																																																																																			
Nitrogen																																																																																			
CO2																																																																																			
Scavenging																																																																																			
Laser Smoke Evac.																																																																																			

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>			quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Nurse Call: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td>1</td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>			quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio	1	Other:											
	quantity																																
Telecommunication Outlets 2A/1I	1																																
Television Outlets 1A/1C/1NC																																	
Patient Monitoring Outlets 2A Red Data Port																																	
Headwall Outlets 2PM/3A (per headwall)																																	
	quantity																																
DS Duty Station																																	
MCS Full feature master control station																																	
EPCA Emergency Pull Cord station with Audio	1																																
Other:																																	
Legend: A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet		PS: Patient Station <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>			quantity	feature 1	feature 2	feature 3	feature 4	2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																												
2/3B: 2/3 button station																																	
4B: 4 button station (single gang)																																	
VST: VoIP Staff Terminal/Station																																	
Other																																	

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control	
VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:	

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	
--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB - Impact Resistant Paint Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>IA-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	IA-01
type	quantity	size	material	finish	Hardware Group										
B	1	1065 x 2135	Solid Core	Plam	IA-01										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input checked="" type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds													
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input checked="" type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												

MILLWORK:		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Countertop:	min. length (mm)	finish	Custom: Reception, Transaction Counter, or Care Team Station Desk:		<input type="checkbox"/>	finish		
Washroom Vanity:			Patient Wardrobe:		<input type="checkbox"/>			
			Mail Slots:		<input type="checkbox"/>			

MECHANICAL REQUIREMENTS

HVAC: Type: II Remarks:	PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																		
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																			

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control
--

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="text"/> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <input type="text"/>

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: <input type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Infant Abduction System <input checked="" type="checkbox"/> Patient Wandering System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>B</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	B	1	1220 x 2135	Solid Core	Plam	CR-01				
GWB	Washable																										
GWB	Washable																										
Resilient	Slip Resistant																										
Flash Cove																											
type	quantity	size	material	finish	Hardware Group																						
B	1	1220 x 2135	Solid Core	Plam	CR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																									
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																									
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: min. length (mm) <input type="text" value="0"/> finish <input type="text"/> Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish <input type="text"/> Washroom Vanity: <input type="text"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks:

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <input style="width:100%; height:50px;" type="text"/>		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; text-align: center;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																					
MEDICAL GASES: (Quantity)		Headwall 1		Headwall 2		Overhead Booms		Other															
		Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																		
Oxygen																							
Medical Air																							
Medical Vacuum																							
Nitrous Oxide																							
Nitrogen																							
CO2																							
Scavenging																							
Laser Smoke Evac.																							
Medical Gas Remarks: <input style="width:100%; height:20px;" type="text"/>																							

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </table>			quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet																																					
	quantity																																																
Telecommunication Outlets 2A/1I	1																																																
Television Outlets 1A/1C/1NC																																																	
Patient Monitoring Outlets 2A Red Data Port																																																	
Headwall Outlets 2PM/3A (per headwall)																																																	
NURSE CALL: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>DS Duty Station</td> <td>1</td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other: _____</td> <td></td> </tr> </table>			quantity	DS Duty Station	1	MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other: _____		<table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																																
DS Duty Station	1																																																
MCS Full feature master control station																																																	
EPCA Emergency Pull Cord station with Audio																																																	
Other: _____																																																	
	quantity	feature 1	feature 2	feature 3	feature 4																																												
PS: Patient Station																																																	
2/3B: 2/3 button station																																																	
4B: 4 button station (single gang)																																																	
VST: VoIP Staff Terminal/Station																																																	
Other																																																	
IMIT Remarks: <input style="width:100%; height:20px;" type="text"/>																																																	

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control	
VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input checked="" type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="text"/> Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <input style="width:100%; height:20px;" type="text"/>	

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System			
--	--	--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling: **GWB** Washable

Wall: **GWB - Moisture and Mould Resistant** Washable

Floor: **Resilient** Slip Resistant

Base: **Flash Cove**

WALL PROTECTION:
 Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:
 Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:
 EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:
 Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:
 Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

DOORS:

type	quantity	size	material	finish	Hardware Group
B	1	1220 x 2135	Solid Core	Plam	CR-01

Door Hardware: Access Control

Other Features:
 Sidelight
 Integral Blinds
 Security Grille
 Laser Ready Integral Blinds

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input checked="" type="checkbox"/> Stainless Steel	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Countertop: min. length (mm) **2400** finish **Stainless Steel**

Washroom Vanity: min. length (mm) **2400** finish **Stainless Steel**

Reception, Transaction Counter, or Care Team Station Desk: finish

Patient Wardrobe: finish

Mail Slots: finish

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;
A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: **III**

Remarks:

PLUMBING:

	quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control	
Utility	1	Counter	Gooseneck	Lever Blade	

Other Fixtures:
 Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout

Room Control Remarks: **BMS Monitor and Control**

VENTILATION: Relative Pressure Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust

Remarks:

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Impact Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Rubber</td><td>Cushioned</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB - Impact Resistant	Washable	Rubber	Cushioned	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CL-01</td> </tr> </tbody> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight, <input checked="" type="checkbox"/> Integral Blinds, <input type="checkbox"/> Security Grille, <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	CL-01								
GWB	Washable																														
GWB - Impact Resistant	Washable																														
Rubber	Cushioned																														
Flash Cove																															
type	quantity	size	material	finish	Hardware Group																										
B	1	1065 x 2135	Solid Core	Plam	CL-01																										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																													
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input checked="" type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input checked="" type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input checked="" type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																													
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td></td> <td></td> </tr> </tbody> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm): 1800</td><td>finish: Plastic Laminate</td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm):</td><td>finish:</td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			min. length (mm): 1800	finish: Plastic Laminate	min. length (mm):	finish:	HARM PREVENTION: <input checked="" type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input type="checkbox"/> Concealed pendant quick response sprinkler <input checked="" type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input checked="" type="checkbox"/> Vandal resistant tamper proof and access panels <input checked="" type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input checked="" type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input checked="" type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																								
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																								
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>																										
min. length (mm): 1800	finish: Plastic Laminate																														
min. length (mm):	finish:																														

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		2	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC	1	I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>II</td></tr></table> Remarks:	II	PLUMBING: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:	quantity	mounting type	faucet type	control type	plumbing remarks															
II																						
quantity	mounting type	faucet type	control type	plumbing remarks																		

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White	Staff Assist	
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: provide remote shutdown of power. Provide tamper proof, ligature proof devices

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB - Impact Resistant Paint Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>AO-12</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	1	1065 x 2135	Solid Core	Plam	AO-12												
type	quantity	size	material	finish	Hardware Group																						
A	1	1065 x 2135	Solid Core	Plam	AO-12																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 3000 finish Solid Surfacing Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2		2	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		2	charging stations
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

LIGHTING:
 Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks
 provide master zone lighting controller. Provide specialty lighting - LED under cabinet & cove lighting

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control																																																																																		
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
1	Wall Hung	Gooseneck	Electronic Control																																																																																									
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td>2</td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port	2	Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input checked="" type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	1																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port	2																																					
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td>1</td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station	1	EPCA Emergency Pull Cord station with Audio		Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station	1																																					
EPCA Emergency Pull Cord station with Audio																																						
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td>1</td> <td>Code Blue</td> <td>Code White</td> <td>Code Pink</td> <td>Staff Assist</td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)	1	Code Blue	Code White	Code Pink	Staff Assist	VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)	1	Code Blue	Code White	Code Pink	Staff Assist																																	
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks: locate Patient monitoring outlets in bulkhead																																						

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:
VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input checked="" type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group

Access Control Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets: <input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers: <input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Countertop: min. length (mm) 915 finish Plastic Laminate

Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: finish

Patient Wardrobe:
 Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
	Vital	Duplex	1	pneumatic tube
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: provide nurse call connection to pneumatic tube

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																		
type	quantity	size	material	finish	Hardware Group																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	GFI	
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting

 lighting remarks
MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control										
quantity	mounting type	faucet type	control type	plumbing remarks																	
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

 Medical Gas Remarks:
 ROOM CONTROLS:
 Room Temp Control with Local Adjustment and Readout
 Room Relative Humidity with Local Readout
 Room Pressure Monitor with Local Readout
 Room Control Remarks:
 VENTILATION:
 Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:
 TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	0	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

- Intercom Station
- Video Intercom Station
- Overhead Paging (Pub Address)
- Teleconferencing

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

 IMIT Remarks:
 SECURITY SYSTEM:
 Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	OF-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

Upper Cabinets	Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/> Standing Height Counter					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PA-01</td> </tr> </tbody> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	B	1	914 x 2135	Solid Core	Plam	PA-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	914 x 2135	Solid Core	Plam	PA-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																									
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																									
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws		MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table> Countertop: min. length (mm) 3000 finish Plastic Laminate Washroom Vanity: _____ Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> _____ finish Patient Wardrobe: <input type="checkbox"/> _____ Mail Slots: <input type="checkbox"/> _____			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																					

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks: _____		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/> _____		quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																			

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other: _____
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2	Duplex	1	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		2	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	2	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

- SECURITY SYSTEM:**
- Security Camera
 - Clinical Camera Monitor
 - Panic Duress - Wired
 - Security Camera Monitor
 - Clinical Camera
 - Infant Abduction System
 - Patient Wandering System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>G</td> <td>1</td> <td>914 x 2135</td> <td>Aluminum</td> <td>Prefinished</td> <td>SL-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	G	1	914 x 2135	Aluminum	Prefinished	SL-01												
type	quantity	size	material	finish	Hardware Group																						
G	1	914 x 2135	Aluminum	Prefinished	SL-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 1500 finish Plastic Laminate Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/> finish																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																		
type	quantity	size	material	finish	Hardware Group																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input checked="" type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																						
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th> </th> <th> </th> <th> </th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												


TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr><td>Telecommunication Outlets 2A/1I</td><td></td></tr> <tr><td>Television Outlets 1A/1C/1NC</td><td></td></tr> <tr><td>Patient Monitoring Outlets 2A Red Data Port</td><td></td></tr> <tr><td>Headwall Outlets 2PM/3A (per headwall)</td><td></td></tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I		Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I																																						
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr><td>DS Duty Station</td><td></td></tr> <tr><td>MCS Full feature master control station</td><td></td></tr> <tr><td>EPCA Emergency Pull Cord station with Audio</td><td></td></tr> <tr><td>Other: _____</td><td></td></tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other: _____																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other: _____																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr><td>PS: Patient Station</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>2/3B: 2/3 button station</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>4B: 4 button station (single gang)</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>VST: VoIP Staff Terminal/Station</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Other</td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:
VENTILATION: Relative Pressure: <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: type quantity size material finish Hardware Group 	
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input checked="" type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input checked="" type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws
MILLWORK: finish doors combination doors & open lockable adjustable shelves microwave shelf Options: <input type="checkbox"/> Standing Height Counter Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>			

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex headwall & 1 duplex bed
UPS	Duplex		3	2 duplex headwall & 1 duplex above bed right side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting Requirements:
 Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks
 1 hand hygiene sink light per 3 bays. Exam light wall mounted

MECHANICAL REQUIREMENTS

HVAC: Type: II Remarks:	PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td>1 for every 3 bays</td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </table>	Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control	1 for every 3 bays												
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control	1 for every 3 bays														
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																			

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen	1	1						
Medical Air	1	1						
Medical Vacuum	1	1						
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC	0	I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port	1	C – Coax
Headwall Outlets 2PM/3A (per headwall)	1	NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Code White	Patient Assist	
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: Clinical camera to be monitored from OR's after hours.

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>WR-01</td> </tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	A	1	1065 x 2135	Solid Core	Plam	WR-01
GWB	Washable																						
GWB - Moisture and Mould Resistant	Washable																						
Resilient	Non-Skid																						
Flash Cove																							
type	quantity	size	material	finish	Hardware Group																		
A	1	1065 x 2135	Solid Core	Plam	WR-01																		
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																					
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input checked="" type="checkbox"/> Shower Seat <input checked="" type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																					
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																							

MILLWORK:		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Countertop:	min. length (mm)	finish	Custom:	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/>		finish	Patient Wardrobe: <input type="checkbox"/>	
Washroom Vanity:				Mail Slots: <input type="checkbox"/>				

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <input style="width:100%;" type="text"/>		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; text-align: center;"> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input type="checkbox"/>				Lavatory	1	Wall Hung	Gooseneck	Electronic Control													
Lavatory	1	Wall Hung	Gooseneck	Electronic Control																			

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <input style="width:100%;" type="text"/>

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <input style="width:100%;" type="text"/> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Dedicated Exhaust Remarks: <input style="width:100%;" type="text"/>
--

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock
LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input checked="" type="checkbox"/> Night Light <input checked="" type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input checked="" type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks: <input style="width:100%; height:50px;" type="text"/>

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>Telecommunication Outlets 2A/1I</td> <td></td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </table>		quantity	Telecommunication Outlets 2A/1I		Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing
	quantity											
Telecommunication Outlets 2A/1I												
Television Outlets 1A/1C/1NC												
Patient Monitoring Outlets 2A Red Data Port												
Headwall Outlets 2PM/3A (per headwall)												

NURSE CALL: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td>2</td> </tr> <tr> <td>Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u></td> <td></td> </tr> </table>		quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio	2	Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u>	
	quantity									
DS Duty Station										
MCS Full feature master control station										
EPCA Emergency Pull Cord station with Audio	2									
Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u>										

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: <input style="width:100%;" type="text"/>
--

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB - Lead Lined	Paint
Floor: Resilient	Slip Resistant
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
F	2	1530 x 2135	Solid Core	Plam	CR-01 / OR-10

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	3	1 per work bench, floor outlets with waterproof covers
	Normal 2	15A/20A, 120V Housekeeping	30	provide quad every 4' at 1500mm AFF
	Conditional 1	30A, 208Volt Laser Outlet	1	provide 1 per work bench
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Quad		15	Quad every 8' - 480mm AFF
	Duplex		3	locate as directed by the authority
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets: <input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers: <input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		

Countertop: min. length (mm) 2400 finish: Hardwood

Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: finish:

Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	6
Television Outlets 1A/1C/1NC	1
Patient Monitoring Outlets 2A Red Data Port	3
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene: 1	Wall Hung	Gooseneck	Electronic Control	
Utility: 1	Counter	Gooseneck	Lever Blade	

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								2
Medical Air								2
Medical Vacuum								2
Nitrous Oxide								2
Nitrogen								2
CO2								2
Scavenging								2
Laser Smoke Evac.								2

Medical Gas Remarks:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Code White	Code Pink	Staff Assist
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White	Staff Assist	
Other					

IMIT Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
C	1	1065 x 2135	Solid Core	Plam	KP-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		4	located as directed by authority
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting Legend:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
 LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MILLWORK:

Upper Cabinets	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Countertop: min. length (mm) 4000 finish Solid Surfacing

Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: finish

Patent Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend:

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

MECHANICAL REQUIREMENTS

HVAC: Type: II

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control
Utility	1	Wall Hung	Gooseneck	Lever Blade

utility sink with eyewash

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust

Remarks: biological safety cabinet venting to outside and local venting for the staining

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>C</td> <td>2</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	C	2	1220 x 2135	Solid Core	Plam	CR-01								
GWB	Washable																														
GWB - Moisture and Mould Resistant	Washable																														
Resilient	Slip Resistant																														
Flash Cove																															
type	quantity	size	material	finish	Hardware Group																										
C	2	1220 x 2135	Solid Core	Plam	CR-01																										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																													
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																													
MILLWORK: <table border="1" style="width:100%;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Stainless Steel</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm): 2400</td><td>finish: Stainless Steel</td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm):</td><td>finish:</td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Stainless Steel	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		min. length (mm): 2400	finish: Stainless Steel	min. length (mm):	finish:	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws					
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																								
Upper Cabinets	<input checked="" type="checkbox"/> Stainless Steel	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																								
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																									
min. length (mm): 2400	finish: Stainless Steel																														
min. length (mm):	finish:																														

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Lighting Legend: <input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input checked="" type="checkbox"/> Clock LIGHTING: <input checked="" type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks:				

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>III</td></tr></table> Remarks:		III	PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> <tr> <td>Utility</td> <td>1</td> <td>Counter</td> <td>Gooseneck</td> <td>Lever Blade</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input checked="" type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> docking station for fluid		quantity	mounting type	faucet type	control type	plumbing remarks	Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control	Utility	1	Counter	Gooseneck	Lever Blade																																																																								
III																																																																																											
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																							
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control																																																																																							
Utility	1	Counter	Gooseneck	Lever Blade																																																																																							
MEDICAL GASES: <table border="1" style="width:100%; text-align: center;"> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </table> Medical Gas Remarks:		(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.									plumbing remarks: two docking stations. One for safety pump, small for emptying suction canisters and one for door knocker (large irrigation emptying), also add hose bib	
(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																							
Oxygen																																																																																											
Medical Air																																																																																											
Medical Vacuum																																																																																											
Nitrous Oxide																																																																																											
Nitrogen																																																																																											
CO2																																																																																											
Scavenging																																																																																											
Laser Smoke Evac.																																																																																											

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </table>			quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend: A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet																																					
	quantity																																																
Telecommunication Outlets 2A/1I	1																																																
Television Outlets 1A/1C/1NC																																																	
Patient Monitoring Outlets 2A Red Data Port																																																	
Headwall Outlets 2PM/3A (per headwall)																																																	
NURSE CALL: <table border="1" style="width:100%;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>DS Duty Station</td> <td>1</td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </table>			quantity	DS Duty Station	1	MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:		<table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																																
DS Duty Station	1																																																
MCS Full feature master control station																																																	
EPCA Emergency Pull Cord station with Audio																																																	
Other:																																																	
	quantity	feature 1	feature 2	feature 3	feature 4																																												
PS: Patient Station																																																	
2/3B: 2/3 button station																																																	
4B: 4 button station (single gang)																																																	
VST: VoIP Staff Terminal/Station																																																	
Other																																																	

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control	
VENTILATION: Relative Pressure: <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:	

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input checked="" type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	
--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB	Washable
Wall	GWB - Impact & Moisture and Mould Resistant	Washable
Floor	Resilient	Non-Skid
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
C	1	1220 x 2135	Solid Core	Plam	CR-01

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:

PLUMBING:

	quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control	
Janitorial	1	Floor	Standard	Lever Blade	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: Detergent Dispenser

MEDICAL GASES: (Quantity)

	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks	
General Power	Normal 1	15A/20A, 120V Housekeeping	3	Locate HK outlets at 1400mm AFF	
	Normal 2	Duplex	1	GFI	
	Conditional 1				
	Conditional 2				
	Conditional 3				
	Delayed Vital				
Vital					
UPS					
Boom:	Normal				
	Conditional				
	Delayed Vital				
	Vital				
	UPS				
Boom:	Normal				
	Conditional				
	Delayed Vital				
	Vital				
	UPS				
Boom:	Normal				
	Conditional				
	Delayed Vital				
	Vital				
	UPS				

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend; Intercom Station Video Intercom Station
A – Active/Allocated Data Port or Data Jack Overhead Paging (Pub Address)
I – Inactive/Unallocated Data Port or Data Jack Teleconferencing
C – Coax NC – Nurse Call
PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB	Washable
Wall	GWB - Moisture and Mould Resistant	Washable
Floor	Resilient	Slip Resistant
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
C	1	1220 x 2135	Solid Core	Plam	CR-01

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT: Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds Roller Shade - Mesh
 Laser Ready Integral Blinds Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES: EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES: Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature Ceiling IV Track

HARM PREVENTION: Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
1	Wall Hung	Gooseneck	Electronic Control	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES: (Quantity)

	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

- LIGHTING:**
- Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend; Intercom Station Video Intercom Station
A – Active/Allocated Data Port or Data Jack Overhead Paging (Pub Address)
I – Inactive/Unallocated Data Port or Data Jack Teleconferencing
C – Coax NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	0
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	0				
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB	Washable
Wall	GWB - Moisture and Mould Resistant	Washable
Floor	Resilient	Non-Skid
Base:	Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	WR-03

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
1	Wall Hung	Gooseneck	Electronic Control	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	0
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB	Washable
Floor: Seamless Epoxy	Anti-static
Base: Seamless Epoxy	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

DOORS:

type	quantity	size	material	finish	Hardware Group
F	1	1830 x 2135	Solid Core	Plam	OR-10
B	1	1220 x 2135	Solid Core	Plam	OR-01

Access Control Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets: <input checked="" type="checkbox"/> Stainless Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers: <input checked="" type="checkbox"/> Stainless Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		

Countertop: min. length (mm) 3600, finish Solid Surfacing

Washroom Vanity: min. length (mm) _____, finish _____

Reception, Transaction Counter, or Care Team Station Desk: _____ finish _____

Patient Wardrobe: _____ finish _____

Mail Slots: _____ finish _____

MECHANICAL REQUIREMENTS

HVAC: Type: I

Remarks: _____

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: _____

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side	Anesthesia	Equipment	Auxiliary	
Oxygen					2	1	2	1
Medical Air					2	1	2	1
Medical Vacuum					3	3	2	1
Nitrous Oxide					1		1	
Nitrogen						1	1	1
CO2						1	1	
Scavenging					1		1	
Laser Smoke Evac.					1	1	1	

Medical Gas Remarks: _____

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout
 Room Relative Humidity with Local Readout
 Room Pressure Monitor with Local Readout
 Room Control Remarks: 2

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	located as directed by authority
	Normal 2	Duplex	2	located as directed by authority
	Conditional 1		3	Locate 1 per workstation
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	located as directed by authority
UPS	30A, 208Volt Laser Outlet		1	Locate adjacent to Anastasia boom. Foot of the bed
Anesthesia	Normal			
	Conditional			
	Delayed Vital	20A, 208Volt twist lock	1	
	Vital	Duplex	6	
UPS	30A, 208Volt Laser Outlet		1	provide UPS power circuits for 4 of 6 vital duplex receptacles
Equipment	Normal			
	Conditional			
	Delayed Vital	20A, 208Volt twist lock	1	
	Vital	Duplex	6	provide 2 UPS duplex/outlets for 2 of 6 vital receptacles
UPS	30A, 208Volt Laser Outlet		1	provide UPS power circuits for 2 of 6 vital duplex receptacles
Auxiliary	Normal			
	Conditional			
	Delayed Vital	20A, 208Volt twist lock	1	
	Vital	Duplex	6	
UPS	30A, 208Volt Laser Outlet		1	provide UPS power circuits for 4 of 6 vital duplex receptacles

Patient Care Area Designation as per CSA Z32

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks: Provide 6 zone lighting controller. Interlock laser outlet with doors to OR. Laser to shut-off when door opens. Provide digital clocks in OR's.

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	8
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	6
Headwall Outlets 2PM/3A (per headwall)	0

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	2	Code Blue	Code White		
4B: 4 button station (single gang)	1	Code Blue	Code White	Code Pink	
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White	Code Pink	Staff Assist
Other					

IMIT Remarks: VST at door to sterile core. 4B button near nursing desk & 2B button on Anastasia & Auxiliary booms. 2 data and 2 PM outlets on ALL booms. ceiling mounted speakers, 27mm conduit and backboxes for wall mounted docking station.

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>	GWB - Moisture and Mould Resistant	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr><th>type</th><th>quantity</th><th>size</th><th>material</th><th>finish</th><th>Hardware Group</th></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	type	quantity	size	material	finish	Hardware Group							WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input checked="" type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																				
GWB - Moisture and Mould Resistant	Washable																																													
GWB - Moisture and Mould Resistant	Washable																																													
Resilient	Non-Skid																																													
Flash Cove																																														
type	quantity	size	material	finish	Hardware Group																																									
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr><th> </th><th>finish</th><th>doors</th><th>combination doors & open</th><th>lockable</th><th>adjustable shelves</th><th>microwave shelf</th><th>Options:</th></tr> <tr><td>Upper Cabinets</td><td><input type="checkbox"/></td><td><input type="checkbox"/></td><td><input type="checkbox"/></td><td><input type="checkbox"/></td><td><input type="checkbox"/></td><td><input type="checkbox"/></td><td><input type="checkbox"/> Standing Height Counter</td></tr> <tr><td>Lower Cabinets/Drawers</td><td><input type="checkbox"/></td><td><input type="checkbox"/></td><td><input type="checkbox"/></td><td><input type="checkbox"/></td><td><input type="checkbox"/></td><td><input type="checkbox"/></td><td></td></tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td><td>Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/></td><td>finish</td></tr><tr><td>0</td><td></td><td></td><td></td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td><td>Patent Wardrobe: <input type="checkbox"/></td><td>finish</td></tr><tr><td></td><td></td><td>Mail Slots: <input type="checkbox"/></td><td></td></tr></table>								finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		min. length (mm)	finish	Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/>	finish	0				min. length (mm)	finish	Patent Wardrobe: <input type="checkbox"/>	finish			Mail Slots: <input type="checkbox"/>							
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																																							
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																																							
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																																								
min. length (mm)	finish	Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/>	finish																																											
0																																														
min. length (mm)	finish	Patent Wardrobe: <input type="checkbox"/>	finish																																											
		Mail Slots: <input type="checkbox"/>																																												

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="II"/> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td> </td></tr></table>		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr><th>quantity</th><th>mounting type</th><th>faucet type</th><th>control type</th><th>plumbing remarks</th></tr> <tr><td>Other</td><td>1</td><td>Wall Hung</td><td>Gooseneck</td><td>Electronic Control</td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Surgical scrub sink	quantity	mounting type	faucet type	control type	plumbing remarks	Other	1	Wall Hung	Gooseneck	Electronic Control					
quantity	mounting type	faucet type	control type	plumbing remarks													
Other	1	Wall Hung	Gooseneck	Electronic Control													

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

--

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <table border="1" style="width:100%;"><tr><td>BMS Monitor and Control</td></tr></table>	BMS Monitor and Control
BMS Monitor and Control	

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%;"><tr><td> </td></tr></table> Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>		

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	1	GFI
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

Surgical scrub sink lighting

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity	
DS Duty Station		
MCS Full feature master control station		
EPCA Emergency Pull Cord station with Audio		
Other: <table border="1" style="width:100%;"><tr><td> </td></tr></table>		

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

--

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group																		
GWB	Washable																																		
GWB	Washable																																		
Resilient	Slip Resistant																																		
Flash Cove																																			
type	quantity	size	material	finish	Hardware Group																														
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																																	
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																																	
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th> </th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td> </td><td> </td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td> </td><td> </td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		min. length (mm)	finish			min. length (mm)	finish			HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																												
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																												
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																													
min. length (mm)	finish																																		
min. length (mm)	finish																																		

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	2	for bed and/or IV Pump
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Lighting Legend: <input checked="" type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks				

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>II</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td> </td></tr></table>		II		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>		quantity	mounting type	faucet type	control type	plumbing remarks																																																																																			
II																																																																																													
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																									
MEDICAL GASES: <table border="1" style="width:100%; text-align: center;"> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th> </th> <th> </th> <th> </th> </tr> <tr><td>Oxygen</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Medical Air</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Medical Vacuum</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Nitrous Oxide</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Nitrogen</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>CO2</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Scavenging</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Laser Smoke Evac.</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table> Medical Gas Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>		(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.										ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <table border="1" style="width:100%;"><tr><td>BMS Monitor and Control</td></tr></table>		BMS Monitor and Control
(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other																																																																																					
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																									
Oxygen																																																																																													
Medical Air																																																																																													
Medical Vacuum																																																																																													
Nitrous Oxide																																																																																													
Nitrogen																																																																																													
CO2																																																																																													
Scavenging																																																																																													
Laser Smoke Evac.																																																																																													
BMS Monitor and Control																																																																																													

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; text-align: center;"> <tr> <th> </th> <th>quantity</th> </tr> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>0</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td>0</td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td>0</td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td>0</td> </tr> </table>			quantity	Telecommunication Outlets 2A/1I	0	Television Outlets 1A/1C/1NC	0	Patient Monitoring Outlets 2A Red Data Port	0	Headwall Outlets 2PM/3A (per headwall)	0	Legend: A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet																																					
	quantity																																																
Telecommunication Outlets 2A/1I	0																																																
Television Outlets 1A/1C/1NC	0																																																
Patient Monitoring Outlets 2A Red Data Port	0																																																
Headwall Outlets 2PM/3A (per headwall)	0																																																
NURSE CALL: <table border="1" style="width:100%; text-align: center;"> <tr> <th> </th> <th>quantity</th> </tr> <tr> <td>DS Duty Station</td> <td> </td> </tr> <tr> <td>MCS Full feature master control station</td> <td> </td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td> </td> </tr> <tr> <td>Other: _____</td> <td> </td> </tr> </table>			quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other: _____		<table border="1" style="width:100%; text-align: center;"> <tr> <th> </th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> <tr> <td>PS: Patient Station</td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td>Other</td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </table>			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																																
DS Duty Station																																																	
MCS Full feature master control station																																																	
EPCA Emergency Pull Cord station with Audio																																																	
Other: _____																																																	
	quantity	feature 1	feature 2	feature 3	feature 4																																												
PS: Patient Station																																																	
2/3B: 2/3 button station																																																	
4B: 4 button station (single gang)																																																	
VST: VoIP Staff Terminal/Station																																																	
Other																																																	
IMIT Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>																																																	

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input checked="" type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%;"><tr><td> </td></tr></table> Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>			

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	
--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB - Lead Lined</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Lead Lined</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Seamless Epoxy</td><td>Anti-static</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Seamless Epoxy</td><td></td></tr></table>		GWB - Lead Lined	Washable	GWB - Lead Lined	Washable	Seamless Epoxy	Anti-static	Seamless Epoxy		DOORS: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>F</td> <td>1</td> <td>1830 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>OR-10</td> </tr> <tr> <td>B</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>OR-01</td> </tr> </tbody> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	F	1	1830 x 2135	Solid Core	Plam	OR-10	B	1	1220 x 2135	Solid Core	Plam	OR-01								
GWB - Lead Lined	Washable																																				
GWB - Lead Lined	Washable																																				
Seamless Epoxy	Anti-static																																				
Seamless Epoxy																																					
type	quantity	size	material	finish	Hardware Group																																
F	1	1830 x 2135	Solid Core	Plam	OR-10																																
B	1	1220 x 2135	Solid Core	Plam	OR-01																																
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input checked="" type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																																			
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																																			
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws		MILLWORK: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Stainless Steel</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Stainless Steel</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> <td></td> </tr> </tbody> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>3600</td><td>finish</td><td>Stainless Steel</td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td></td><td>finish</td><td></td></tr></table> Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> <table border="1" style="width:100%;"><tr><td>finish</td><td></td></tr></table> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Stainless Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Stainless Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>			min. length (mm)	3600	finish	Stainless Steel	min. length (mm)		finish		finish	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																														
Upper Cabinets	<input checked="" type="checkbox"/> Stainless Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																														
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Stainless Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																																
min. length (mm)	3600	finish	Stainless Steel																																		
min. length (mm)		finish																																			
finish																																					

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	located as directed by authority
	Normal 2	Duplex	2	located as directed by authority
	Conditional 1	Duplex	3	Locate 1 per workstation
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	located as directed by authority
UPS	30A, 208Volt Laser Outlet		1	Locate adjacent to Anastasia boom. Foot of the bed
Anesthesia	Normal			
	Conditional			
	Delayed Vital	20A, 208Volt twist lock	1	
	Vital	Duplex	6	
UPS	30A, 208Volt Laser Outlet		1	provide UPS power circuits for 4 of 6 vital duplex receptacles
Equipment	Normal			
	Conditional			
	Delayed Vital	20A, 208Volt twist lock	1	
	Vital	Duplex	6	provide 2 UPS duplex/outlets for 2 of 6 vital receptacles
UPS	30A, 208Volt Laser Outlet		1	provide UPS power circuits for 2 of 6 vital duplex receptacles
Auxiliary	Normal			
	Conditional			
	Delayed Vital	20A, 208Volt twist lock	1	
	Vital	Duplex	6	
UPS	30A, 208Volt Laser Outlet		1	provide UPS power circuits for 4 of 6 vital duplex receptacles

Patient Care Area
 Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks
 Provide 6 zone lighting controller. Interlock laser outlet with doors to OR. Laser to shut-off when door opens. Provide digital clocks in OR's.

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>I</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"></table>		I	PLUMBING: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>		quantity	mounting type	faucet type	control type	plumbing remarks																																																																																				
I																																																																																													
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																									
MEDICAL GASES: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Anesthesia</th> <th>Equipment</th> <th>Auxiliary</th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td>2</td><td>1</td><td>2</td><td>1</td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td>2</td><td>1</td><td>2</td><td>1</td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td>3</td><td>3</td><td>2</td><td>1</td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td>1</td><td></td><td>1</td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td>1</td><td>1</td><td>1</td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td>1</td><td>1</td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td>1</td><td></td><td>1</td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td>1</td><td>1</td><td>1</td><td></td></tr> </tbody> </table> Medical Gas Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>		(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side	Anesthesia	Equipment	Auxiliary	Oxygen					2	1	2	1	Medical Air					2	1	2	1	Medical Vacuum					3	3	2	1	Nitrous Oxide					1		1		Nitrogen						1	1	1	CO2						1	1		Scavenging					1		1		Laser Smoke Evac.					1	1	1			ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input checked="" type="checkbox"/> Room Relative Humidity with Local Readout <input checked="" type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>		
(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other																																																																																					
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side	Anesthesia	Equipment	Auxiliary																																																																																						
Oxygen					2	1	2	1																																																																																					
Medical Air					2	1	2	1																																																																																					
Medical Vacuum					3	3	2	1																																																																																					
Nitrous Oxide					1		1																																																																																						
Nitrogen						1	1	1																																																																																					
CO2						1	1																																																																																						
Scavenging					1		1																																																																																						
Laser Smoke Evac.					1	1	1																																																																																						

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr><td>Telecommunication Outlets 2A/1I</td><td>8</td></tr> <tr><td>Television Outlets 1A/1C/1NC</td><td></td></tr> <tr><td>Patient Monitoring Outlets 2A Red Data Port</td><td>6</td></tr> <tr><td>Headwall Outlets 2PM/3A (per headwall)</td><td>0</td></tr> </tbody> </table>			quantity	Telecommunication Outlets 2A/1I	8	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port	6	Headwall Outlets 2PM/3A (per headwall)	0	Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet																																					
	quantity																																																
Telecommunication Outlets 2A/1I	8																																																
Television Outlets 1A/1C/1NC																																																	
Patient Monitoring Outlets 2A Red Data Port	6																																																
Headwall Outlets 2PM/3A (per headwall)	0																																																
NURSE CALL: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr><td>DS Duty Station</td><td></td></tr> <tr><td>MCS Full feature master control station</td><td></td></tr> <tr><td>EPCA Emergency Pull Cord station with Audio</td><td></td></tr> <tr><td>Other: _____</td><td></td></tr> </tbody> </table>			quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other: _____		<table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr><td>PS: Patient Station</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>2/3B: 2/3 button station</td><td>2</td><td>Code Blue</td><td>Code White</td><td></td><td></td></tr> <tr><td>4B: 4 button station (single gang)</td><td>1</td><td>Code Blue</td><td>Code White</td><td>Code Pink</td><td></td></tr> <tr><td>VST: VoIP Staff Terminal/Station</td><td>1</td><td>Code Blue</td><td>Code White</td><td>Code Pink</td><td>Staff Assist</td></tr> <tr><td>Other</td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station	2	Code Blue	Code White			4B: 4 button station (single gang)	1	Code Blue	Code White	Code Pink		VST: VoIP Staff Terminal/Station	1	Code Blue	Code White	Code Pink	Staff Assist	Other					
	quantity																																																
DS Duty Station																																																	
MCS Full feature master control station																																																	
EPCA Emergency Pull Cord station with Audio																																																	
Other: _____																																																	
	quantity	feature 1	feature 2	feature 3	feature 4																																												
PS: Patient Station																																																	
2/3B: 2/3 button station	2	Code Blue	Code White																																														
4B: 4 button station (single gang)	1	Code Blue	Code White	Code Pink																																													
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White	Code Pink	Staff Assist																																												
Other																																																	
IMIT Remarks: <table border="1" style="width:100%;"><tr><td>VST at door to sterile core. 4B button near nursing desk & 2B button on Anastasia & Auxiliary booms. 2 data and 2 PM outlets on ALL booms. ceiling mounted speakers, 27mm conduit and backboxes for wall mounted docking station.</td></tr></table>				VST at door to sterile core. 4B button near nursing desk & 2B button on Anastasia & Auxiliary booms. 2 data and 2 PM outlets on ALL booms. ceiling mounted speakers, 27mm conduit and backboxes for wall mounted docking station.																																													
VST at door to sterile core. 4B button near nursing desk & 2B button on Anastasia & Auxiliary booms. 2 data and 2 PM outlets on ALL booms. ceiling mounted speakers, 27mm conduit and backboxes for wall mounted docking station.																																																	

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input checked="" type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%;"><tr><td> </td></tr></table> Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>			

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input checked="" type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input checked="" type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	
--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB - Moisture and Mould Resistant	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>		type	quantity	size	material	finish	Hardware Group																																										
GWB - Moisture and Mould Resistant	Washable																																																										
GWB - Moisture and Mould Resistant	Washable																																																										
Resilient	Non-Skid																																																										
Flash Cove																																																											
type	quantity	size	material	finish	Hardware Group																																																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																																																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input checked="" type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3																																																									
ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																																									
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th> </th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>																																												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																																																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																																																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																																																					
Countertop: min. length (mm) <input type="text" value="0"/> finish <input type="text"/> Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish <input type="text"/> Washroom Vanity: <input type="text"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																																																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	1	GFI
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Lighting Legend: <input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input checked="" type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks Surgical scrub sink lighting				

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="II"/> Remarks: <input style="width:100%;" type="text"/>		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Other</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>				quantity	mounting type	faucet type	control type	plumbing remarks	Other	1	Wall Hung	Gooseneck	Electronic Control										
quantity	mounting type	faucet type	control type	plumbing remarks																					
Other	1	Wall Hung	Gooseneck	Electronic Control																					
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Surgical scrub sink		Verify bowl number with Users																							
MEDICAL GASES: (Quantity)		Headwall 1 Nursing Side Non-Nursing Side		Headwall 2 Nursing Side Non-Nursing Side		Overhead Booms		Other																	
Oxygen																									
Medical Air																									
Medical Vacuum																									
Nitrous Oxide																									
Nitrogen																									
CO2																									
Scavenging																									
Laser Smoke Evac.																									
Medical Gas Remarks: <input style="width:100%;" type="text"/>																									

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; text-align: center;"> <tr> <th> </th> <th>quantity</th> </tr> <tr> <td>Telecommunication Outlets 2A/1I</td> <td></td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </table>			quantity	Telecommunication Outlets 2A/1I		Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet		<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input checked="" type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																																					
	quantity																																																		
Telecommunication Outlets 2A/1I																																																			
Television Outlets 1A/1C/1NC																																																			
Patient Monitoring Outlets 2A Red Data Port																																																			
Headwall Outlets 2PM/3A (per headwall)																																																			
NURSE CALL: <table border="1" style="width:100%; text-align: center;"> <tr> <th> </th> <th>quantity</th> </tr> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other: _____</td> <td></td> </tr> </table>			quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other: _____		<table border="1" style="width:100%; text-align: center;"> <tr> <th> </th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>					quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																																		
DS Duty Station																																																			
MCS Full feature master control station																																																			
EPCA Emergency Pull Cord station with Audio																																																			
Other: _____																																																			
	quantity	feature 1	feature 2	feature 3	feature 4																																														
PS: Patient Station																																																			
2/3B: 2/3 button station																																																			
4B: 4 button station (single gang)																																																			
VST: VoIP Staff Terminal/Station																																																			
Other																																																			
ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control		IMIT Remarks: <input style="width:100%;" type="text"/>																																																	

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="text"/>		Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <input style="width:100%;" type="text"/>	
--	--	--	--

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System			
--	--	--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>2</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	2	1065 x 2135	Solid Core	Plam	CR-01												
type	quantity	size	material	finish	Hardware Group																						
B	2	1065 x 2135	Solid Core	Plam	CR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input checked="" type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input checked="" type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>										
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 1500 finish Solid Surfacing Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	1	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: II Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																						
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input checked="" type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	1																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:
VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB	Paint
Wall	GWB	Paint
Floor	Resilient	Slip Resistant
Base:	Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	CR-01
A	1	914 x 2135	Solid Core	Plam	CR-01

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: II Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	1	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend; Intercom Station Video Intercom Station
A – Active/Allocated Data Port or Data Jack Overhead Paging (Pub Address)
I – Inactive/Unallocated Data Port or Data Jack Teleconferencing
C – Coax NC – Nurse Call
PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: <input type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB - Lead Lined	Washable
Wall	GWB - Lead Lined	Washable
Floor	Seamless Epoxy	Anti-static
Base:	Seamless Epoxy	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
F	1	1830 x 2135	Solid Core	Plam	OR-10
B	1	1220 x 2135	Solid Core	Plam	OR-01

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input checked="" type="checkbox"/> Stainless Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Stainless Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		

Countertop: min. length (mm) 3600 finish Stainless Steel Custom: Reception, Transaction Counter, or Care Team Station Desk: finish Solid Surfacing

Washroom Vanity: Patient Wardrobe: Mail Slots:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	located as directed by authority
	Normal 2	Duplex	2	located as directed by authority
	Conditional 1	Duplex	3	Locate 1 per workstation
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	located as directed by authority
UPS	30A, 208Volt Laser Outlet		1	Locate adjacent to Anastasia boom. Foot of the bed
Anesthesia	Normal			
	Conditional			
	Delayed Vital	20A, 208Volt twist lock	1	
	Vital	Duplex	6	
UPS	30A, 208Volt Laser Outlet		1	provide UPS power circuits for 4 of 6 vital duplex receptacles
Equipment	Normal			
	Conditional			
	Delayed Vital	20A, 208Volt twist lock	1	
	Vital	Duplex	6	provide 2 UPS duplex/outlets for 2 of 6 vital receptacles
UPS	30A, 208Volt Laser Outlet		1	provide UPS power circuits for 2 of 6 vital duplex receptacles
Auxiliary	Normal			
	Conditional			
	Delayed Vital	20A, 208Volt twist lock	1	
	Vital	Duplex	6	
UPS	30A, 208Volt Laser Outlet		1	provide UPS power circuits for 4 of 6 vital duplex receptacles

Lighting Requirements:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks: Provide 6 zone lighting controller. Interlock laser outlet with doors to OR. Laser to shut-off when door opens. Provide digital clocks in OR's.

MECHANICAL REQUIREMENTS

HVAC: Type: I

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
				Flushing rim

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side	Anesthesia	Equipment	Auxiliary	
Oxygen					2	1	2	1
Medical Air					2	1	2	1
Medical Vacuum					3	3	2	1
Nitrous Oxide					1		1	
Nitrogen						1	1	1
CO2						1	1	
Scavenging					1		1	
Laser Smoke Evac.					1	1	1	

Medical Gas Remarks: Mobile smoke evacuation with internal filtration

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	8
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	6
Headwall Outlets 2PM/3A (per headwall)	0

Legend; Intercom Station Video Intercom Station
 Overhead Paging (Pub Address) Teleconferencing
A - Active/Allocated Data Port or Data Jack
I - Inactive/Unallocated Data Port or Data Jack
C - Coax
NC - Nurse Call
PM - Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	2	Code Blue	Code White		
4B: 4 button station (single gang)	1	Code Blue	Code White	Code Pink	
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White	Code Pink	Staff Assist
Other					

IMIT Remarks: VST at door to sterile core. 4B button near nursing desk & 2B button on Anastasia & Auxiliary booms. 2 data and 2 PM outlets on ALL booms. ceiling mounted speakers, 27mm conduit and backboxes for wall mounted docking station.

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: material: <input type="checkbox"/> Washable Wall: material: <input type="checkbox"/> Washable Floor: material: <input type="checkbox"/> Non-Skid Base: material: <input type="checkbox"/> Flash Cove	DOORS: type: <input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input type="checkbox"/> G <input type="checkbox"/> H quantity: <input type="checkbox"/> size: <input type="checkbox"/> material: <input type="checkbox"/> finish: <input type="checkbox"/> Hardware Group: <input type="checkbox"/> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input checked="" type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws
MILLWORK: Upper Cabinets: <input type="checkbox"/> finish: <input type="checkbox"/> doors: <input type="checkbox"/> combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/> finish: <input type="checkbox"/> doors: <input type="checkbox"/> combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/> Countertop: min. length (mm): 0 finish: <input type="checkbox"/> Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish: <input type="checkbox"/> Washroom Vanity: <input type="checkbox"/> finish: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/> finish: <input type="checkbox"/> Options: <input type="checkbox"/> Standing Height Counter						

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="checkbox"/> II Remarks: <input type="checkbox"/>	PLUMBING: quantity: <input type="checkbox"/> 1 mounting type: <input type="checkbox"/> Wall Hung faucet type: <input type="checkbox"/> Gooseneck control type: <input type="checkbox"/> Electronic Control plumbing remarks: <input type="checkbox"/> Verify bowl number with Users Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Surgical scrub sink
---	---

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <input type="checkbox"/> BMS Monitor and Control

VENTILATION: Relative Pressure: <input type="checkbox"/> Equal <input checked="" type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="checkbox"/> Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <input type="checkbox"/>
--

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	1	GFI
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

Surgical scrub sink lighting

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

- Intercom Station
- Video Intercom Station
- Overhead Paging (Pub Address)
- Teleconferencing

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: <input type="checkbox"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

- SECURITY SYSTEM:**
- Security Camera
 - Clinical Camera Monitor
 - Panic Duress - Wired
 - Security Camera Monitor
 - Clinical Camera
 - Infant Abduction System
 - Patient Wandering System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets <input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers <input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: II

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	2	for bed and/or IV Pump
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off

Headwall

Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	0
Television Outlets 1A/1C/1NC	0
Patient Monitoring Outlets 2A Red Data Port	0
Headwall Outlets 2PM/3A (per headwall)	0

Legend;

A – Active/Allocated Data Port or Data Jack Intercom Station

I – Inactive/Unallocated Data Port or Data Jack Video Intercom Station

C – Coax Overhead Paging (Pub Address)

NC – Nurse Call Teleconferencing

PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System

Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	CR-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	1065 x 2135	Solid Core	Plam	CR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>										
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 1500 finish Solid Surfacing Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	1	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Vital	Duplex		1
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting Requirements:
 Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks:

MECHANICAL REQUIREMENTS

HVAC: Type: II Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																						
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	1																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:
VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input checked="" type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>G</td> <td>1</td> <td>914 x 2135</td> <td>Aluminum</td> <td>Prefinished</td> <td>SL-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	G	1	914 x 2135	Aluminum	Prefinished	SL-01												
type	quantity	size	material	finish	Hardware Group																						
G	1	914 x 2135	Aluminum	Prefinished	SL-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 1500 finish Plastic Laminate Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/> finish																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																												
quantity	mounting type	faucet type	control type	plumbing remarks																																																																														
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																																																																																		
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="2">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			Oxygen								Medical Air								Medical Vacuum								Nitrous Oxide								Nitrogen								CO2								Scavenging								Laser Smoke Evac.							
(Quantity)	Headwall 1		Headwall 2			Overhead Booms		Other																																																																										
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																														
Oxygen																																																																																		
Medical Air																																																																																		
Medical Vacuum																																																																																		
Nitrous Oxide																																																																																		
Nitrogen																																																																																		
CO2																																																																																		
Scavenging																																																																																		
Laser Smoke Evac.																																																																																		
Medical Gas Remarks:																																																																																		

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	1																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>KP-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	914 x 2135	Solid Core	Plam	KP-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	914 x 2135	Solid Core	Plam	KP-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input checked="" type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>																						
Countertop: min. length (mm) 2400 finish Plastic Laminate Washroom Vanity: _____ Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> _____ finish Patient Wardrobe: <input type="checkbox"/> _____ Mail Slots: <input type="checkbox"/> _____																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Vital	Duplex		1
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks: _____	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control	
quantity	mounting type	faucet type	control type	plumbing remarks							
1	Wall Hung	Gooseneck	Electronic Control								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/> _____											

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								1
Medical Air								1
Medical Vacuum								1
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								1
Laser Smoke Evac.								2

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: _____

VENTILATION: Relative Pressure Equal Positive Negative Other: _____
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks: _____

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

DOORS:

type	quantity	size	material	finish	Hardware Group

Access Control Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Countertop: min. length (mm) 1800 finish Solid Surfacing
 Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: finish
 Patient Wardrobe:
 Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: II

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																											WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	
type	quantity	size	material	finish	Hardware Group																																																
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																																																	
MILLWORK: Upper Cabinets: <input checked="" type="checkbox"/> finish: doors: <input type="checkbox"/> combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/>		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws		Options: <input checked="" type="checkbox"/> Standing Height Counter <input type="checkbox"/> Reception, Transaction Counter, or Care Team Station Desk <input type="checkbox"/> Patient Wardrobe <input type="checkbox"/> Mail Slots																																																	
Countertop: min. length (mm) 4500 finish: Plastic Laminate Washroom Vanity:		Custom:		finish:																																																	

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																					
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																							

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control
--

VENTILATION: Relative Pressure: <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:
--

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	
Telecommunication Outlets 2A/1I	3	
Television Outlets 1A/1C/1NC		
Patient Monitoring Outlets 2A Red Data Port		
Headwall Outlets 2PM/3A (per headwall)		

Legend;

- A – Active/Allocated Data Port or Data Jack
- I – Inactive/Unallocated Data Port or Data Jack
- C – Coax
- NC – Nurse Call
- PM- Patient Monitoring Outlet

- Intercom Station
- Video Intercom Station
- Overhead Paging (Pub Address)
- Teleconferencing


NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB - Impact Resistant Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: type quantity size material finish Hardware Group  Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight, <input type="checkbox"/> Integral Blinds, <input type="checkbox"/> Security Grille, <input type="checkbox"/> Laser Ready Integral Blinds	
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input checked="" type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws		MILLWORK: Upper Cabinets <input type="checkbox"/> finish doors <input type="checkbox"/> combination doors & open <input type="checkbox"/> lockable <input type="checkbox"/> adjustable shelves <input type="checkbox"/> microwave shelf <input type="checkbox"/> Lower Cabinets/Drawers <input type="checkbox"/> finish doors <input type="checkbox"/> combination doors & open <input type="checkbox"/> lockable <input type="checkbox"/> adjustable shelves <input type="checkbox"/> microwave shelf <input type="checkbox"/> Options: <input type="checkbox"/> Standing Height Counter Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>	

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Vital	Duplex		1
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																		
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																				
MEDICAL GASES: (Quantity)		Headwall 1 Nursing Side Non-Nursing Side		Headwall 2 Nursing Side Non-Nursing Side		Overhead Booms		Other												
Oxygen																				
Medical Air																				
Medical Vacuum																				
Nitrous Oxide																				
Nitrogen																				
CO2																				
Scavenging																				
Laser Smoke Evac.																				

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;	
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack	<input type="checkbox"/> Intercom Station
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack	<input type="checkbox"/> Video Intercom Station
Patient Monitoring Outlets 2A Red Data Port		C – Coax	<input type="checkbox"/> Overhead Paging (Pub Address)
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call	<input type="checkbox"/> Teleconferencing
		PM- Patient Monitoring Outlet	

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

DOORS:

type	quantity	size	material	finish	Hardware Group

Access Control Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Lighting:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	0
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																		
type	quantity	size	material	finish	Hardware Group																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain- Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																						
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th> </th> <th> </th> <th> </th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr><td>Telecommunication Outlets 2A/1I</td><td>0</td></tr> <tr><td>Television Outlets 1A/1C/1NC</td><td></td></tr> <tr><td>Patient Monitoring Outlets 2A Red Data Port</td><td></td></tr> <tr><td>Headwall Outlets 2PM/3A (per headwall)</td><td></td></tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	0	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	0																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr><td>DS Duty Station</td><td></td></tr> <tr><td>MCS Full feature master control station</td><td></td></tr> <tr><td>EPCA Emergency Pull Cord station with Audio</td><td></td></tr> <tr><td>Other: _____</td><td></td></tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other: _____																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other: _____																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr><td>PS: Patient Station</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>2/3B: 2/3 button station</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>4B: 4 button station (single gang)</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>VST: VoIP Staff Terminal/Station</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Other</td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:
VENTILATION: Relative Pressure: <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: _____ Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB - Impact Resistant Washable Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																																	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	
type	quantity	size	material	finish	Hardware Group																																																						
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																																					
MILLWORK: Upper Cabinets: <input type="checkbox"/> finish: doors: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/> finish: doors: <input type="checkbox"/> Combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/> Options: <input type="checkbox"/> Standing Height Counter		Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>		DOOR HARDWARE: <input type="checkbox"/> Access Control OTHER FEATURES: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																																																							

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2	Quad	6	provide recep. on 1 m centers mounted at 1400mm AFF
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																					
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																							
MEDICAL GASES: (Quantity)		Headwall 1		Headwall 2		Overhead Booms		Other															
		Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																		
Oxygen																							
Medical Air																							
Medical Vacuum																							
Nitrous Oxide																							
Nitrogen																							
CO2																							
Scavenging																							
Laser Smoke Evac.																							
Medical Gas Remarks:																							

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>			quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet		<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																																					
	quantity																																																		
Telecommunication Outlets 2A/1I	1																																																		
Television Outlets 1A/1C/1NC																																																			
Patient Monitoring Outlets 2A Red Data Port																																																			
Headwall Outlets 2PM/3A (per headwall)																																																			
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td>1</td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>			quantity	DS Duty Station	1	MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:		<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td><td></td><td></td><td></td><td></td></tr> <tr> <td>2/3B: 2/3 button station</td> <td></td><td></td><td></td><td></td><td></td></tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td><td></td><td></td><td></td><td></td></tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td><td></td><td></td><td></td><td></td></tr> <tr> <td>Other</td> <td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																																		
DS Duty Station	1																																																		
MCS Full feature master control station																																																			
EPCA Emergency Pull Cord station with Audio																																																			
Other:																																																			
	quantity	feature 1	feature 2	feature 3	feature 4																																														
PS: Patient Station																																																			
2/3B: 2/3 button station																																																			
4B: 4 button station (single gang)																																																			
VST: VoIP Staff Terminal/Station																																																			
Other																																																			
IMIT Remarks:																																																			

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control	
VENTILATION: Relative Pressure: <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:	

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System			
--	--	--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB - Moisture and Mould Resistant	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
C	3	1065 x 2135	Solid Core	Plam	PP-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets: <input checked="" type="checkbox"/> Stainless Steel	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers: <input checked="" type="checkbox"/> Stainless Steel	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		

Countertop: min. length (mm) 3000 finish Solid Surfacing

Washroom Vanity: _____

Reception, Transaction Counter, or Care Team Station Desk: _____ finish _____

Patient Wardrobe: _____

Mail Slots: _____

MECHANICAL REQUIREMENTS

HVAC: Type: I

Remarks: _____

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: _____

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: _____

VENTILATION: Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Quad		6	Locate outlets at 1400mm AFF. As directed by the authority
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off

Headwall

Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

Provide 6 zone lighting controller.

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	2
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack

I – Inactive/Unallocated Data Port or Data Jack

C – Coax

NC – Nurse Call

PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	2
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station	2				
Other					

IMIT Remarks: Locate duty stations at entrances.

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																		
type	quantity	size	material	finish	Hardware Group																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								

MILLWORK:		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Countertop:	min. length (mm)	finish	Custom:		finish			
915		Plastic Laminate	Reception, Transaction Counter, or Care Team Station Desk:		<input type="checkbox"/>			
Washroom Vanity:			Patient Wardrobe:		<input type="checkbox"/>			
			Mail Slots:		<input type="checkbox"/>			

MECHANICAL REQUIREMENTS

HVAC: Type: II Remarks:	PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																		
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																			

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
	Vital	Duplex	1	pneumatic tube
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: <input type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PA-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	914 x 2135	Solid Core	Plam	PA-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	914 x 2135	Solid Core	Plam	PA-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		DOOR HARDWARE: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>																						
Countertop: min. length (mm) 1500 finish Solid Surfacing Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

MECHANICAL REQUIREMENTS

HVAC: Type: II Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: _____

VENTILATION: Relative Pressure: Equal Positive Negative Other: _____
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station	1				
Other					

IMIT Remarks: _____

- SECURITY SYSTEM:**
- Security Camera
 - Clinical Camera Monitor
 - Panic Duress - Wired
 - Security Camera Monitor
 - Clinical Camera
 - Infant Abduction System
 - Patient Wandering System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>G</td> <td>1</td> <td>1220 x 2135</td> <td>Aluminum</td> <td>Prefinished</td> <td>AO-01</td> </tr> </tbody> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	G	1	1220 x 2135	Aluminum	Prefinished	AO-01								
GWB	Washable																														
GWB - Moisture and Mould Resistant	Washable																														
Resilient	Slip Resistant																														
Flash Cove																															
type	quantity	size	material	finish	Hardware Group																										
G	1	1220 x 2135	Aluminum	Prefinished	AO-01																										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																													
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input checked="" type="checkbox"/> Ceiling IV Track																													
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td></td> <td></td> </tr> </tbody> </table> Countertop: <table border="1" style="width:100%;"><tr><td>2400</td><td>Solid Surfacing</td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td></td><td></td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			2400	Solid Surfacing			HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																								
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																								
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>																										
2400	Solid Surfacing																														

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>II</td></tr></table> Remarks: <div style="border: 1px solid black; height: 40px; width: 100%;"></div>	II	PLUMBING: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> </tbody> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control	
II												
quantity	mounting type	faucet type	control type	plumbing remarks								
1	Wall Hung	Gooseneck	Electronic Control									

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input checked="" type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%;"><tr><td></td></tr></table> Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <div style="border: 1px solid black; width: 100%; height: 20px;"></div>	

NURSE CALL:	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White	Staff Assist	
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

locate 2/3B button at door

SECURITY SYSTEM: <input checked="" type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB	Washable
Wall	GWB - Moisture and Mould Resistant	Washable
Floor	Resilient	Non-Skid
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	WR-03

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT: Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds Roller Shade - Mesh
 Laser Ready Integral Blinds Vertical Blinds
 One Way Mirror Anti-Ligature

MENTAL HEALTH GLASS TYPES: EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES: Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature Ceiling IV Track

HARM PREVENTION: Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
1	Wall Hung	Gooseneck	Electronic Control	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES: (Quantity)

	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

- LIGHTING:**
- Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend; Intercom Station Video Intercom Station
A – Active/Allocated Data Port or Data Jack Overhead Paging (Pub Address)
I – Inactive/Unallocated Data Port or Data Jack Teleconferencing
C – Coax NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	CR-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	1065 x 2135	Solid Core	Plam	CR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 7500 finish Solid Surfacing Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	2	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		2	charging stations
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks
 provide master zone lighting controller. Provide specialty lighting - LED under cabinet & cove lighting

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	2
Headwall Outlets 2PM/3A (per headwall)	

Legend;
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control	
quantity	mounting type	faucet type	control type	plumbing remarks							
1	Wall Hung	Gooseneck	Electronic Control								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:											

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:


NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	1
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist	Code Pink
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: locate Patient monitoring outlets in bulkhead

SECURITY SYSTEM: <input checked="" type="checkbox"/> Security Camera <input checked="" type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Infant Abduction System <input checked="" type="checkbox"/> Patient Wandering System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Rubber		DOORS: type quantity size material finish Hardware Group  Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight, <input type="checkbox"/> Integral Blinds, <input type="checkbox"/> Security Grille, <input type="checkbox"/> Laser Ready Integral Blinds																									
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																									
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																									
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws		MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: min. length (mm) 915 finish Plastic Laminate Washroom Vanity: _____ Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish _____ Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																					

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Vital	Duplex		1
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </table>															
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																	
MEDICAL GASES: (Quantity)		Headwall 1		Headwall 2		Overhead Booms		Other									
		Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side												
Oxygen																	
Medical Air																	
Medical Vacuum																	
Nitrous Oxide																	
Nitrogen																	
CO2																	
Scavenging																	
Laser Smoke Evac.																	

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: _____

VENTILATION: Relative Pressure Equal Positive Negative Other: _____
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks: _____

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: provide nurse call connection to pneumatic tube

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>OF-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	OF-01												
type	quantity	size	material	finish	Hardware Group																						
A	1	914 x 2135	Solid Core	Plam	OF-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																						
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	1																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:
VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	OF-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
B	1	914 x 2135	Solid Core	Plam	PA-01

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

Upper Cabinets	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Countertop: min. length (mm) 3000 finish Plastic Laminate Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2	Duplex	1	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		2	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

- LIGHTING:**
- Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	2
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend; Intercom Station Video Intercom Station
A – Active/Allocated Data Port or Data Jack Overhead Paging (Pub Address)
I – Inactive/Unallocated Data Port or Data Jack Teleconferencing
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>G</td> <td>1</td> <td>914 x 2135</td> <td>Aluminum</td> <td>Prefinished</td> <td>SL-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	G	1	914 x 2135	Aluminum	Prefinished	SL-01												
type	quantity	size	material	finish	Hardware Group																						
G	1	914 x 2135	Aluminum	Prefinished	SL-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 1500 finish Plastic Laminate Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/> finish																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;	
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack	<input type="checkbox"/> Intercom Station
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack	<input type="checkbox"/> Video Intercom Station
Patient Monitoring Outlets 2A Red Data Port		C – Coax	<input type="checkbox"/> Overhead Paging (Pub Address)
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call	<input type="checkbox"/> Teleconferencing
		PM- Patient Monitoring Outlet	

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets: Plastic Laminate <input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers: <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </table>		type	quantity	size	material	finish	Hardware Group																		
type	quantity	size	material	finish	Hardware Group																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input checked="" type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input checked="" type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th> </th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex headwall & 1 duplex bed
UPS	Duplex		3	2 duplex headwall & 1 duplex above bed right side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting Requirements:
 Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks
 1 hand hygiene sink light per 3 bays. Provide separate stretcher bay lighting controlled from care station. Separately switched down light located between bays.

MECHANICAL REQUIREMENTS

HVAC: Type: I Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control																																																																				
quantity	mounting type	faucet type	control type	plumbing remarks																																																																											
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control																																																																											
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																																																																															
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="2">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th> </th> <th> </th> </tr> <tr> <td>Oxygen</td> <td>2</td> <td>2</td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td>Medical Air</td> <td>1</td> <td>1</td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td>Medical Vacuum</td> <td>3</td> <td>3</td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td>Nitrous Oxide</td> <td> </td> </tr> <tr> <td>Nitrogen</td> <td> </td> </tr> <tr> <td>CO2</td> <td> </td> </tr> <tr> <td>Scavenging</td> <td> </td> </tr> <tr> <td>Laser Smoke Evac.</td> <td> </td> </tr> </table>		(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			Oxygen	2	2						Medical Air	1	1						Medical Vacuum	3	3						Nitrous Oxide								Nitrogen								CO2								Scavenging								Laser Smoke Evac.							
(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other																																																																								
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																											
Oxygen	2	2																																																																													
Medical Air	1	1																																																																													
Medical Vacuum	3	3																																																																													
Nitrous Oxide																																																																															
Nitrogen																																																																															
CO2																																																																															
Scavenging																																																																															
Laser Smoke Evac.																																																																															
Medical Gas Remarks:																																																																															

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC	0	I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port	1	C – Coax
Headwall Outlets 2PM/3A (per headwall)	1	NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Code White	Patient Assist	
2/3B: 2/3 button station					
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist	Room Ready
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: Provide room ready option. Nurse call dome light to annunciate green when room ready function is activated

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:
VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input checked="" type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input checked="" type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB - Moisture and Mould Resistant Washable Floor: Resilient Non-Skid Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																											WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	
type	quantity	size	material	finish	Hardware Group																																																
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																															

MILLWORK:		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input checked="" type="checkbox"/>	Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input checked="" type="checkbox"/>	Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Countertop: min. length (mm) 1800 finish Solid Surfacing
 Washroom Vanity: min. length (mm) Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
 Patient Wardrobe:
 Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td>Double Bowl</td> <td>1</td> <td>Counter</td> <td>Gooseneck</td> <td>Lever Blade</td> <td></td> </tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>				Double Bowl	1	Counter	Gooseneck	Lever Blade													
Double Bowl	1	Counter	Gooseneck	Lever Blade																			
Other Fixtures: <input type="checkbox"/> Urinal: <input checked="" type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																							

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	GFI
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																		
type	quantity	size	material	finish	Hardware Group																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input checked="" type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																						
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th> </th> <th> </th> <th> </th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr><td>Telecommunication Outlets 2A/1I</td><td></td></tr> <tr><td>Television Outlets 1A/1C/1NC</td><td></td></tr> <tr><td>Patient Monitoring Outlets 2A Red Data Port</td><td></td></tr> <tr><td>Headwall Outlets 2PM/3A (per headwall)</td><td></td></tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I		Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I																																						
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr><td>DS Duty Station</td><td></td></tr> <tr><td>MCS Full feature master control station</td><td></td></tr> <tr><td>EPCA Emergency Pull Cord station with Audio</td><td></td></tr> <tr><td>Other: _____</td><td></td></tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other: _____																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other: _____																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr><td>PS: Patient Station</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>2/3B: 2/3 button station</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>4B: 4 button station (single gang)</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>VST: VoIP Staff Terminal/Station</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Other</td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control
VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: _____ Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Infant Abduction System <input checked="" type="checkbox"/> Patient Wandering System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	Acoustic Tile	Washable
Wall	GWB - Impact Resistant	Washable
Floor	Resilient	Slip Resistant
Base:	Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
C	1	1220 x 2135	Solid Core	Plam	CR-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2	Quad	18	provide recep. on 1 m centers mounted at 1400mm AFF
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB	Washable
Wall	GWB - Moisture and Mould Resistant	Washable
Floor	Resilient	Slip Resistant
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

DOORS:

type	quantity	size	material	finish	Hardware Group
G	2	1220 x 2135	Aluminum	Prefinished	AO-01

Door Hardware: Access Control

Other Features:

Sidelight
 Integral Blinds
 Security Grille
 Laser Ready Integral Blinds

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		

Countertop: min. length (mm) 3000 finish Solid Surfacing

Washroom Vanity: min. length (mm) finish

Reception, Transaction Counter, or Care Team Station Desk: finish

Patient Wardrobe:

Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: II

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
1	Wall Hung	Gooseneck	Electronic Control	

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White	Staff Assist	
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: locate 2/3B button at door

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>B</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	B	1	1220 x 2135	Solid Core	Plam	CR-01				
GWB	Washable																										
GWB	Washable																										
Resilient	Slip Resistant																										
Flash Cove																											
type	quantity	size	material	finish	Hardware Group																						
B	1	1220 x 2135	Solid Core	Plam	CR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																									
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																									
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: min. length (mm) <input type="text" value="0"/> finish <input type="text"/> Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish <input type="text"/> Washroom Vanity: <input type="text"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks:

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <div style="border: 1px solid black; height: 60px; width: 100%;"></div>		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; text-align: center;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																					
MEDICAL GASES: (Quantity)		Headwall 1		Headwall 2		Overhead Booms		Other															
		Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																		
Oxygen																							
Medical Air																							
Medical Vacuum																							
Nitrous Oxide																							
Nitrogen																							
CO2																							
Scavenging																							
Laser Smoke Evac.																							
Medical Gas Remarks: <div style="border: 1px solid black; height: 20px; width: 100%;"></div>																							

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </table>			quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet																																					
	quantity																																																
Telecommunication Outlets 2A/1I	1																																																
Television Outlets 1A/1C/1NC																																																	
Patient Monitoring Outlets 2A Red Data Port																																																	
Headwall Outlets 2PM/3A (per headwall)																																																	
NURSE CALL: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>DS Duty Station</td> <td>1</td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other: _____</td> <td></td> </tr> </table>			quantity	DS Duty Station	1	MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other: _____		<table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																																
DS Duty Station	1																																																
MCS Full feature master control station																																																	
EPCA Emergency Pull Cord station with Audio																																																	
Other: _____																																																	
	quantity	feature 1	feature 2	feature 3	feature 4																																												
PS: Patient Station																																																	
2/3B: 2/3 button station																																																	
4B: 4 button station (single gang)																																																	
VST: VoIP Staff Terminal/Station																																																	
Other																																																	
IMIT Remarks: <div style="border: 1px solid black; height: 20px; width: 100%;"></div>																																																	

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control	
VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input checked="" type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="text"/> Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System			
--	--	--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
B	1	1220 x 2135	Solid Core	Plam	CL-02

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

Upper Cabinets	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Stainless Steel	<input type="checkbox"/> Standing Height Counter					
<input type="checkbox"/>		<input type="checkbox"/>					

Lower Cabinets/Drawers

Countertop: min. length (mm) 2400, finish Stainless Steel

Washroom Vanity: min. length (mm) _____, finish _____

Reception, Transaction Counter, or Care Team Station Desk: finish _____

Patient Wardrobe: finish _____

Mail Slots: finish _____

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control
Utility	1	Counter	Gooseneck	Lever Blade

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: _____

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout

Room Control Remarks: BMS Monitor and Control

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust

Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB	Washable
Wall	GWB - Moisture and Mould Resistant	Washable
Floor	Resilient	Non-Skid
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	1065 x 2135	Solid Core	Plam	WR-01

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
1	Wall Hung	Gooseneck	Electronic Control	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend; Intercom Station Video Intercom Station
A – Active/Allocated Data Port or Data Jack Overhead Paging (Pub Address)
I – Inactive/Unallocated Data Port or Data Jack Teleconferencing
C – Coax NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	2
Other: Locate 1 EPCA between toilet and sink, 1 adjacent to shower	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Non-Skid
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	WR-03

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Lavatory	1	Wall Hung	Gooseneck	Electronic Control

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	0
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	CR-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	1065 x 2135	Solid Core	Plam	CR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3																									
ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																									
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 3000 finish Solid Surfacing Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	2	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		2	charging stations
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

LIGHTING:
 Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks
 provide master zone lighting controller. Provide specialty lighting - LED under cabinet & cove lighting

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	2
Headwall Outlets 2PM/3A (per headwall)	

Legend;
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </table>				Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control													
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control																			
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																							

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:
NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	1
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist	
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: locate Patient monitoring outlets in bulkhead

SECURITY SYSTEM:
 Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
B	1	914 x 2135	Solid Core	Plam	PA-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

Upper Cabinets	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter

Countertop: min. length (mm) 3000 finish Plastic Laminate

Washroom Vanity: min. length (mm) _____ finish _____

Reception, Transaction Counter, or Care Team Station Desk: _____ finish _____

Patient Wardrobe: _____ finish _____

Mail Slots: _____ finish _____

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks: _____

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: _____

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2	Duplex	1	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		2	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks: _____

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	2
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	


	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Flash Cove		DOORS: type quantity size material finish Hardware Group  Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight, <input type="checkbox"/> Integral Blinds, <input type="checkbox"/> Security Grille, <input type="checkbox"/> Laser Ready Integral Blinds	
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input checked="" type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input checked="" type="checkbox"/> Ceiling IV Track	
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws		MILLWORK: Upper Cabinets <input type="checkbox"/> finish doors <input type="checkbox"/> combination doors & open <input type="checkbox"/> lockable <input type="checkbox"/> adjustable shelves <input type="checkbox"/> microwave shelf <input type="checkbox"/> Lower Cabinets/Drawers <input type="checkbox"/> finish doors <input type="checkbox"/> combination doors & open <input type="checkbox"/> lockable <input type="checkbox"/> adjustable shelves <input type="checkbox"/> microwave shelf <input type="checkbox"/> Options: <input type="checkbox"/> Standing Height Counter Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>	

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex headwall & 1 duplex bed
	Duplex		3	2 duplex headwall & 1 duplex above bed right side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

LIGHTING:
 Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks
 1 hand hygiene sink light per 3 bays. Provide separate stretcher bay lighting controlled from care station. Separately switched down light located between bays.

MECHANICAL REQUIREMENTS

HVAC: Type: I Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks Hand Hygiene 1 Wall Hung Gooseneck Electronic Control 1 per 3 Bays Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:						
MEDICAL GASES: (Quantity)		Headwall 1		Headwall 2		Overhead Booms		Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen	2	2						
Medical Air	1	1						
Medical Vacuum	3	3						
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet
	quantity	
Telecommunication Outlets 2A/1I	1	
Television Outlets 1A/1C/1NC	0	
Patient Monitoring Outlets 2A Red Data Port	1	
Headwall Outlets 2PM/3A (per headwall)	1	

NURSE CALL:		quantity
DS Duty Station		
MCS Full feature master control station		
EPCA Emergency Pull Cord station with Audio		
Other:		

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Code White	Patient Assist	
2/3B: 2/3 button station					
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist	Room Ready
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: Provide room ready option. Nurse call dome light to annunciate green when room ready function is activated

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: material: <input type="checkbox"/> Washable Wall: material: <input type="checkbox"/> Waterproof Cover. Floor: material: <input type="checkbox"/> Non-Skid Base: material: <input type="checkbox"/> Flash Cove	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>WR-01</td> </tr> </table>	type	quantity	size	material	finish	Hardware Group	A	1	1065 x 2135	Solid Core	Plam	WR-01	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator
type	quantity	size	material	finish	Hardware Group									
A	1	1065 x 2135	Solid Core	Plam	WR-01									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input checked="" type="checkbox"/> Shower Seat <input checked="" type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain- Anti-ligature <input type="checkbox"/> Ceiling IV Track												
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws														

MILLWORK: Upper Cabinets: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/>	finish: _____ doors: <input type="checkbox"/> combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input checked="" type="checkbox"/> microwave shelf: <input type="checkbox"/>	Options: <input type="checkbox"/> Standing Height Counter	Countertop: min. length (mm) _____ finish _____ Washroom Vanity: _____ Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> _____ finish _____ Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/> _____
--	--	--	---

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="checkbox"/> III Remarks: _____	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Lever Blade</td> </tr> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Gooseneck	Lever Blade
quantity	mounting type	faucet type	control type	plumbing remarks							
Lavatory	1	Wall Hung	Gooseneck	Lever Blade							
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Shower											

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input checked="" type="checkbox"/> Room Relative Humidity with Local Readout <input checked="" type="checkbox"/> Room Pressure Monitor with Local Readout	Room Control Remarks: _____
--	-----------------------------

VENTILATION: Relative Pressure: <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: _____ Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Dedicated Exhaust	Remarks: _____
--	----------------

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock	LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input checked="" type="checkbox"/> Night Light <input checked="" type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input checked="" type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks: _____
--	---

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	2
Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB	Washable
Wall	GWB	Washable
Floor	Resilient	Slip Resistant
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
H	1	1830 x 2135	Aluminum	Prefinished	SL-02

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: I Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
1	Wall Hung	Gooseneck	Electronic Control	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			
Oxygen	2	2					
Medical Air	1	1					
Medical Vacuum	3	3					
Nitrous Oxide							
Nitrogen							
CO2							
Scavenging							
Laser Smoke Evac.							

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex at headwall & 1 duplex for bed
UPS	Duplex		3	2 duplex at headwall & 1 duplex above bed non-nursing side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	1
Patient Monitoring Outlets 2A Red Data Port	1
Headwall Outlets 2PM/3A (per headwall)	1

Legend; Intercom Station Video Intercom Station
 Overhead Paging (Pub Address) Teleconferencing
A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Code White	Patient Assist	
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist	
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: Provide room ready option. Nurse call dome light to annunciate green when room ready function is activated. Locate 2/3b at entrance to room

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>G</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Prefinished</td> <td>SL-01</td> </tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight, <input type="checkbox"/> Integral Blinds, <input type="checkbox"/> Security Grille, <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	G	1	1065 x 2135	Solid Core	Prefinished	SL-01																
GWB	Washable																																						
GWB - Moisture and Mould Resistant	Washable																																						
Resilient	Non-Skid																																						
Flash Cove																																							
type	quantity	size	material	finish	Hardware Group																																		
G	1	1065 x 2135	Solid Core	Prefinished	SL-01																																		
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds, <input type="checkbox"/> Roller Shade - Black Out, <input type="checkbox"/> Curtain Fabric, <input type="checkbox"/> Integral Blinds, <input type="checkbox"/> Roller Shade - Mesh, <input type="checkbox"/> Laser Ready Integral Blinds, <input type="checkbox"/> Vertical Blinds, <input type="checkbox"/> One Way Mirror, <input type="checkbox"/> Anti-Ligature MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1, <input type="checkbox"/> EXT-2, <input type="checkbox"/> EXT-3, <input type="checkbox"/> INT-1, <input type="checkbox"/> INT-2, <input type="checkbox"/> INT-3																																					
ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks, <input type="checkbox"/> Coat Hooks - Anti-ligature, <input checked="" type="checkbox"/> Mirror, <input type="checkbox"/> Mirror - Vandal Resistant, <input type="checkbox"/> Privacy Curtain, <input type="checkbox"/> Privacy Curtain - Anti-ligature, <input type="checkbox"/> Shower Seat, <input type="checkbox"/> Shower Curtain, <input type="checkbox"/> Shower Curtain - Anti-ligature, <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler, <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler, <input type="checkbox"/> Tamper proof screws and fittings, <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures, <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover, <input type="checkbox"/> Vandal resistant tamper proof and access panels, <input type="checkbox"/> Security-type ventilating grille, <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles, <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles, <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover, <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																					
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table> Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> <table border="1" style="width:100%;"><tr><td>finish</td></tr><tr><td></td></tr></table> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/> <table border="1" style="width:100%;"><tr><td>finish</td></tr><tr><td></td></tr></table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		min. length (mm)	finish			min. length (mm)	finish			finish		finish												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																																
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																																
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																																	
min. length (mm)	finish																																						
min. length (mm)	finish																																						
finish																																							
finish																																							

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks																									
General Power	Normal 1	Duplex	1	GFI																									
	Normal 2																												
	Conditional 1																												
	Conditional 2																												
	Conditional 3																												
	Delayed Vital																												
Vital																													
UPS																													
Lighting Legend: <input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input checked="" type="checkbox"/> Night Light <input checked="" type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input checked="" type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks: <table border="1" style="width:100%; height: 100px;"><tr><td></td></tr></table>																													
Booms: <table border="1" style="width:100%; text-align: center;"> <tr><td>Normal</td><td></td><td></td><td></td><td></td></tr> <tr><td>Conditional</td><td></td><td></td><td></td><td></td></tr> <tr><td>Delayed Vital</td><td></td><td></td><td></td><td></td></tr> <tr><td>Vital</td><td></td><td></td><td></td><td></td></tr> <tr><td>UPS</td><td></td><td></td><td></td><td></td></tr> </table>					Normal					Conditional					Delayed Vital					Vital					UPS				
Normal																													
Conditional																													
Delayed Vital																													
Vital																													
UPS																													
Booms: <table border="1" style="width:100%; text-align: center;"> <tr><td>Normal</td><td></td><td></td><td></td><td></td></tr> <tr><td>Conditional</td><td></td><td></td><td></td><td></td></tr> <tr><td>Delayed Vital</td><td></td><td></td><td></td><td></td></tr> <tr><td>Vital</td><td></td><td></td><td></td><td></td></tr> <tr><td>UPS</td><td></td><td></td><td></td><td></td></tr> </table>					Normal					Conditional					Delayed Vital					Vital					UPS				
Normal																													
Conditional																													
Delayed Vital																													
Vital																													
UPS																													
Booms: <table border="1" style="width:100%; text-align: center;"> <tr><td>Normal</td><td></td><td></td><td></td><td></td></tr> <tr><td>Conditional</td><td></td><td></td><td></td><td></td></tr> <tr><td>Delayed Vital</td><td></td><td></td><td></td><td></td></tr> <tr><td>Vital</td><td></td><td></td><td></td><td></td></tr> <tr><td>UPS</td><td></td><td></td><td></td><td></td></tr> </table>					Normal					Conditional					Delayed Vital					Vital					UPS				
Normal																													
Conditional																													
Delayed Vital																													
Vital																													
UPS																													

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>III</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td></td></tr></table>		III		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Lever Blade</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input type="checkbox"/>		quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Gooseneck	Lever Blade																																																																													
III																																																																																												
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Lavatory	1	Wall Hung	Gooseneck	Lever Blade																																																																																								
MEDICAL GASES: <table border="1" style="width:100%; text-align: center;"> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </table> Medical Gas Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>				(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.									
(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other																																																																																				
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>Telecommunication Outlets 2A/1I</td> <td></td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </table>			quantity	Telecommunication Outlets 2A/1I		Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend: A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet																																					
	quantity																																																
Telecommunication Outlets 2A/1I																																																	
Television Outlets 1A/1C/1NC																																																	
Patient Monitoring Outlets 2A Red Data Port																																																	
Headwall Outlets 2PM/3A (per headwall)																																																	
NURSE CALL: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> </tr> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td>2</td> </tr> <tr> <td>Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u></td> <td></td> </tr> </table>			quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio	2	Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u>		<table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																																
DS Duty Station																																																	
MCS Full feature master control station																																																	
EPCA Emergency Pull Cord station with Audio	2																																																
Other: <u>Locate 1 EPCA between toilet and sink, 1 adjacent to shower</u>																																																	
	quantity	feature 1	feature 2	feature 3	feature 4																																												
PS: Patient Station																																																	
2/3B: 2/3 button station																																																	
4B: 4 button station (single gang)																																																	
VST: VoIP Staff Terminal/Station																																																	
Other																																																	
IMIT Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>																																																	

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>			
VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%;"><tr><td></td></tr></table> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>			

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	
--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB	Washable
Wall	GWB	Washable
Floor	Resilient	Slip Resistant
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
C	2	1065 x 2135	Solid Core	Plam	PA-01

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	Mobile Equipment
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: I

Remarks:

PLUMBING:

	quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum	0	0						
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White	Code Pink	Staff Assist
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	Acoustic Tile	Washable
Wall	GWB	Washable
Floor	Resilient	Slip Resistant
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
H	1	1830 x 2135	Aluminum	Prefinished	SL-02

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: 1

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
1	Wall Hung	Gooseneck	Electronic Control	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen	2	2						
Medical Air	1	1						
Medical Vacuum	3	3						
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex at headwall & 1 duplex for bed
UPS	Duplex		3	2 duplex at headwall & 1 duplex above bed non-nursing side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

- LIGHTING:**
- Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	1
Patient Monitoring Outlets 2A Red Data Port	1
Headwall Outlets 2PM/3A (per headwall)	1

Legend; Intercom Station Video Intercom Station
A – Active/Allocated Data Port or Data Jack Overhead Paging (Pub Address)
I – Inactive/Unallocated Data Port or Data Jack Teleconferencing
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Code White	Patient Assist	
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist	Code Pink
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: Provide room ready option. Nurse call dome light to annunciate green when room ready function is activated. Locate 2/3b at entrance to room

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
G	1	1220 x 2135	Aluminum	Prefinished	AO-01

Door Hardware: Access Control

Other Features:
 Sidelight
 Integral Blinds
 Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:
 Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:
 EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:
 Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:
 Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets: Plastic Laminate <input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers: <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		

Countertop: min. length (mm) 3000 finish Solid Surfacing

Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: finish

Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene: 1	Wall Hung	Gooseneck	Electronic Control	

Other Fixtures:
 Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;
A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White	Staff Assist	
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: locate 2/3B button at door

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB	Washable
Wall	GWB - Moisture and Mould Resistant	Washable
Floor	Resilient	Slip Resistant
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
B	1	1220 x 2135	Solid Core	Plam	CL-02

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input checked="" type="checkbox"/> Stainless Steel	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Countertop: min. length (mm) 2400 finish Stainless Steel Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

	quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control	
Utility	1	Counter	Gooseneck	Lever Blade	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																											WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input checked="" type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	
type	quantity	size	material	finish	Hardware Group																																																
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																															
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		Countertop: <table border="1" style="width:100%; border-collapse: collapse;"><tr><td> </td><td> </td></tr></table> Washroom Vanity: <table border="1" style="width:100%; border-collapse: collapse;"><tr><td> </td><td> </td></tr></table>						Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> <table border="1" style="width:100%; border-collapse: collapse;"><tr><td> </td><td> </td></tr></table> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/> <table border="1" style="width:100%; border-collapse: collapse;"><tr><td> </td><td> </td></tr></table>																					
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																																														
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																																														
Lower Cabinets/Drawers	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																																															

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks: <table border="1" style="width:100%; border-collapse: collapse;"><tr><td> </td></tr></table>			PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		quantity	mounting type	faucet type	control type	plumbing remarks																																																																																			
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th> </th> <th> </th> <th> </th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Medical Air</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Medical Vacuum</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Nitrous Oxide</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Nitrogen</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>CO2</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Scavenging</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Laser Smoke Evac.</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.									Medical Gas Remarks: <table border="1" style="width:100%; border-collapse: collapse;"><tr><td> </td></tr></table>		
(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other																																																																																				
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <table border="1" style="width:100%; border-collapse: collapse;"><tr><td> </td></tr></table>	

VENTILATION: Relative Pressure: <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%; border-collapse: collapse;"><tr><td> </td></tr></table> Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%; border-collapse: collapse;"><tr><td> </td></tr></table>		

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2	Quad	4	Locate HK outlets at 1400mm AFF
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

- A – Active/Allocated Data Port or Data Jack
- I – Inactive/Unallocated Data Port or Data Jack
- C – Coax
- NC – Nurse Call
- PM- Patient Monitoring Outlet

- Intercom Station
- Video Intercom Station
- Overhead Paging (Pub Address)
- Teleconferencing

NURSE CALL:	quantity	
DS Duty Station	0	
MCS Full feature master control station		
EPCA Emergency Pull Cord station with Audio		
Other: <table border="1" style="width:100%; border-collapse: collapse;"><tr><td> </td></tr></table>		

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

--

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

DOORS:

type	quantity	size	material	finish	Hardware Group

Access Control Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

MILLWORK:

Upper Cabinets	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
<input type="checkbox"/>		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

Upper Cabinets	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
<input type="checkbox"/>		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Non-Skid
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	WR-03

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

MILLWORK:

Upper Cabinets	Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/> Standing Height Counter					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

Upper Cabinets	Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/> Standing Height Counter					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Lavatory	1	Wall Hung	Gooseneck	Electronic Control

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>OF-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	OF-01												
type	quantity	size	material	finish	Hardware Group																						
A	1	914 x 2135	Solid Core	Plam	OF-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																						
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	1																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	OF-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting Requirements:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>OF-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	OF-01												
type	quantity	size	material	finish	Hardware Group																						
A	1	914 x 2135	Solid Core	Plam	OF-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																						
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	1																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:
VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	OF-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	OF-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>OF-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	OF-01												
type	quantity	size	material	finish	Hardware Group																						
A	1	914 x 2135	Solid Core	Plam	OF-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																						
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	1																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling Acoustic Tile Pre-Finished Wall GWB Paint Floor Resilient Slip Resistant Base Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>C</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>OF-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	C	1	914 x 2135	Solid Core	Plam	OF-01												
type	quantity	size	material	finish	Hardware Group																						
C	1	914 x 2135	Solid Core	Plam	OF-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																						
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	1																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:
VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling Acoustic Tile Pre-Finished Wall GWB Paint Floor Resilient Slip Resistant Base Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>KP-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	KP-01												
type	quantity	size	material	finish	Hardware Group																						
A	1	914 x 2135	Solid Core	Plam	KP-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input checked="" type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>																						
Countertop: min. length (mm) finish 1800 Solid Surfacing																											
Washroom Vanity: min. length (mm) finish Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> <tr> <td>Double Bowl</td> <td>1</td> <td>Counter</td> <td>Gooseneck</td> <td>Lever Blade</td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control	Double Bowl	1	Counter	Gooseneck	Lever Blade
quantity	mounting type	faucet type	control type	plumbing remarks												
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control												
Double Bowl	1	Counter	Gooseneck	Lever Blade												
Other Fixtures: <input type="checkbox"/> Urinal: <input checked="" type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC	1	I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station	1				
Other					

IMIT Remarks:

- SECURITY SYSTEM:**
- Security Camera
 - Clinical Camera Monitor
 - Panic Duress - Wired
 - Security Camera Monitor
 - Clinical Camera
 - Infant Abduction System
 - Patient Wandering System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	KP-01

Door Hardware: Access Control

Other Features:

Sidelight
 Integral Blinds
 Security Grille
 Laser Ready Integral Blinds

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Lighting:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

Upper Cabinets	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/> Standing Height Counter

Countertop: min. length (mm) 1800 finish Solid Surfacing

Washroom Vanity: min. length (mm) finish Reception, Transaction Counter, or Care Team Station Desk: finish Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene: 1	Wall Hung	Gooseneck	Electronic Control	
Double Bowl: 1	Counter	Gooseneck	Lever Blade	

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: Acoustic Tile (material), Pre-Finished (finish) Wall: GWB (material), Paint (finish) Floor: Resilient (material), Slip Resistant (finish) Base: Rubber (material)	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>KP-01</td> </tr> </table>	type	quantity	size	material	finish	Hardware Group	A	1	1065 x 2135	Solid Core	Plam	KP-01	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:50%;"> WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator </td> <td style="width:50%;"> DOOR HARDWARE: <input checked="" type="checkbox"/> Access Control </td> <td style="width:50%;"> OTHER FEATURES: <input checked="" type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds </td> </tr> </table>	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	DOOR HARDWARE: <input checked="" type="checkbox"/> Access Control	OTHER FEATURES: <input checked="" type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds
type	quantity	size	material	finish	Hardware Group												
A	1	1065 x 2135	Solid Core	Plam	KP-01												
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	DOOR HARDWARE: <input checked="" type="checkbox"/> Access Control	OTHER FEATURES: <input checked="" type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds															
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws														

MILLWORK: Upper Cabinets: <input checked="" type="checkbox"/> Plastic Laminate Lower Cabinets/Drawers: <input checked="" type="checkbox"/> Plastic Laminate	finish: Plastic Laminate doors: <input checked="" type="checkbox"/> combination doors & open: <input checked="" type="checkbox"/> lockable: <input checked="" type="checkbox"/> adjustable shelves: <input checked="" type="checkbox"/> microwave shelf: <input type="checkbox"/>	Options: <input checked="" type="checkbox"/> Standing Height Counter	Countertop: min. length (mm) 2400, finish Plastic Laminate Washroom Vanity: _____ Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>
--	--	---	---

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks: _____	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control		OTHER FIXTURES: <input type="checkbox"/> Urinal: _____ <input type="checkbox"/> Macerator: _____ <input type="checkbox"/> Water Closet: _____ <input type="checkbox"/> Instantaneous Hot Water: _____ <input type="checkbox"/> Eye Wash: _____ <input type="checkbox"/> Emergency Shower: _____ <input type="checkbox"/> Floor Drain: _____
quantity	mounting type	faucet type	control type	plumbing remarks								
1	Wall Hung	Gooseneck	Electronic Control									

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen	1							
Medical Air	1							
Medical Vacuum	1							
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout	Room Control Remarks: BMS Monitor and Control
--	---

VENTILATION: Relative Pressure: <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: _____	Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: _____
---	---

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	2	Provide floor mounted outlets
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input checked="" type="checkbox"/> Clock	LIGHTING: <input checked="" type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input checked="" type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks: _____
---	--

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	3	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Clinical Camera Monitor	<input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Security Camera Monitor	<input type="checkbox"/> Clinical Camera <input type="checkbox"/> Infant Abduction System	<input checked="" type="checkbox"/> Patient Wandering System
---	---	--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: Ceiling: Acoustic Tile (material), Pre-Finished (finish) Wall: GWB - Moisture and Mould Resistant (material), Paint (finish) Floor: Resilient (material), Non-Skid (finish) Base: Flash Cove (material)	DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>KP-01</td> </tr> </tbody> </table>	type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	KP-01	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:50%;"> WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator </td> <td style="width:50%;"> DOOR HARDWARE: <input checked="" type="checkbox"/> Access Control </td> <td style="width:50%;"> OTHER FEATURES: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds </td> </tr> </table>	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	DOOR HARDWARE: <input checked="" type="checkbox"/> Access Control	OTHER FEATURES: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds
type	quantity	size	material	finish	Hardware Group												
A	1	914 x 2135	Solid Core	Plam	KP-01												
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	DOOR HARDWARE: <input checked="" type="checkbox"/> Access Control	OTHER FEATURES: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds															
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws														

MILLWORK: Upper Cabinets: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/>	finish: _____ doors: <input type="checkbox"/> combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/>	Options: <input type="checkbox"/> Standing Height Counter	Countertop: min. length (mm) _____ finish _____ Washroom Vanity: min. length (mm) _____ finish _____ Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish _____ Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>
--	---	--	---

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks: 10 air changes minimum	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: _____

VENTILATION: Relative Pressure: Equal Positive Negative Other: _____
 Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks: _____

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

- Intercom Station
- Video Intercom Station
- Overhead Paging (Pub Address)
- Teleconferencing

NURSE CALL:	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Non-Skid
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	WR-02

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Lighting:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) 4800 finish Solid Surfacing

Reception, Transaction Counter, or Care Team Station Desk:

Patient Wardrobe:

Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Lavatory	4	Counter	Gooseneck	Lever Blade

4 WC's & 4 Urinals

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other:	

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

IMIT Remarks: locate between toilet and sink

VENTILATION:

Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust

Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: <input type="checkbox"/> GWB - Moisture and Mould Resistant	Paint
Wall: <input type="checkbox"/> GWB - Moisture and Mould Resistant	Paint
Floor: <input type="checkbox"/> Seamless Epoxy	Non-Skid
Base: <input type="checkbox"/> Seamless Epoxy	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	WR-01

Door Hardware: Access Control

Other Features: Sidelight
 Integral Blinds
 Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets <input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers <input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: Shower

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1			
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	0
Other: <input type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other: <input type="text"/>					

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB - Moisture and Mould Resistant	Paint
Floor: Resilient	Non-Skid
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	KP-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks: 10 air changes minimum

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Non-Skid
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	WR-02

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting Legend:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) 4800, finish Solid Surfacing

Reception, Transaction Counter, or Care Team Station Desk:

Patient Wardrobe:

Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend:

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Lavatory	4	Counter	Gooseneck	Lever Blade

6 WC's

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION:

Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust

Remarks:

IMIT Remarks: locate between toilet and sink

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Paint</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Paint</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Seamless Epoxy</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Seamless Epoxy</td><td></td></tr></table>		GWB - Moisture and Mould Resistant	Paint	GWB - Moisture and Mould Resistant	Paint	Seamless Epoxy	Non-Skid	Seamless Epoxy		DOORS: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>WR-01</td> </tr> </tbody> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	WR-01
GWB - Moisture and Mould Resistant	Paint																						
GWB - Moisture and Mould Resistant	Paint																						
Seamless Epoxy	Non-Skid																						
Seamless Epoxy																							
type	quantity	size	material	finish	Hardware Group																		
A	1	914 x 2135	Solid Core	Plam	WR-01																		
WALL PROTECTION: <input type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																					
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																					
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																							

MILLWORK:		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	
Upper Cabinets	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	
Lower Cabinets/Drawers	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Countertop:	min. length (mm)	finish	Custom:	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/>					finish
Washroom Vanity:				Patient Wardrobe: <input type="checkbox"/>					
				Mail Slots: <input type="checkbox"/>					

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <input style="width:100%;" type="text"/>		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%;"><tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr><tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr></table>																					
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Shower																							

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <input style="width:100%;" type="text"/>
--

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <input style="width:100%;" type="text"/> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <input style="width:100%;" type="text"/>

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1			
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	
Telecommunication Outlets 2A/1I		
Television Outlets 1A/1C/1NC		
Patient Monitoring Outlets 2A Red Data Port		
Headwall Outlets 2PM/3A (per headwall)		

Legend;

- A – Active/Allocated Data Port or Data Jack
- I – Inactive/Unallocated Data Port or Data Jack
- C – Coax
- NC – Nurse Call
- PM- Patient Monitoring Outlet

- Intercom Station
- Video Intercom Station
- Overhead Paging (Pub Address)
- Teleconferencing

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	0
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Infant Abduction System <input checked="" type="checkbox"/> Patient Wandering System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>OF-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	OF-01												
type	quantity	size	material	finish	Hardware Group																						
A	1	914 x 2135	Solid Core	Plam	OF-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																						
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	1																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:
VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Non-Skid
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	WR-03

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Lavatory	1	Wall Hung	Gooseneck	Electronic Control

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: Shower

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	0
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>E</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CL-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	E	1	1065 x 2135	Solid Core	Plam	CL-01												
type	quantity	size	material	finish	Hardware Group																						
E	1	1065 x 2135	Solid Core	Plam	CL-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control
--

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	2	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC	1	I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																																	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	
type	quantity	size	material	finish	Hardware Group																																																						
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																																					
MILLWORK: Upper Cabinets: <input type="checkbox"/> finish: doors: <input type="checkbox"/> combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/> finish: doors: <input type="checkbox"/> combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/>		Options: <input type="checkbox"/> Standing Height Counter		Countertop: min. length (mm): 1500 finish: Solid Surfacing Washroom Vanity: min. length (mm): finish:		Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																																																					

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																					
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																							

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: <input type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

- SECURITY SYSTEM:**
- Security Camera
 - Clinical Camera Monitor
 - Panic Duress - Wired
 - Security Camera Monitor
 - Clinical Camera
 - Infant Abduction System
 - Patient Wandering System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
B	1	914 x 2135	Solid Core	Plam	PA-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets: <input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers: <input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Countertop: min. length (mm) 1500 finish Solid Surfacing

Washroom Vanity: _____

Reception, Transaction Counter, or Care Team Station Desk: Solid Surfacing

Patient Wardrobe:

Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks: _____

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: _____

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout

Room Control Remarks: _____

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust

Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Non-Skid
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	1065 x 2135	Solid Core	Plam	WR-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting Legend:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
 LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend:

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Lavatory	1	Wall Hung	Gooseneck	Electronic Control

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other: Locate EPCA between toilet and sink	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group

Door Hardware: Access Control

Other Features: Sidelight, Integral Blinds, Security Grille, Laser Ready Integral Blinds

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds, Roller Shade - Black Out, Curtain Fabric, Integral Blinds, Roller Shade - Mesh, Laser Ready Integral Blinds, Vertical Blinds, One Way Mirror, Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1, EXT-2, EXT-3, INT-1, INT-2, INT-3

ROOM ACCESSORIES:

Coat Hooks, Coat Hooks - Anti-ligature, Mirror, Mirror - Vandal Resistant, Privacy Curtain, Privacy Curtain - Anti-ligature, Shower Seat, Shower Curtain, Shower Curtain - Anti-ligature, Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler, Concealed pendant quick response sprinkler, Tamper proof screws and fittings, Vandal resistant anti-ligature plumbing fixtures, Vandal resistant tamper proof pipe and valve cover, Vandal resistant tamper proof and access panels, Security-type ventilating grille, Vandal resistant lighting fixtures and tamper resistant receptacles, Tamper resistant lighting fixtures and tamper resistant receptacles, Tamper Proof and Anti ligature Breakaway Smoke Detector Cover, Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light, Bedside Staff Light, Visitor Light, Night Light, Vanity Light, In Use Light Laser and/or X-ray, Zone Controller, Colour Tunable, Reading Light, Hand Hygiene Sink Light, Examination Light, Shower Light, Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets <input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers <input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene: 1	Wall Hung	Gooseneck	Electronic Control	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust Remarks:

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Recessed Entry Mat	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
J	1	2700 x 2135	Aluminum	Prefinished	AO-10
J	1	2700 x 2135	Aluminum	Prefinished	AO-11

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

DOORS:

type	quantity	size	material	finish	Hardware Group

Access Control Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB - Impact Resistant Washable Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																											Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	
type	quantity	size	material	finish	Hardware Group																																																
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																													
MILLWORK: Upper Cabinets <input type="checkbox"/> finish doors <input type="checkbox"/> Lower Cabinets/Drawers <input type="checkbox"/> finish doors <input type="checkbox"/> combination doors & open <input type="checkbox"/> lockable <input type="checkbox"/> adjustable shelves <input type="checkbox"/> microwave shelf <input type="checkbox"/> Options: <input type="checkbox"/> Standing Height Counter		Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																																																			

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks
 Provide specialty lighting

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																					
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																							
MEDICAL GASES: (Quantity)		Headwall 1		Headwall 2		Overhead Booms		Other															
		Nursing Side		Non-Nursing Side																			
Oxygen																							
Medical Air																							
Medical Vacuum																							
Nitrous Oxide																							
Nitrogen																							
CO2																							
Scavenging																							
Laser Smoke Evac.																							
Medical Gas Remarks:																							

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>2</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>			quantity	Telecommunication Outlets 2A/1I	2	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet																																					
	quantity																																																
Telecommunication Outlets 2A/1I	2																																																
Television Outlets 1A/1C/1NC																																																	
Patient Monitoring Outlets 2A Red Data Port																																																	
Headwall Outlets 2PM/3A (per headwall)																																																	
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>			quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:		<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																																
DS Duty Station																																																	
MCS Full feature master control station																																																	
EPCA Emergency Pull Cord station with Audio																																																	
Other:																																																	
	quantity	feature 1	feature 2	feature 3	feature 4																																												
PS: Patient Station																																																	
2/3B: 2/3 button station																																																	
4B: 4 button station (single gang)																																																	
VST: VoIP Staff Terminal/Station																																																	
Other																																																	
IMIT Remarks: Include 2 pay stations																																																	

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:	
VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:	

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	
--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																																
type	quantity	size	material	finish	Hardware Group																																																				
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																																																							
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																																						

MILLWORK:		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Countertop:	min. length (mm)	finish	Custom:	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/>		finish		
Washroom Vanity:				Patient Wardrobe: <input type="checkbox"/>			Mail Slots: <input type="checkbox"/>	

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

Provide specialty lighting

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	3	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

- Intercom Station
- Video Intercom Station
- Overhead Paging (Pub Address)
- Teleconferencing

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: Provide 2 pay phones & dedicated taxi line

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB - Impact Resistant Washable Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																											WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	
type	quantity	size	material	finish	Hardware Group																																																
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																															
MILLWORK: Upper Cabinets: <input type="checkbox"/> finish: doors: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/> finish: lockable: <input type="checkbox"/> Adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/> Options: <input type="checkbox"/> Standing Height Counter		Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																																																			

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks
 Provide specialty lighting

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																					
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																							
MEDICAL GASES: (Quantity)		Headwall 1		Headwall 2		Overhead Booms		Other															
		Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																		
Oxygen																							
Medical Air																							
Medical Vacuum																							
Nitrous Oxide																							
Nitrogen																							
CO2																							
Scavenging																							
Laser Smoke Evac.																							
Medical Gas Remarks:																							

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>			quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet																																					
	quantity																																																
Telecommunication Outlets 2A/1I	1																																																
Television Outlets 1A/1C/1NC																																																	
Patient Monitoring Outlets 2A Red Data Port																																																	
Headwall Outlets 2PM/3A (per headwall)																																																	
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>			quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:		<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td><td></td><td></td><td></td><td></td></tr> <tr> <td>2/3B: 2/3 button station</td> <td></td><td></td><td></td><td></td><td></td></tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td><td></td><td></td><td></td><td></td></tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td><td></td><td></td><td></td><td></td></tr> <tr> <td>Other</td> <td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																																
DS Duty Station																																																	
MCS Full feature master control station																																																	
EPCA Emergency Pull Cord station with Audio																																																	
Other:																																																	
	quantity	feature 1	feature 2	feature 3	feature 4																																												
PS: Patient Station																																																	
2/3B: 2/3 button station																																																	
4B: 4 button station (single gang)																																																	
VST: VoIP Staff Terminal/Station																																																	
Other																																																	
ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:		IMIT Remarks:																																															

VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other:		Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:	
---	--	---	--

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	
--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																																	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	
type	quantity	size	material	finish	Hardware Group																																																						
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																																					
MILLWORK: Upper Cabinets: <input type="checkbox"/> finish: <input type="checkbox"/> doors: <input type="checkbox"/> Lower Cabinets/Drawers: <input checked="" type="checkbox"/> Plastic Laminate <input type="checkbox"/> combination doors & open: <input checked="" type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/> Options: <input checked="" type="checkbox"/> Standing Height Counter		Countertop: min. length (mm) 3000 finish Solid Surfacing Washroom Vanity: <input type="checkbox"/> Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>		Options: <input checked="" type="checkbox"/> Standing Height Counter																																																							

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>				quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																					
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																									

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks	
General Power	Normal 1	15A/20A, 120V Housekeeping	1		
	Normal 2	Duplex	2	provide ceiling mounted outlets	
	Conditional 1				
	Conditional 2				
	Conditional 3				
	Delayed Vital				
Vital	Duplex		1		
UPS					
Boom:	Normal				
	Conditional				
	Delayed Vital				
	Vital				
	UPS				
Boom:	Normal				
	Conditional				
	Delayed Vital				
	Vital				
	UPS				
Boom:	Normal				
	Conditional				
	Delayed Vital				
	Vital				
	UPS				

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks
 Provide specialty lighting - suspended architectural

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	2
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	0
EPCA Emergency Pull Cord station with Audio	
Other: <input type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PA-01</td> </tr> </tbody> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	PA-01												
type	quantity	size	material	finish	Hardware Group																						
A	1	914 x 2135	Solid Core	Plam	PA-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																									
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																									
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws		MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table> Countertop: min. length (mm) 8000 finish Solid Surfacing Washroom Vanity: Custom: Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off

Headwall

Clock

LIGHTING:

Workstation Task Light

Bedside Staff Light

Visitor Light

Night Light

Vanity Light

In Use Light Laser and/or X-ray

Zone Controller

Colour Tunable

Reading Light

Hand Hygiene Sink Light

Examination Light

Shower Light

Circadian Lighting

lighting remarks

Provide specialty lighting - under cabinet LED cove lighting

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack

I – Inactive/Unallocated Data Port or Data Jack

C – Coax

NC – Nurse Call

PM- Patient Monitoring Outlet

Intercom Station

Video Intercom Station

Overhead Paging (Pub Address)

Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:	quantity	mounting type	faucet type	control type	plumbing remarks										
quantity	mounting type	faucet type	control type	plumbing remarks												

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	1
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PA-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	PA-01												
type	quantity	size	material	finish	Hardware Group																						
A	1	914 x 2135	Solid Core	Plam	PA-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 1500 finish Solid Surfacing Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

LIGHTING:
 Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks
 Provide specialty lighting - under cabinet LED cove lighting

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks										
quantity	mounting type	faucet type	control type	plumbing remarks												
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:
NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: Provide Fire alarm connection for security grill

SECURITY SYSTEM:
 Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CL-02</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	914 x 2135	Solid Core	Plam	CL-02												
type	quantity	size	material	finish	Hardware Group																						
B	1	914 x 2135	Solid Core	Plam	CL-02																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>																						
Countertop: min. length (mm) 1800 finish Plastic Laminate Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	2	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks										
quantity	mounting type	faucet type	control type	plumbing remarks												
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	1
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																										
type	quantity	size	material	finish	Hardware Group																																														
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																																																	
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																																

MILLWORK: finish doors combination doors & open lockable adjustable shelves microwave shelf Upper Cabinets: <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>		Options: <input checked="" type="checkbox"/> Standing Height Counter
Countertop: min. length (mm) 6000 finish Solid Surfacing Washroom Vanity: <input type="checkbox"/>	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>	

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																		
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																			

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control
--

VENTILATION: Relative Pressure: <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="checkbox"/> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	4	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input checked="" type="checkbox"/> Clock
LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>2</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td>1</td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td> </td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td> </td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	2	Television Outlets 1A/1C/1NC	1	Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input checked="" type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing
	quantity											
Telecommunication Outlets 2A/1I	2											
Television Outlets 1A/1C/1NC	1											
Patient Monitoring Outlets 2A Red Data Port												
Headwall Outlets 2PM/3A (per headwall)												

NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td> </td> </tr> <tr> <td>MCS Full feature master control station</td> <td> </td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td>1</td> </tr> <tr> <td>Other: _____</td> <td> </td> </tr> </tbody> </table>		quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio	1	Other: _____	
	quantity									
DS Duty Station										
MCS Full feature master control station										
EPCA Emergency Pull Cord station with Audio	1									
Other: _____										

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: provide ceiling or wall mounted CATV, and data for electronic display

SECURITY SYSTEM: <input checked="" type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>E</td> <td>2</td> <td>1830 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CL-10</td> </tr> <tr> <td>C</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>SR-01</td> </tr> </tbody> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	E	2	1830 x 2135	Solid Core	Plam	CL-10	C	1	1220 x 2135	Solid Core	Plam	SR-01						
type	quantity	size	material	finish	Hardware Group																						
E	2	1830 x 2135	Solid Core	Plam	CL-10																						
C	1	1220 x 2135	Solid Core	Plam	SR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																									
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																									
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws		MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table> Countertop: min. length (mm) 2400 finish Plastic Laminate Washroom Vanity: _____ Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Plastic Laminate Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																					

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	workstation outlet
	Conditional 1	Duplex	4	convenience outlets
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	ice cream and flower coolers, pop machine
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting Requirements:
 Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks
 Provide specialty lighting - LED under cabinet & cove lighting

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks: _____		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td></td> <td></td> <td></td> <td></td> <td>FD's for coolers</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>				quantity	mounting type	faucet type	control type	plumbing remarks					FD's for coolers										
quantity	mounting type	faucet type	control type	plumbing remarks																					
				FD's for coolers																					
MEDICAL GASES: (Quantity)		Headwall 1 Nursing Side Non-Nursing Side		Headwall 2 Nursing Side Non-Nursing Side		Overhead Booms _____		Other																	
Oxygen																									
Medical Air																									
Medical Vacuum																									
Nitrous Oxide																									
Nitrogen																									
CO2																									
Scavenging																									
Laser Smoke Evac.																									

Medical Gas Remarks: _____

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>3</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>			quantity	Telecommunication Outlets 2A/1I	3	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet																																					
	quantity																																																
Telecommunication Outlets 2A/1I	3																																																
Television Outlets 1A/1C/1NC																																																	
Patient Monitoring Outlets 2A Red Data Port																																																	
Headwall Outlets 2PM/3A (per headwall)																																																	
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other: _____</td> <td></td> </tr> </tbody> </table>			quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other: _____		<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																																
DS Duty Station																																																	
MCS Full feature master control station																																																	
EPCA Emergency Pull Cord station with Audio																																																	
Other: _____																																																	
	quantity	feature 1	feature 2	feature 3	feature 4																																												
PS: Patient Station																																																	
2/3B: 2/3 button station																																																	
4B: 4 button station (single gang)																																																	
VST: VoIP Staff Terminal/Station																																																	
Other																																																	

IMIT Remarks: Provide POS outlets

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: _____	
VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: _____ Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: _____	

SECURITY SYSTEM: <input checked="" type="checkbox"/> Security Camera <input checked="" type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	
--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Non-Skid Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>SR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	914 x 2135	Solid Core	Plam	SR-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	914 x 2135	Solid Core	Plam	SR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 6000 finish Solid Surfacing Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/> Solid Surfacing Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	3	provide 2 ceiling mounted outlets power/data
	Normal 2	Quad	2	workstation outlets
	Conditional 1	Duplex	5	hot water, crock pots, microwave, conv.
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	fridge, displays
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

Provide specialty lighting - LED under cabinet & cove lighting

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> <tr> <td>Double Bowl</td> <td>1</td> <td>Counter</td> <td>Gooseneck</td> <td>Lever Blade</td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control	Double Bowl	1	Counter	Gooseneck	Lever Blade
quantity	mounting type	faucet type	control type	plumbing remarks												
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control												
Double Bowl	1	Counter	Gooseneck	Lever Blade												
Other Fixtures: <input type="checkbox"/> Urinal: <input checked="" type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Grease interceptor																

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	3	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: Provide POS outlets

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB - Impact Resistant Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>2</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>SR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	2	1065 x 2135	Solid Core	Plam	SR-01												
type	quantity	size	material	finish	Hardware Group																						
A	2	1065 x 2135	Solid Core	Plam	SR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	workstation outlets
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	2	fridge freezer
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																												
quantity	mounting type	faucet type	control type	plumbing remarks																																																																														
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																																																																																		
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="2">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			Oxygen								Medical Air								Medical Vacuum								Nitrous Oxide								Nitrogen								CO2								Scavenging								Laser Smoke Evac.							
(Quantity)	Headwall 1		Headwall 2			Overhead Booms		Other																																																																										
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																														
Oxygen																																																																																		
Medical Air																																																																																		
Medical Vacuum																																																																																		
Nitrous Oxide																																																																																		
Nitrogen																																																																																		
CO2																																																																																		
Scavenging																																																																																		
Laser Smoke Evac.																																																																																		
Medical Gas Remarks:																																																																																		

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	1																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																																	WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	
type	quantity	size	material	finish	Hardware Group																																																						
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																																					
MILLWORK: Upper Cabinets: <input type="checkbox"/> finish: doors: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/> finish: doors: <input type="checkbox"/> Combination doors & open: <input type="checkbox"/> lockable: <input type="checkbox"/> adjustable shelves: <input type="checkbox"/> microwave shelf: <input type="checkbox"/> Options: <input type="checkbox"/> Standing Height Counter		Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																																																									

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																					
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																							

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control
--

VENTILATION: Relative Pressure: <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="text"/> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <input type="text"/>
--

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Quad	1	provide ceiling mounted outlets power/data
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

- Intercom Station
- Video Intercom Station
- Overhead Paging (Pub Address)
- Teleconferencing

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: <input type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: provide ceiling mounted data outlet and 2x27mmC from ceiling to security system

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>SR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	914 x 2135	Solid Core	Plam	SR-01												
type	quantity	size	material	finish	Hardware Group																						
B	1	914 x 2135	Solid Core	Plam	SR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 6000 finish Plastic Laminate Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input checked="" type="checkbox"/> Plastic Laminate																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Vital	Duplex		1
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	KP-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting Legend:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
 LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend:

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>KP-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	KP-01												
type	quantity	size	material	finish	Hardware Group																						
A	1	914 x 2135	Solid Core	Plam	KP-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2			
	Conditional 1	Duplex	2	Recessed floor boxes power/data
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																						
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>2</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	2	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input checked="" type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	2																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks: provide 1 data outlet @1500mm AFF at door entrance. Provide 1 floor mounted data outlet																																						

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:
VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>	GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>WR-01</td> </tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	WR-01
GWB	Washable																				
GWB - Moisture and Mould Resistant	Washable																				
Resilient	Non-Skid																				
Flash Cove																					
type	quantity	size	material	finish	Hardware Group																
A	1	914 x 2135	Solid Core	Plam	WR-01																
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																	

MILLWORK: Upper Cabinets: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/>	finish doors combination doors & open lockable adjustable shelves microwave shelf	Options: <input type="checkbox"/> Standing Height Counter	Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td> </td><td> </td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td> </td><td> </td></tr></table> Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>	min. length (mm)	finish			min. length (mm)	finish		
min. length (mm)	finish										
min. length (mm)	finish										

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>III</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td> </td></tr></table>	III		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> </table> Other Fixtures: <input checked="" type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input type="checkbox"/>	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Gooseneck	Electronic Control
III													
quantity	mounting type	faucet type	control type	plumbing remarks									
Lavatory	1	Wall Hung	Gooseneck	Electronic Control									

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

--

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout	Room Control Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>	

VENTILATION: Relative Pressure: <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%;"><tr><td> </td></tr></table>		Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>	

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	0	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other: <u>Locate EPCA between toilet and sink</u>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

--

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System	<input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>WR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	WR-01												
type	quantity	size	material	finish	Hardware Group																						
A	1	914 x 2135	Solid Core	Plam	WR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	1	
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: II Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> <td></td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks	1	Wall Hung	Gooseneck	Electronic Control																																																																																		
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
1	Wall Hung	Gooseneck	Electronic Control																																																																																									
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	1																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td>1</td> <td>Code Blue</td> <td>Code White</td> <td>Patient Assist</td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station	1	Code Blue	Code White	Patient Assist		4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station	1	Code Blue	Code White	Patient Assist																																		
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																																
type	quantity	size	material	finish	Hardware Group																																																				
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																																																							
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																																																						

MILLWORK:		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Countertop:	min. length (mm)	finish	Custom:	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/>		finish		
Washroom Vanity:				Patient Wardrobe: <input type="checkbox"/>			Mail Slots: <input type="checkbox"/>	

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control
--

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="text"/> Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <input type="text"/>
--

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	provide ceiling mounted outlet
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	
Telecommunication Outlets 2A/1I	2	
Television Outlets 1A/1C/1NC		
Patient Monitoring Outlets 2A Red Data Port		
Headwall Outlets 2PM/3A (per headwall)		

Legend;

- A – Active/Allocated Data Port or Data Jack
- I – Inactive/Unallocated Data Port or Data Jack
- C – Coax
- NC – Nurse Call
- PM- Patient Monitoring Outlet

- Intercom Station
- Video Intercom Station
- Overhead Paging (Pub Address)
- Teleconferencing

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Impact & Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB - Impact & Moisture and Mould Resistant	Washable	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>C</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	C	1	1220 x 2135	Solid Core	Plam	CR-01
GWB	Washable																						
GWB - Impact & Moisture and Mould Resistant	Washable																						
Resilient	Non-Skid																						
Flash Cove																							
type	quantity	size	material	finish	Hardware Group																		
C	1	1220 x 2135	Solid Core	Plam	CR-01																		
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																					
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																					
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																							

MILLWORK:		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	
Upper Cabinets	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	
Lower Cabinets/Drawers	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Countertop:	min. length (mm)	finish	Custom:	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/>					finish
Washroom Vanity:				Patient Wardrobe: <input type="checkbox"/>					
				Mail Slots: <input type="checkbox"/>					

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <input style="width:100%;" type="text"/>		PLUMBING: quantity mounting type faucet type control type plumbing remarks			
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control	
Janitorial	1	Floor	Standard	Lever Blade	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input checked="" type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input checked="" type="checkbox"/> Detergent Dispenser					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <input style="width:100%;" type="text" value="BMS Monitor and Control"/>

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <input style="width:100%;" type="text"/> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <input style="width:100%;" type="text"/>
--

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks	
General Power	Normal 1	15A/20A, 120V Housekeeping	3	Locate HK outlets at 1400mm AFF	
	Normal 2	Duplex	1	GFI	
	Conditional 1				
	Conditional 2				
	Conditional 3				
	Delayed Vital				
Vital					
UPS					
Boom:	Normal				
	Conditional				
	Delayed Vital				
	Vital				
	UPS				
Boom:	Normal				
	Conditional				
	Delayed Vital				
	Vital				
	UPS				
Boom:	Normal				
	Conditional				
	Delayed Vital				
	Vital				
	UPS				

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock	LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input checked="" type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks <input style="width:100%; height:100%;" type="text"/>
--	---

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:		quantity	
Telecommunication Outlets 2A/1I		1	
Television Outlets 1A/1C/1NC			
Patient Monitoring Outlets 2A Red Data Port			
Headwall Outlets 2PM/3A (per headwall)			

Legend;
 A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

<input type="checkbox"/> Intercom Station
<input type="checkbox"/> Video Intercom Station
<input type="checkbox"/> Overhead Paging (Pub Address)
<input type="checkbox"/> Teleconferencing

NURSE CALL:		quantity
DS Duty Station		
MCS Full feature master control station		
EPCA Emergency Pull Cord station with Audio		0
Other: <input style="width:100%;" type="text"/>		

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--



ARCHITECTURAL REQUIREMENTS

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

DOORS:

type	quantity	size	material	finish	Hardware Group

Door Hardware: Access Control
Other Features: Sidelight
 Integral Blinds
 Security Grille
 Laser Ready Integral Blinds

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf
Upper Cabinets	<input type="checkbox"/>				
Lower Cabinets/Drawers	<input type="checkbox"/>				

Options: Standing Height Counter

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	4	In-floor tamper proof box and outlets. Each box to have 2 Telecommunication Outlets.
	Normal 2	Duplex	4	
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	2	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

Lighting:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks
Lighting level will be consistent throughout the space, indirect source, and decorative.

MECHANICAL REQUIREMENTS

HVAC: Type: III
Remarks: Temp. range 20-24°; relative humidity 30-60%

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	6
Television Outlets 1A/1C/1NC	2
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend:
A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	2
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	2				
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: Provide ambient noise sensor to control paging volume based on ambient noise level.

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	PA-01

Door Hardware: Access Control

Other Features: Sidelight Integral Blinds Security Grille Laser Ready Integral Blinds

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers <input checked="" type="checkbox"/>	Plastic Laminate <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		

Countertop: min. length (mm) **1800** finish **Solid Surfacing**

Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: finish
 Patient Wardrobe:
 Mail Slots:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	Ticket counter
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks
 Provide specialty lighting - under cabinet LED cove lighting

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	2
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: **III**

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: **BMS Monitor and Control**

VENTILATION: Relative Pressure Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust Remarks:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: **Ticket Counter**

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB Washable Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																		
type	quantity	size	material	finish	Hardware Group																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 915 finish Plastic Laminate Washroom Vanity: Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Vital	Duplex		1
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																						
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th> </th> <th> </th> <th> </th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Medical Air</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Medical Vacuum</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Nitrous Oxide</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Nitrogen</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>CO2</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Scavenging</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td>Laser Smoke Evac.</td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	1																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other: _____</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other: _____																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other: _____																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks: provide nurse call connection to pneumatic tube																																						

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Washable Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group																																											WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	
type	quantity	size	material	finish	Hardware Group																																																
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																																																	
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws		Countertop: min. length (mm) 3000 finish Plastic Laminate Washroom Vanity: finish Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																									
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																																														
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter																																														
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>																																															

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																					
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																							

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	3	labelers, photo copier
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: <input type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <input type="text" value="GWB"/> <input type="text" value="Paint"/> Wall: <input type="text" value="GWB"/> <input type="text" value="Paint"/> Floor: <input type="text" value="Resilient"/> <input type="text" value="Slip Resistant"/> Base: <input type="text" value="Rubber"/>		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CL-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	914 x 2135	Solid Core	Plam	CL-01
type	quantity	size	material	finish	Hardware Group										
B	1	914 x 2135	Solid Core	Plam	CL-01										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds													
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
MILLWORK: finish doors combination doors & open lockable adjustable shelves microwave shelf Options: <input type="checkbox"/> Standing Height Counter Upper Cabinets <input type="checkbox"/> Lower Cabinets/Drawers <input type="checkbox"/> Countertop: min. length (mm) 1500 finish Plastic Laminate Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>															

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <input style="width:100%;" type="text"/>	PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: <input style="width:100%;" type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>PA-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	1	914 x 2135	Solid Core	Plam	PA-01
type	quantity	size	material	finish	Hardware Group										
B	1	914 x 2135	Solid Core	Plam	PA-01										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds													
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												

MILLWORK:		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Countertop:	min. length (mm)	finish	Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/>					
Washroom Vanity:	3000	Plastic Laminate	Patient Wardrobe: <input type="checkbox"/>					
			Mail Slots: <input type="checkbox"/>					

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																		
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																			

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control
--

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="text"/> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <input type="text"/>

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2	Duplex	1	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		2	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;	<input type="checkbox"/> Intercom Station
Telecommunication Outlets 2A/1I	2	A – Active/Allocated Data Port or Data Jack	<input type="checkbox"/> Video Intercom Station
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack	<input type="checkbox"/> Overhead Paging (Pub Address)
Patient Monitoring Outlets 2A Red Data Port		C – Coax	<input type="checkbox"/> Teleconferencing
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call	
		PM- Patient Monitoring Outlet	

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: <input type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>OF-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	OF-01												
type	quantity	size	material	finish	Hardware Group																						
A	1	914 x 2135	Solid Core	Plam	OF-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;	
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack	<input type="checkbox"/> Intercom Station
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack	<input type="checkbox"/> Video Intercom Station
Patient Monitoring Outlets 2A Red Data Port		C – Coax	<input type="checkbox"/> Overhead Paging (Pub Address)
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call	<input type="checkbox"/> Teleconferencing
		PM- Patient Monitoring Outlet	

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>2</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	B	2	914 x 2135	Solid Core	Plam	CR-01												
type	quantity	size	material	finish	Hardware Group																						
B	2	914 x 2135	Solid Core	Plam	CR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting

 lighting remarks
 MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																	
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

 Medical Gas Remarks:
 ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:
TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

- Legend;**
- A – Active/Allocated Data Port or Data Jack
 - I – Inactive/Unallocated Data Port or Data Jack
 - C – Coax
 - NC – Nurse Call
 - PM- Patient Monitoring Outlet
- Intercom Station
 - Video Intercom Station
 - Overhead Paging (Pub Address)
 - Teleconferencing

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

 IMIT Remarks:
 SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	KP-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets: <input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers: <input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Countertop: min. length (mm) **1800** finish **Solid Surfacing**

Washroom Vanity: min. length (mm) _____ finish _____

Reception, Transaction Counter, or Care Team Station Desk: finish _____

Patient Wardrobe: finish _____

Mail Slots: finish _____

MECHANICAL REQUIREMENTS

HVAC: Type: **III**

Remarks: _____

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene: 1	Wall Hung	Gooseneck	Electronic Control	
Double Bowl: 1	Counter	Gooseneck	Lever Blade	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout

Room Control Remarks: _____

VENTILATION: Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust

Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks: _____

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	1
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend:
A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB	Washable
Wall	GWB - Moisture and Mould Resistant	Washable
Floor	Resilient	Non-Skid
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	WR-03

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
1	Wall Hung	Gooseneck	Electronic Control	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>E</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	E	1	1065 x 2135	Solid Core	Plam	CR-01												
type	quantity	size	material	finish	Hardware Group																						
E	1	1065 x 2135	Solid Core	Plam	CR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Duplex	1	Printer
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																						
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>2</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td>1</td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	2	Television Outlets 1A/1C/1NC	1	Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input checked="" type="checkbox"/> Video Intercom Station <input checked="" type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	2																																					
Television Outlets 1A/1C/1NC	1																																					
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td>1</td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio	1	Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio	1																																					
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td>1</td> <td>Code Blue</td> <td>Code White</td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station	1	Code Blue	Code White			4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station	1	Code Blue	Code White																																			
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

SECURITY SYSTEM:
 Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	OF-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>OF-01</td> </tr> </tbody> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	OF-01												
type	quantity	size	material	finish	Hardware Group																						
A	1	914 x 2135	Solid Core	Plam	OF-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																									
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																									
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws		MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table> Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input checked="" type="checkbox"/> Clock LIGHTING: <input checked="" type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																			
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																					
MEDICAL GASES: (Quantity)	<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2"></th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table> Medical Gas Remarks:		Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
	Headwall 1		Headwall 2		Overhead Booms			Other																																																																																	
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																					
Oxygen																																																																																									
Medical Air																																																																																									
Medical Vacuum																																																																																									
Nitrous Oxide																																																																																									
Nitrogen																																																																																									
CO2																																																																																									
Scavenging																																																																																									
Laser Smoke Evac.																																																																																									

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table> NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table> <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table> IMIT Remarks:		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)			quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other						Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet
	quantity																																																								
Telecommunication Outlets 2A/1I	1																																																								
Television Outlets 1A/1C/1NC																																																									
Patient Monitoring Outlets 2A Red Data Port																																																									
Headwall Outlets 2PM/3A (per headwall)																																																									
	quantity																																																								
DS Duty Station																																																									
MCS Full feature master control station																																																									
EPCA Emergency Pull Cord station with Audio																																																									
Other:																																																									
	quantity	feature 1	feature 2	feature 3	feature 4																																																				
PS: Patient Station																																																									
2/3B: 2/3 button station																																																									
4B: 4 button station (single gang)																																																									
VST: VoIP Staff Terminal/Station																																																									
Other																																																									

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:
VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	Acoustic Tile	Washable
Wall	GWB - Moisture and Mould Resistant	Washable
Floor	Resilient	Slip Resistant
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Countertop: min. length (mm) 1800 finish Plastic Laminate Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Double Bowl	1	Counter	Gooseneck	Lever Blade

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	GFI
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack Intercom Station
I – Inactive/Unallocated Data Port or Data Jack Video Intercom Station
C – Coax Overhead Paging (Pub Address)
NC – Nurse Call Teleconferencing
PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
B	1	914 x 2135	Solid Core	Plam	PA-01

Access Control Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets: <input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers: <input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		

Countertop: min. length (mm) 3000 finish Plastic Laminate

Washroom Vanity: _____

Reception, Transaction Counter, or Care Team Station Desk: _____ finish _____

Patient Wardrobe: _____

Mail Slots: _____

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks: _____

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet: _____

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout

Room Control Remarks: BMS Monitor and Control

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust

Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2	Duplex	1	convenience
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		2	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

- LIGHTING:**
- Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	2
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Carpet</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Carpet	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>WR-03</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	WR-03												
GWB	Washable																																		
GWB - Moisture and Mould Resistant	Washable																																		
Carpet	Non-Skid																																		
Flash Cove																																			
type	quantity	size	material	finish	Hardware Group																														
A	1	914 x 2135	Solid Core	Plam	WR-03																														
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																																	
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																																	
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr><tr><td></td><td></td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		min. length (mm)	finish			min. length (mm)	finish			HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																												
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																												
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																													
min. length (mm)	finish																																		
min. length (mm)	finish																																		

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <div style="border: 1px solid black; height: 40px; width: 100%;"></div>	PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input type="checkbox"/>	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Gooseneck	Electronic Control
quantity	mounting type	faucet type	control type	plumbing remarks							
Lavatory	1	Wall Hung	Gooseneck	Electronic Control							

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	Acoustic Tile	Pre-Finished
Wall	GWB - Abuse Resistant	Paint
Floor	Resilient	Slip Resistant
Base:	Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
B	2	1830 x 2135	Hollow Metal	Paint	SR-10

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	6	Mount outlets at 1500mm AFF
	Normal 2	Duplex	1	
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB	Paint
Wall	GWB - Moisture and Mould Resistant	Paint
Floor	Resilient	Slip Resistant
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
C	1	1220 x 2135	Solid Core	Plam	CR-01

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2	Quad	4	provide recep. on 1 m centers mounted at 1400mm AFF
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling: **GWB** Washable

Wall: **GWB - Impact & Moisture and Mould Resistant** Washable

Floor: **Resilient** Non-Skid

Base: **Flash Cove**

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail

Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out Curtain Fabric Integral Blinds Roller Shade - Mesh Laser Ready Integral Blinds Vertical Blinds One Way Mirror Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature Mirror Mirror - Vandal Resistant Privacy Curtain Privacy Curtain - Anti-ligature Shower Seat Shower Curtain Shower Curtain - Anti-ligature Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler Concealed pendant quick response sprinkler Tamper proof screws and fittings Vandal resistant anti-ligature plumbing fixtures Vandal resistant tamper proof pipe and valve cover Vandal resistant tamper proof and access panels Security-type ventilating grille Vandal resistant lighting fixtures and tamper resistant receptacles Tamper resistant lighting fixtures and tamper resistant receptacles Tamper Proof and Anti ligature Breakaway Smoke Detector Cover Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

DOORS:

type	quantity	size	material	finish	Hardware Group
C	1	1220 x 2135	Solid Core	Plam	CR-01

Door Hardware: Access Control

Other Features: Sidelight Integral Blinds Security Grille Laser Ready Integral Blinds

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: **III** Remarks: **12 air changes minimum**

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
1	Wall Hung	Gooseneck	Electronic Control	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower Macerator: Eye Wash: Floor Drain: Water Closet: Detergent Dispenser and

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: **BMS Monitor and Control**

VENTILATION: Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust Remarks: **12 air changes**

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	3	Locate HK outlets at 1400mm AFF
	Normal 2	Duplex	1	GFI
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off

Headwall

Clock

LIGHTING:

Workstation Task Light Bedside Staff Light Visitor Light Night Light Vanity Light In Use Light Laser and/or X-ray Zone Controller Colour Tunable Reading Light Hand Hygiene Sink Light Examination Light Shower Light Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend; Intercom Station Video Intercom Station Overhead Paging (Pub Address) Teleconferencing

A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	SR-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2	Duplex	1	
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets <input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers <input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: II

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System



ARCHITECTURAL REQUIREMENTS

INTERIOR FINISHES: material finish

Ceiling: **GWB** Washable

Wall: **GWB - Impact Resistant** Washable

Floor: **Resilient** Non-Skid

Base: **Flash Cove**

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail

Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out Curtain Fabric Integral Blinds Roller Shade - Mesh Laser Ready Integral Blinds Vertical Blinds One Way Mirror Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature Mirror Mirror - Vandal Resistant Privacy Curtain Privacy Curtain - Anti-ligature Shower Seat Shower Curtain Shower Curtain - Anti-ligature Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler Concealed pendant quick response sprinkler Tamper proof screws and fittings Vandal resistant anti-ligature plumbing fixtures Vandal resistant tamper proof pipe and valve cover Vandal resistant tamper proof and access panels Security-type ventilating grille Vandal resistant lighting fixtures and tamper resistant receptacles Tamper resistant lighting fixtures and tamper resistant receptacles Tamper Proof and Anti ligature Breakaway Smoke Detector Cover Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

DOORS:

type	quantity	size	material	finish	Hardware Group
A	2	1830 x 2135	Solid Core	Plam	SR-10

Door Hardware: Access Control

Other Features: Sidelight Integral Blinds Security Grille Laser Ready Integral Blinds

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	6	Mount outlets at 1500mm AFF
	Normal 2	Duplex	1	
	Conditional 1			
	Conditional 2			
	Conditional 3			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off Headwall Clock

LIGHTING:

Workstation Task Light Bedside Staff Light Visitor Light Night Light Vanity Light In Use Light Laser and/or X-ray Zone Controller Colour Tunable Reading Light Hand Hygiene Sink Light Examination Light Shower Light Circadian Lighting

lighting remarks

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack Intercom Station

I – Inactive/Unallocated Data Port or Data Jack Video Intercom Station

C – Coax Overhead Paging (Pub Address)

NC – Nurse Call Teleconferencing

PM- Patient Monitoring Outlet

MECHANICAL REQUIREMENTS

HVAC: Type: **II**

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower Macerator: Eye Wash: Floor Drain: Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout

Room Control Remarks:

IMIT Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust

Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System

Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

DOORS:

type	quantity	size	material	finish	Hardware Group

Access Control Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	pneumatic tube
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

Booms:

Normal				
Conditional				
Delayed Vital				
Vital				
UPS				

MILLWORK:

Upper Cabinets	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input checked="" type="checkbox"/>	Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter

Countertop: min. length (mm) 915, finish Plastic Laminate

Washroom Vanity: min. length (mm) , finish Plastic Laminate

Reception, Transaction Counter, or Care Team Station Desk:

Patient Wardrobe:

Mail Slots:

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off

Headwall

Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout

Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust

Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: provide nurse call connection to pneumatic tube

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB	Washable
Wall	GWB - Impact Resistant	Washable
Floor	Resilient	Non-Skid
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
A	2	1830 x 2135	Solid Core	Plam	SR-10

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: II Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES: (Quantity)

	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	6	Mount outlets at 1500mm AFF
	Normal 2	Duplex	1	
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend; Intercom Station Video Intercom Station
A – Active/Allocated Data Port or Data Jack Overhead Paging (Pub Address)
I – Inactive/Unallocated Data Port or Data Jack Teleconferencing
C – Coax NC – Nurse Call
PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB	Washable
Wall	GWB - Impact Resistant	Washable
Floor	Resilient	Non-Skid
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
A	2	1830 x 2135	Solid Core	Plam	SR-10

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
1	Wall Hung	Gooseneck	Electronic Control	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other:
Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	6	Mount outlets at 1500mm AFF
	Normal 2	Duplex	1	
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend; Intercom Station Video Intercom Station
A – Active/Allocated Data Port or Data Jack Overhead Paging (Pub Address)
I – Inactive/Unallocated Data Port or Data Jack Teleconferencing
C – Coax NC – Nurse Call
PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: <input type="text"/>	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Washable Wall: GWB - Impact Resistant Washable Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>C</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	C	1	1220 x 2135	Solid Core	Plam	CR-01
type	quantity	size	material	finish	Hardware Group										
C	1	1220 x 2135	Solid Core	Plam	CR-01										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control													
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws													

WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																									
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>				quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																					
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																									

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								2
Medical Air								2
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control
--

VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2	Quad	6	provide recep. on 1 m centers mounted at 1400mm AFF
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:		Legend; <input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing
Telecommunication Outlets 2A/1I	quantity	1
Television Outlets 1A/1C/1NC		
Patient Monitoring Outlets 2A Red Data Port		
Headwall Outlets 2PM/3A (per headwall)		

NURSE CALL:		quantity
DS Duty Station		1
MCS Full feature master control station		
EPCA Emergency Pull Cord station with Audio		
Other:		

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>E</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CL-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	E	1	1065 x 2135	Solid Core	Plam	CL-01												
type	quantity	size	material	finish	Hardware Group																						
E	1	1065 x 2135	Solid Core	Plam	CL-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks										
quantity	mounting type	faucet type	control type	plumbing remarks												
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	2	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC	1	I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:	material	finish
Ceiling	Acoustic Tile	Pre-Finished
Wall	GWB	Paint
Floor	Resilient	Slip Resistant
Base:	Rubber	

DOORS:						
	type	quantity	size	material	finish	Hardware Group
	A	1	914 x 2135	Solid Core	Plam	PA-01
Door Hardware: <input type="checkbox"/> Access Control						
Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds						

WALL PROTECTION:		
<input checked="" type="checkbox"/> Corner Guards	<input type="checkbox"/> Hand Rails	<input type="checkbox"/> Chair Rail
<input type="checkbox"/> Crash Rails	<input checked="" type="checkbox"/> Sheet	<input type="checkbox"/> Bed Bumper / Locator

WINDOW TREATMENT:	
<input type="checkbox"/> Horizontal Blinds	<input type="checkbox"/> Roller Shade - Black Out
<input type="checkbox"/> Curtain Fabric	<input type="checkbox"/> Integral Blinds
<input type="checkbox"/> Roller Shade - Mesh	<input type="checkbox"/> Laser Ready Integral Blinds
<input type="checkbox"/> Vertical Blinds	<input type="checkbox"/> One Way Mirror
<input type="checkbox"/> Anti-Ligature	

MENTAL HEALTH GLASS TYPES:	
<input type="checkbox"/> EXT-1	<input type="checkbox"/> EXT-2
<input type="checkbox"/> EXT-3	<input type="checkbox"/> INT-1
<input type="checkbox"/> INT-2	<input type="checkbox"/> INT-3

ROOM ACCESSORIES:	
<input type="checkbox"/> Coat Hooks	<input type="checkbox"/> Mirror
<input type="checkbox"/> Coat Hooks - Anti-ligature	<input type="checkbox"/> Mirror - Vandal Resistant
<input type="checkbox"/> Privacy Curtain	<input type="checkbox"/> Privacy Curtain - Anti-ligature
<input type="checkbox"/> Shower Seat	<input type="checkbox"/> Shower Curtain
<input type="checkbox"/> Shower Curtain - Anti-ligature	<input type="checkbox"/> Ceiling IV Track

HARM PREVENTION:	
<input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler	<input checked="" type="checkbox"/> Concealed pendant quick response sprinkler
<input type="checkbox"/> Tamper proof screws and fittings	<input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures
<input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover	<input type="checkbox"/> Vandal resistant tamper proof and access panels
<input type="checkbox"/> Security-type ventilating grille	<input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles
<input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles	<input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
<input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws	

MILLWORK:							
Upper Cabinets	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Lower Cabinets/Drawers							<input type="checkbox"/> Standing Height Counter
Countertop:	min. length (mm)	finish	Custom: Reception, Transaction Counter, or Care Team Station Desk: <input checked="" type="checkbox"/>				finish
Washroom Vanity:	1500	Solid Surfacing	Patient Wardrobe: <input type="checkbox"/>				
			Mail Slots: <input type="checkbox"/>				

MECHANICAL REQUIREMENTS

HVAC:	Type: III
Remarks:	

PLUMBING:				
quantity	mounting type	faucet type	control type	plumbing remarks
Other Fixtures:				
<input type="checkbox"/> Urinal:	<input type="checkbox"/> Instantaneous Hot Water:	<input type="checkbox"/> Emergency Shower		
<input type="checkbox"/> Macerator:	<input type="checkbox"/> Eye Wash:	<input type="checkbox"/> Floor Drain:		
<input type="checkbox"/> Water Closet:				

MEDICAL GASES:	Headwall 1		Headwall 2		Overhead Booms			Other
	(Quantity)	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: _____

ROOM CONTROLS:	<input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout	<input type="checkbox"/> Room Relative Humidity with Local Readout	<input type="checkbox"/> Room Pressure Monitor with Local Readout	Room Control Remarks: _____
----------------	---	--	---	-----------------------------

VENTILATION:	Relative Pressure	<input type="checkbox"/> Equal	<input type="checkbox"/> Positive	<input checked="" type="checkbox"/> Negative	<input type="checkbox"/> Other: _____
	Exhaust Required:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	<input type="checkbox"/> Dedicated Exhaust	Remarks: _____

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting

lighting remarks

Provide specialty lighting - under cabinet LED cove lighting

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

- Legend;
- A – Active/Allocated Data Port or Data Jack
 - I – Inactive/Unallocated Data Port or Data Jack
 - C – Coax
 - NC – Nurse Call
 - PM- Patient Monitoring Outlet
- Intercom Station
 - Video Intercom Station
 - Overhead Paging (Pub Address)
 - Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	1
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: _____

SECURITY SYSTEM:

- Security Camera
- Panic Duress - Wired
- Clinical Camera
- Patient Wandering System
- Clinical Camera Monitor
- Security Camera Monitor
- Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
B	1	914 x 2135	Solid Core	Plam	CR-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Paint</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Paint</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>	GWB	Paint	GWB	Paint	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>B</td> <td>1</td> <td>1065 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>KP-01</td> </tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input checked="" type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input checked="" type="checkbox"/> Laser Ready Integral Blinds	type	quantity	size	material	finish	Hardware Group	B	1	1065 x 2135	Solid Core	Plam	KP-01
GWB	Paint																				
GWB	Paint																				
Resilient	Slip Resistant																				
Flash Cove																					
type	quantity	size	material	finish	Hardware Group																
B	1	1065 x 2135	Solid Core	Plam	KP-01																
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																				
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																				
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																					

MILLWORK: Upper Cabinets <input checked="" type="checkbox"/> Lower Cabinets/Drawers <input checked="" type="checkbox"/>	finish doors combination doors & open lockable adjustable shelves microwave shelf	Options: <input type="checkbox"/> Standing Height Counter	Countertop: <table border="1" style="width:100%;"><tr><td>2400</td><td>Solid Surfacing</td></tr></table>	2400	Solid Surfacing	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>	min. length (mm) finish Custom: finish
2400	Solid Surfacing						

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td> </td></tr></table> Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>			PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td></td> </tr> <tr> <td>Utility</td> <td>1</td> <td>Counter</td> <td></td> <td></td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>	quantity	mounting type	faucet type	control type	plumbing remarks	Hand Hygiene	1	Wall Hung	Gooseneck		Utility	1	Counter		
quantity	mounting type	faucet type	control type	plumbing remarks														
Hand Hygiene	1	Wall Hung	Gooseneck															
Utility	1	Counter																

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								2
Medical Air								2
Medical Vacuum								2
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

--

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input checked="" type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>	

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%;"><tr><td> </td></tr></table> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>		

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex headwall & 1 duplex bed
UPS	Duplex		3	2 duplex headwall & 1 duplex above bed right side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input type="checkbox"/> Clock	LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>	

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist	
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: <table border="1" style="width:100%;"><tr><td> </td></tr></table>	

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	1065 x 2135	Solid Core	Plam	CL-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex headwall & 1 duplex bed
UPS	Duplex		3	2 duplex headwall & 1 duplex above bed right side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting Requirements:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	0
Patient Monitoring Outlets 2A Red Data Port	1
Headwall Outlets 2PM/3A (per headwall)	1

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: II

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist	
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: Locate 1 x 2/3b at entrance to room c/w (code blue, code white) and 1 x 2/3b button at headwall c/w (code pink, staff assist).

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen	1	0						
Medical Air	1							
Medical Vacuum	1							
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout

Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust

Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Paint</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Paint</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Paint	GWB	Paint	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>B</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>KP-01</td> </tr> </table> Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight, <input checked="" type="checkbox"/> Integral Blinds, <input type="checkbox"/> Security Grille, <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	B	1	1220 x 2135	Solid Core	Plam	KP-01								
GWB	Paint																														
GWB	Paint																														
Resilient	Slip Resistant																														
Flash Cove																															
type	quantity	size	material	finish	Hardware Group																										
B	1	1220 x 2135	Solid Core	Plam	KP-01																										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																													
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input checked="" type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																													
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input checked="" type="checkbox"/> Plastic Laminate</td> <td><input type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> <td></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm): 1800</td><td>finish: Solid Surfacing</td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm):</td><td>finish:</td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			min. length (mm): 1800	finish: Solid Surfacing	min. length (mm):	finish:	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws	
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																								
Upper Cabinets	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																								
Lower Cabinets/Drawers	<input checked="" type="checkbox"/> Plastic Laminate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																										
min. length (mm): 1800	finish: Solid Surfacing																														
min. length (mm):	finish:																														

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	Locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		5	4 duplex headwall and 1 duplex bed
UPS	Duplex		4	3 duplex headwall and 1 duplex above bed non-nursing side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
 - Remote Power Shut-Off
 - Headwall
 - Clock
- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks
- Provide 6 zone lighting controller. Provide digital clock.

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>I</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td></td></tr></table>	I		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> <tr> <td>Utility</td> <td>1</td> <td>Counter</td> <td>Gooseneck</td> <td>Lever Blade</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>	quantity	mounting type	faucet type	control type	plumbing remarks	Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control	Utility	1	Counter	Gooseneck	Lever Blade
I																		
quantity	mounting type	faucet type	control type	plumbing remarks														
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control														
Utility	1	Counter	Gooseneck	Lever Blade														

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen	1	1						
Medical Air	1	1						
Medical Vacuum	1	1						
Nitrous Oxide	1							
Nitrogen								
CO2	1							
Scavenging	1							
Laser Smoke Evac.								

Medical Gas Remarks:

--

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

--

VENTILATION: Relative Pressure: Equal Positive Negative Other:

--

 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

Low level exhaust

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port	2	C – Coax
Headwall Outlets 2PM/3A (per headwall)	2	NC – Nurse Call PM- Patient Monitoring Outlet

NURSE CALL:	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other: _____	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist	
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

Locate patient monitoring outlets as directed by the Authority.

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
C	2	1065 x 2135	Solid Core	Plam	PA-01

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets <input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers <input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: I

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Other: 1	Wall Hung	Gooseneck	Lever Blade	Provide Scrub Sink

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum	0	0						
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	Mobile Equipment
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off

Headwall

Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White	Code Pink	Staff Assist
Other					

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets <input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter
Lower Cabinets/Drawers <input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: II Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	0
Television Outlets 1A/1C/1NC	0
Patient Monitoring Outlets 2A Red Data Port	0
Headwall Outlets 2PM/3A (per headwall)	0

Legend; Intercom Station Video Intercom Station
A – Active/Allocated Data Port or Data Jack Overhead Paging (Pub Address)
I – Inactive/Unallocated Data Port or Data Jack Teleconferencing
C – Coax NC – Nurse Call
PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group

WALL PROTECTION:

Corner Guards
 Hand Rails
 Chair Rail
 Crash Rails
 Sheet
 Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
Vital	Duplex		3	2 duplex headwall & 1 duplex bed
	Duplex		3	2 duplex headwall & 1 duplex above bed right side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting Checklist:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks
 1 hand hygiene sink light per 3 bays. Exam light wall mounted. Provide separate stretcher bay lighting controlled from care station. Separately switched down light located between bays.

MILLWORK:

Upper Cabinets	Lower Cabinets/Drawers	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/> Standing Height Counter					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	0
Patient Monitoring Outlets 2A Red Data Port	1
Headwall Outlets 2PM/3A (per headwall)	1

Legend:

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: I

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene: 1	Wall Hung	Gooseneck	Electronic Control	1 per 3 Bays

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1				
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: Provide room ready option. Nurse call dome light to annunciate green when room ready function is activated

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen	1							
Medical Air	1							
Medical Vacuum	1							
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout
 Room Relative Humidity with Local Readout
 Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust Remarks:

SECURITY SYSTEM:

Security Camera
 Panic Duress - Wired
 Clinical Camera
 Patient Wandering System
 Clinical Camera Monitor
 Security Camera Monitor
 Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB	Washable
Wall	GWB	Washable
Floor	Resilient	Slip Resistant
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
H	1	1830 x 2135	Aluminum	Prefinished	SL-02

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: I

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
1	Wall Hung	Gooseneck	Electronic Control	

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen	1	1						
Medical Air	1	1						
Medical Vacuum	1	1						
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	Locate at headwall
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex at headwall & 1 duplex for bed
UPS	Duplex		3	2 duplex at headwall & 1 duplex above bed non-nursing side
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	1
Patient Monitoring Outlets 2A Red Data Port	1
Headwall Outlets 2PM/3A (per headwall)	1

Legend; Intercom Station Video Intercom Station
A – Active/Allocated Data Port or Data Jack Overhead Paging (Pub Address)
I – Inactive/Unallocated Data Port or Data Jack Teleconferencing
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Code White	Patient Assist	
2/3B: 2/3 button station	1	Code Blue	Code White		
4B: 4 button station (single gang)	1	Code Blue	Code White	Staff Assist	
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: Provide room ready option. Nurse call dome light to annunciate green when room ready function is activated. Locate 2/3b at entrance to room

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB	Washable
Floor: Resilient	Slip Resistant
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
C	2	1065 x 2135	Solid Core	Plam	PA-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	Mobile Equipment
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: I

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White	Code Pink	Staff Assist
Other					

IMIT Remarks:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout

Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust

Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Washable
Wall: GWB	Washable
Floor: Resilient	Non-Skid
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	1065 x 2135	Solid Core	Plam	CL-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1			
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: GWB	Washable
Wall: GWB - Moisture and Mould Resistant	Washable
Floor: Resilient	Non-Skid
Base: Flash Cove	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	1065 x 2135	Solid Core	Plam	WR-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: Reception, Transaction Counter, or Care Team Station Desk:

Washroom Vanity: Patient Wardrobe:

Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Lavatory	1	Wall Hung	Gooseneck	Lever Blade

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other:

Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	1
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>B</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CR-01</td> </tr> </tbody> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	B	1	1220 x 2135	Solid Core	Plam	CR-01				
GWB	Washable																										
GWB	Washable																										
Resilient	Slip Resistant																										
Flash Cove																											
type	quantity	size	material	finish	Hardware Group																						
B	1	1220 x 2135	Solid Core	Plam	CR-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																									
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																									
MILLWORK: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table> Countertop: min. length (mm) <input type="text" value="0"/> finish <input type="text"/> Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish <input type="text"/> Washroom Vanity: <input type="text"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks:

MECHANICAL REQUIREMENTS

HVAC: Type: <input type="text" value="III"/> Remarks: <div style="border: 1px solid black; height: 50px; width: 100%;"></div>		PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>				quantity	mounting type	faucet type	control type	plumbing remarks															
quantity	mounting type	faucet type	control type	plumbing remarks																					
MEDICAL GASES: (Quantity)		Headwall 1 Nursing Side Non-Nursing Side		Headwall 2 Nursing Side Non-Nursing Side		Overhead Booms		Other																	
Oxygen																									
Medical Air																									
Medical Vacuum																									
Nitrous Oxide																									
Nitrogen																									
CO2																									
Scavenging																									
Laser Smoke Evac.																									
Medical Gas Remarks: <div style="border: 1px solid black; width: 100%; height: 20px;"></div>																									

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>			quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet																																					
	quantity																																																
Telecommunication Outlets 2A/1I	1																																																
Television Outlets 1A/1C/1NC																																																	
Patient Monitoring Outlets 2A Red Data Port																																																	
Headwall Outlets 2PM/3A (per headwall)																																																	
NURSE CALL: <table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td>1</td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other: _____</td> <td></td> </tr> </tbody> </table>			quantity	DS Duty Station	1	MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other: _____		<table border="1" style="width:100%; text-align: center;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>			quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity																																																
DS Duty Station	1																																																
MCS Full feature master control station																																																	
EPCA Emergency Pull Cord station with Audio																																																	
Other: _____																																																	
	quantity	feature 1	feature 2	feature 3	feature 4																																												
PS: Patient Station																																																	
2/3B: 2/3 button station																																																	
4B: 4 button station (single gang)																																																	
VST: VoIP Staff Terminal/Station																																																	
Other																																																	
IMIT Remarks: <div style="border: 1px solid black; width: 100%; height: 20px;"></div>																																																	

ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: BMS Monitor and Control	
VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input checked="" type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: <input type="text"/> Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <div style="border: 1px solid black; width: 100%; height: 20px;"></div>	

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System			
--	--	--	--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Slip Resistant</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>		GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Slip Resistant	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>B</td> <td>1</td> <td>1220 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>CL-02</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds		type	quantity	size	material	finish	Hardware Group	B	1	1220 x 2135	Solid Core	Plam	CL-02										
GWB	Washable																																
GWB - Moisture and Mould Resistant	Washable																																
Resilient	Slip Resistant																																
Flash Cove																																	
type	quantity	size	material	finish	Hardware Group																												
B	1	1220 x 2135	Solid Core	Plam	CL-02																												
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature																															
MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3		ROOM ACCESSORIES: <input type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track																															
HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws		MILLWORK: <table border="1" style="width:100%; text-align: center;"> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> <tr> <td>Upper Cabinets</td> <td><input checked="" type="checkbox"/> Stainless Steel</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </table> Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm): 2400</td><td>finish: Stainless Steel</td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm):</td><td>finish:</td></tr></table> Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> <table border="1" style="width:100%;"><tr><td>finish:</td></tr></table> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/> <table border="1" style="width:100%;"><tr><td>finish:</td></tr></table>			finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input checked="" type="checkbox"/> Stainless Steel	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>		min. length (mm): 2400	finish: Stainless Steel	min. length (mm):	finish:	finish:	finish:										
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																										
Upper Cabinets	<input checked="" type="checkbox"/> Stainless Steel	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																										
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																											
min. length (mm): 2400	finish: Stainless Steel																																
min. length (mm):	finish:																																
finish:																																	
finish:																																	

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	2	Locate HK outlets at 1400mm AFF
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Lighting Legend:
 Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks:

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>III</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"></table>		III	PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Hand Hygiene</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> <tr> <td>Utility</td> <td>1</td> <td>Counter</td> <td>Gooseneck</td> <td>Lever Blade</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input checked="" type="checkbox"/> Macerator: <input checked="" type="checkbox"/> Eye Wash: <input checked="" type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>		quantity	mounting type	faucet type	control type	plumbing remarks	Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control	Utility	1	Counter	Gooseneck	Lever Blade																																																																
III																																																																																			
quantity	mounting type	faucet type	control type	plumbing remarks																																																																															
Hand Hygiene	1	Wall Hung	Gooseneck	Electronic Control																																																																															
Utility	1	Counter	Gooseneck	Lever Blade																																																																															
MEDICAL GASES: <table border="1" style="width:100%; text-align: center;"> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="2">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> </tr> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </table> Medical Gas Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>		(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			Oxygen								Medical Air								Medical Vacuum								Nitrous Oxide								Nitrogen								CO2								Scavenging								Laser Smoke Evac.									ROOM CONTROLS: <input type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <table border="1" style="width:100%;"><tr><td>BMS Monitor and Control</td></tr></table>		BMS Monitor and Control
(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other																																																																												
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																															
Oxygen																																																																																			
Medical Air																																																																																			
Medical Vacuum																																																																																			
Nitrous Oxide																																																																																			
Nitrogen																																																																																			
CO2																																																																																			
Scavenging																																																																																			
Laser Smoke Evac.																																																																																			
BMS Monitor and Control																																																																																			

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I	1	A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

NURSE CALL:

	quantity
DS Duty Station	1
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

VENTILATION: Relative Pressure: <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <table border="1" style="width:100%;"><tr><td></td></tr></table> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <table border="1" style="width:100%;"><tr><td></td></tr></table>				SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System	

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>G</td> <td>1</td> <td>914 x 2135</td> <td>Aluminum</td> <td>Prefinished</td> <td>SL-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	G	1	914 x 2135	Aluminum	Prefinished	SL-01												
type	quantity	size	material	finish	Hardware Group																						
G	1	914 x 2135	Aluminum	Prefinished	SL-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) 1500 finish Plastic Laminate Washroom Vanity: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/> finish																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Vital	Duplex	1	
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																												
quantity	mounting type	faucet type	control type	plumbing remarks																																																																														
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																																																																																		
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="2">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms		Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side			Oxygen								Medical Air								Medical Vacuum								Nitrous Oxide								Nitrogen								CO2								Scavenging								Laser Smoke Evac.							
(Quantity)	Headwall 1		Headwall 2			Overhead Booms		Other																																																																										
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																														
Oxygen																																																																																		
Medical Air																																																																																		
Medical Vacuum																																																																																		
Nitrous Oxide																																																																																		
Nitrogen																																																																																		
CO2																																																																																		
Scavenging																																																																																		
Laser Smoke Evac.																																																																																		
Medical Gas Remarks:																																																																																		

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	1																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks: BMS Monitor and Control

VENTILATION: Relative Pressure Equal Positive Negative Other:
 Exhaust Required: Yes No Dedicated Exhaust
 Remarks:

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	KP-01

Access Control Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	3	
	Normal 2			
	Conditional 1	Duplex	2	Recessed floor boxes power/data
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		1	
UPS				

Lighting:

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	2
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)	1	Code Blue	Code White	Code Pink	
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks: provide floor mounted outlets. Provide 1 data at entrance to room mounted at 1500mm AFF

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								1
Medical Air								1
Medical Vacuum								1
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout
 Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: _____

Exhaust Required: Yes No Dedicated Exhaust Remarks: _____

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB Paint Floor: Resilient Slip Resistant Base: Rubber		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>OF-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	OF-01												
type	quantity	size	material	finish	Hardware Group																						
A	1	914 x 2135	Solid Core	Plam	OF-01																						
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input checked="" type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		DOOR HARDWARE: <input type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds																									
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input checked="" type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																								
MILLWORK: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>finish</th> <th>doors</th> <th>combination doors & open</th> <th>lockable</th> <th>adjustable shelves</th> <th>microwave shelf</th> <th>Options:</th> </tr> </thead> <tbody> <tr> <td>Upper Cabinets</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/> Standing Height Counter</td> </tr> <tr> <td>Lower Cabinets/Drawers</td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td><input type="checkbox"/></td> <td></td> </tr> </tbody> </table>					finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	Upper Cabinets	<input type="checkbox"/> Standing Height Counter	Lower Cabinets/Drawers	<input type="checkbox"/>												
	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:																				
Upper Cabinets	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter																				
Lower Cabinets/Drawers	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																					
Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> finish Washroom Vanity: Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>																											

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock
LIGHTING:
 Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting
 lighting remarks

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks:	PLUMBING: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	quantity	mounting type	faucet type	control type	plumbing remarks																																																																																						
quantity	mounting type	faucet type	control type	plumbing remarks																																																																																								
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet:																																																																																												
MEDICAL GASES: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">(Quantity)</th> <th colspan="2">Headwall 1</th> <th colspan="2">Headwall 2</th> <th colspan="3">Overhead Booms</th> <th rowspan="2">Other</th> </tr> <tr> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th>Nursing Side</th> <th>Non-Nursing Side</th> <th></th> <th></th> <th></th> </tr> </thead> <tbody> <tr><td>Oxygen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Air</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Medical Vacuum</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrous Oxide</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Nitrogen</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>CO2</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Scavenging</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Laser Smoke Evac.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </tbody> </table>					(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				Oxygen									Medical Air									Medical Vacuum									Nitrous Oxide									Nitrogen									CO2									Scavenging									Laser Smoke Evac.								
(Quantity)	Headwall 1		Headwall 2			Overhead Booms			Other																																																																																			
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side																																																																																								
Oxygen																																																																																												
Medical Air																																																																																												
Medical Vacuum																																																																																												
Nitrous Oxide																																																																																												
Nitrogen																																																																																												
CO2																																																																																												
Scavenging																																																																																												
Laser Smoke Evac.																																																																																												
Medical Gas Remarks:																																																																																												

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Telecommunication Outlets 2A/1I</td> <td>1</td> </tr> <tr> <td>Television Outlets 1A/1C/1NC</td> <td></td> </tr> <tr> <td>Patient Monitoring Outlets 2A Red Data Port</td> <td></td> </tr> <tr> <td>Headwall Outlets 2PM/3A (per headwall)</td> <td></td> </tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I	1	Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing																										
	quantity																																					
Telecommunication Outlets 2A/1I	1																																					
Television Outlets 1A/1C/1NC																																						
Patient Monitoring Outlets 2A Red Data Port																																						
Headwall Outlets 2PM/3A (per headwall)																																						
NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>DS Duty Station</td> <td></td> </tr> <tr> <td>MCS Full feature master control station</td> <td></td> </tr> <tr> <td>EPCA Emergency Pull Cord station with Audio</td> <td></td> </tr> <tr> <td>Other:</td> <td></td> </tr> </tbody> </table>				quantity	DS Duty Station		MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other:																											
	quantity																																					
DS Duty Station																																						
MCS Full feature master control station																																						
EPCA Emergency Pull Cord station with Audio																																						
Other:																																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>quantity</th> <th>feature 1</th> <th>feature 2</th> <th>feature 3</th> <th>feature 4</th> </tr> </thead> <tbody> <tr> <td>PS: Patient Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2/3B: 2/3 button station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4B: 4 button station (single gang)</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>VST: VoIP Staff Terminal/Station</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Other</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				quantity	feature 1	feature 2	feature 3	feature 4	PS: Patient Station						2/3B: 2/3 button station						4B: 4 button station (single gang)						VST: VoIP Staff Terminal/Station						Other					
	quantity	feature 1	feature 2	feature 3	feature 4																																	
PS: Patient Station																																						
2/3B: 2/3 button station																																						
4B: 4 button station (single gang)																																						
VST: VoIP Staff Terminal/Station																																						
Other																																						
IMIT Remarks:																																						

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks:
VENTILATION: Relative Pressure <input checked="" type="checkbox"/> Equal <input type="checkbox"/> Positive <input type="checkbox"/> Negative <input type="checkbox"/> Other: Exhaust Required: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Clinical Camera <input checked="" type="checkbox"/> Patient Wandering System <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
A	1	914 x 2135	Solid Core	Plam	OF-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES:

material	finish
Ceiling: Acoustic Tile	Pre-Finished
Wall: GWB	Paint
Floor: Resilient	Slip Resistant
Base: Rubber	

DOORS:

type	quantity	size	material	finish	Hardware Group
B	1	914 x 2135	Solid Core	Plam	OF-01

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

WINDOW TREATMENT:

Horizontal Blinds
 Roller Shade - Black Out
 Curtain Fabric
 Integral Blinds
 Roller Shade - Mesh
 Laser Ready Integral Blinds
 Vertical Blinds
 One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1
 EXT-2
 EXT-3
 INT-1
 INT-2
 INT-3

ROOM ACCESSORIES:

Coat Hooks
 Coat Hooks - Anti-ligature
 Mirror
 Mirror - Vandal Resistant
 Privacy Curtain
 Privacy Curtain - Anti-ligature
 Shower Seat
 Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	1	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32

Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks

MILLWORK:

finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter					
Lower Cabinets/Drawers	<input type="checkbox"/>					

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish

Washroom Vanity: Patient Wardrobe: Mail Slots:

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	1
Television Outlets 1A/1C/1NC	
Patient Monitoring Outlets 2A Red Data Port	
Headwall Outlets 2PM/3A (per headwall)	

Legend;

A – Active/Allocated Data Port or Data Jack
 I – Inactive/Unallocated Data Port or Data Jack
 C – Coax
 NC – Nurse Call
 PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

MECHANICAL REQUIREMENTS

HVAC: Type: III

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks

Other Fixtures:

Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	1
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS:

Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION:

Relative Pressure: Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

IMIT Remarks:

SECURITY SYSTEM:

Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: Acoustic Tile Pre-Finished Wall: GWB - Moisture and Mould Resistant Paint Floor: Resilient Non-Skid Base: Flash Cove		DOORS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>KP-01</td> </tr> </tbody> </table>		type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	KP-01
type	quantity	size	material	finish	Hardware Group										
A	1	914 x 2135	Solid Core	Plam	KP-01										
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator		Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds													
WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input checked="" type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws												

MILLWORK:		finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:	
Upper Cabinets	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> Standing Height Counter	
Lower Cabinets/Drawers	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Countertop:	min. length (mm)	finish	Custom:	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/>					finish
Washroom Vanity:				Patient Wardrobe: <input type="checkbox"/>					
				Mail Slots: <input type="checkbox"/>					

MECHANICAL REQUIREMENTS

HVAC: Type: III Remarks: 10 air changes per hour	PLUMBING: quantity mounting type faucet type control type plumbing remarks <table border="1" style="width:100%; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </table>																		
Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input type="checkbox"/> Water Closet: <input type="checkbox"/>																			

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

ROOM CONTROLS: <input checked="" type="checkbox"/> Room Temp Control with Local Adjustment and Readout <input type="checkbox"/> Room Relative Humidity with Local Readout <input type="checkbox"/> Room Pressure Monitor with Local Readout Room Control Remarks: <input style="width:100%;" type="text"/>
--

VENTILATION: Relative Pressure <input type="checkbox"/> Equal <input type="checkbox"/> Positive <input checked="" type="checkbox"/> Negative <input type="checkbox"/> Other: <input style="width:100%;" type="text"/> Exhaust Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Dedicated Exhaust Remarks: <input style="width:100%;" type="text"/>

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2			
	Conditional 1	Duplex	2	
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

<input type="checkbox"/> Patient Care Area Designation as per CSA Z32 <input type="checkbox"/> Remote Power Shut-Off <input type="checkbox"/> Headwall <input checked="" type="checkbox"/> Clock
LIGHTING: <input type="checkbox"/> Workstation Task Light <input type="checkbox"/> Bedside Staff Light <input type="checkbox"/> Visitor Light <input type="checkbox"/> Night Light <input type="checkbox"/> Vanity Light <input type="checkbox"/> In Use Light Laser and/or X-ray <input type="checkbox"/> Zone Controller <input type="checkbox"/> Colour Tunable <input type="checkbox"/> Reading Light <input type="checkbox"/> Hand Hygiene Sink Light <input type="checkbox"/> Examination Light <input type="checkbox"/> Shower Light <input type="checkbox"/> Circadian Lighting lighting remarks: <input style="width:100%; height:100%;" type="text"/>

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr><td>Telecommunication Outlets 2A/1I</td><td> </td></tr> <tr><td>Television Outlets 1A/1C/1NC</td><td> </td></tr> <tr><td>Patient Monitoring Outlets 2A Red Data Port</td><td> </td></tr> <tr><td>Headwall Outlets 2PM/3A (per headwall)</td><td> </td></tr> </tbody> </table>		quantity	Telecommunication Outlets 2A/1I		Television Outlets 1A/1C/1NC		Patient Monitoring Outlets 2A Red Data Port		Headwall Outlets 2PM/3A (per headwall)		Legend; A – Active/Allocated Data Port or Data Jack I – Inactive/Unallocated Data Port or Data Jack C – Coax NC – Nurse Call PM- Patient Monitoring Outlet	<input type="checkbox"/> Intercom Station <input type="checkbox"/> Video Intercom Station <input checked="" type="checkbox"/> Overhead Paging (Pub Address) <input type="checkbox"/> Teleconferencing
	quantity											
Telecommunication Outlets 2A/1I												
Television Outlets 1A/1C/1NC												
Patient Monitoring Outlets 2A Red Data Port												
Headwall Outlets 2PM/3A (per headwall)												

NURSE CALL: <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th> </th> <th>quantity</th> </tr> </thead> <tbody> <tr><td>DS Duty Station</td><td>1</td></tr> <tr><td>MCS Full feature master control station</td><td> </td></tr> <tr><td>EPCA Emergency Pull Cord station with Audio</td><td> </td></tr> <tr><td>Other: <input style="width:100%;" type="text"/></td><td> </td></tr> </tbody> </table>		quantity	DS Duty Station	1	MCS Full feature master control station		EPCA Emergency Pull Cord station with Audio		Other: <input style="width:100%;" type="text"/>	
	quantity									
DS Duty Station	1									
MCS Full feature master control station										
EPCA Emergency Pull Cord station with Audio										
Other: <input style="width:100%;" type="text"/>										

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

SECURITY SYSTEM: <input type="checkbox"/> Security Camera <input type="checkbox"/> Clinical Camera Monitor <input type="checkbox"/> Panic Duress - Wired <input type="checkbox"/> Security Camera Monitor <input type="checkbox"/> Clinical Camera <input type="checkbox"/> Infant Abduction System <input checked="" type="checkbox"/> Patient Wandering System
--

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish Ceiling: <table border="1" style="width:100%;"><tr><td>GWB</td><td>Washable</td></tr></table> Wall: <table border="1" style="width:100%;"><tr><td>GWB - Moisture and Mould Resistant</td><td>Washable</td></tr></table> Floor: <table border="1" style="width:100%;"><tr><td>Resilient</td><td>Non-Skid</td></tr></table> Base: <table border="1" style="width:100%;"><tr><td>Flash Cove</td><td></td></tr></table>	GWB	Washable	GWB - Moisture and Mould Resistant	Washable	Resilient	Non-Skid	Flash Cove		DOORS: <table border="1" style="width:100%; text-align: center;"> <tr> <th>type</th> <th>quantity</th> <th>size</th> <th>material</th> <th>finish</th> <th>Hardware Group</th> </tr> <tr> <td>A</td> <td>1</td> <td>914 x 2135</td> <td>Solid Core</td> <td>Plam</td> <td>WR-03</td> </tr> </table> Door Hardware: <input checked="" type="checkbox"/> Access Control Other Features: <input type="checkbox"/> Sidelight <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Security Grille <input type="checkbox"/> Laser Ready Integral Blinds	type	quantity	size	material	finish	Hardware Group	A	1	914 x 2135	Solid Core	Plam	WR-03
GWB	Washable																				
GWB - Moisture and Mould Resistant	Washable																				
Resilient	Non-Skid																				
Flash Cove																					
type	quantity	size	material	finish	Hardware Group																
A	1	914 x 2135	Solid Core	Plam	WR-03																
WALL PROTECTION: <input checked="" type="checkbox"/> Corner Guards <input type="checkbox"/> Hand Rails <input type="checkbox"/> Chair Rail <input type="checkbox"/> Crash Rails <input checked="" type="checkbox"/> Sheet <input type="checkbox"/> Bed Bumper / Locator	WINDOW TREATMENT: <input type="checkbox"/> Horizontal Blinds <input type="checkbox"/> Roller Shade - Black Out <input type="checkbox"/> Curtain Fabric <input type="checkbox"/> Integral Blinds <input type="checkbox"/> Roller Shade - Mesh <input type="checkbox"/> Laser Ready Integral Blinds <input type="checkbox"/> Vertical Blinds <input type="checkbox"/> One Way Mirror <input type="checkbox"/> Anti-Ligature	MENTAL HEALTH GLASS TYPES: <input type="checkbox"/> EXT-1 <input type="checkbox"/> EXT-2 <input type="checkbox"/> EXT-3 <input type="checkbox"/> INT-1 <input type="checkbox"/> INT-2 <input type="checkbox"/> INT-3	ROOM ACCESSORIES: <input checked="" type="checkbox"/> Coat Hooks <input type="checkbox"/> Coat Hooks - Anti-ligature <input type="checkbox"/> Mirror <input type="checkbox"/> Mirror - Vandal Resistant <input type="checkbox"/> Privacy Curtain <input type="checkbox"/> Privacy Curtain - Anti-ligature <input type="checkbox"/> Shower Seat <input type="checkbox"/> Shower Curtain <input type="checkbox"/> Shower Curtain - Anti-ligature <input type="checkbox"/> Ceiling IV Track	HARM PREVENTION: <input type="checkbox"/> Industrial anti-ligature tamper-resistant sprinkler <input checked="" type="checkbox"/> Concealed pendant quick response sprinkler <input type="checkbox"/> Tamper proof screws and fittings <input type="checkbox"/> Vandal resistant anti-ligature plumbing fixtures <input type="checkbox"/> Vandal resistant tamper proof pipe and valve cover <input type="checkbox"/> Vandal resistant tamper proof and access panels <input type="checkbox"/> Security-type ventilating grille <input type="checkbox"/> Vandal resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper resistant lighting fixtures and tamper resistant receptacles <input type="checkbox"/> Tamper Proof and Anti ligature Breakaway Smoke Detector Cover <input type="checkbox"/> Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws																	

MILLWORK: Upper Cabinets: <input type="checkbox"/> Lower Cabinets/Drawers: <input type="checkbox"/>	finish doors combination doors & open lockable adjustable shelves microwave shelf	Options: <input type="checkbox"/> Standing Height Counter	Countertop: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr></table> Washroom Vanity: <table border="1" style="width:100%;"><tr><td>min. length (mm)</td><td>finish</td></tr></table>	min. length (mm)	finish	min. length (mm)	finish	Reception, Transaction Counter, or Care Team Station Desk: <input type="checkbox"/> Patient Wardrobe: <input type="checkbox"/> Mail Slots: <input type="checkbox"/>
min. length (mm)	finish							
min. length (mm)	finish							

MECHANICAL REQUIREMENTS

HVAC: Type: <table border="1" style="width:100%;"><tr><td>III</td></tr></table> Remarks: <table border="1" style="width:100%; height: 50px;"><tr><td></td></tr></table>	III		PLUMBING: <table border="1" style="width:100%; text-align: center;"> <tr> <th>quantity</th> <th>mounting type</th> <th>faucet type</th> <th>control type</th> <th>plumbing remarks</th> </tr> <tr> <td>Lavatory</td> <td>1</td> <td>Wall Hung</td> <td>Gooseneck</td> <td>Electronic Control</td> </tr> </table> Other Fixtures: <input type="checkbox"/> Urinal: <input type="checkbox"/> Instantaneous Hot Water: <input type="checkbox"/> Emergency Shower <input type="checkbox"/> Macerator: <input type="checkbox"/> Eye Wash: <input type="checkbox"/> Floor Drain: <input checked="" type="checkbox"/> Water Closet: <input type="checkbox"/>	quantity	mounting type	faucet type	control type	plumbing remarks	Lavatory	1	Wall Hung	Gooseneck	Electronic Control
III													
quantity	mounting type	faucet type	control type	plumbing remarks									
Lavatory	1	Wall Hung	Gooseneck	Electronic Control									

MEDICAL GASES: (Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen								
Medical Air								
Medical Vacuum								
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks:

--

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

--

VENTILATION: Relative Pressure: Equal Positive Negative Other:

--

 Exhaust Required: Yes No Dedicated Exhaust Remarks:

--

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	Duplex	1	GFI
	Normal 2			
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital				
UPS				
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

- Patient Care Area Designation as per CSA Z32
- Remote Power Shut-Off
- Headwall
- Clock

- LIGHTING:**
- Workstation Task Light
 - Bedside Staff Light
 - Visitor Light
 - Night Light
 - Vanity Light
 - In Use Light Laser and/or X-ray
 - Zone Controller
 - Colour Tunable
 - Reading Light
 - Hand Hygiene Sink Light
 - Examination Light
 - Shower Light
 - Circadian Lighting
- lighting remarks:

--

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:	quantity	Legend;
Telecommunication Outlets 2A/1I		A – Active/Allocated Data Port or Data Jack
Television Outlets 1A/1C/1NC		I – Inactive/Unallocated Data Port or Data Jack
Patient Monitoring Outlets 2A Red Data Port		C – Coax
Headwall Outlets 2PM/3A (per headwall)		NC – Nurse Call
		PM- Patient Monitoring Outlet

- Intercom Station
- Video Intercom Station
- Overhead Paging (Pub Address)
- Teleconferencing

NURSE CALL:	quantity	
DS Duty Station		
MCS Full feature master control station		
EPCA Emergency Pull Cord station with Audio		
Other: <table border="1" style="width:100%;"><tr><td></td></tr></table>		

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station					
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station					
Other					

IMIT Remarks:

--

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System

**ARCHITECTURAL REQUIREMENTS**

INTERIOR FINISHES: material finish

Ceiling	GWB - Lead Lined	Washable
Wall	GWB - Lead Lined	Washable
Floor	Seamless Epoxy	Anti-static
Base:	Flash Cove	

WALL PROTECTION:

Corner Guards Hand Rails Chair Rail
 Crash Rails Sheet Bed Bumper / Locator

DOORS:

type	quantity	size	material	finish	Hardware Group
F	1	1830 x 2135	Solid Core	Plam	OR-10
B	1	1220 x 2135	Solid Core	Plam	OR-01

Door Hardware: Access Control Other Features: Sidelight
 Integral Blinds Security Grille
 Laser Ready Integral Blinds

WINDOW TREATMENT:

Horizontal Blinds Roller Shade - Black Out
 Curtain Fabric Integral Blinds
 Roller Shade - Mesh Laser Ready Integral Blinds
 Vertical Blinds One Way Mirror
 Anti-Ligature

MENTAL HEALTH GLASS TYPES:

EXT-1 EXT-2 EXT-3
 INT-1 INT-2 INT-3

ROOM ACCESSORIES:

Coat Hooks Coat Hooks - Anti-ligature
 Mirror Mirror - Vandal Resistant
 Privacy Curtain Privacy Curtain - Anti-ligature
 Shower Seat Shower Curtain
 Shower Curtain - Anti-ligature
 Ceiling IV Track

HARM PREVENTION:

Industrial anti-ligature tamper-resistant sprinkler
 Concealed pendant quick response sprinkler
 Tamper proof screws and fittings
 Vandal resistant anti-ligature plumbing fixtures
 Vandal resistant tamper proof pipe and valve cover
 Vandal resistant tamper proof and access panels
 Security-type ventilating grille
 Vandal resistant lighting fixtures and tamper resistant receptacles
 Tamper resistant lighting fixtures and tamper resistant receptacles
 Tamper Proof and Anti ligature Breakaway Smoke Detector Cover
 Electrical Cover Plate Extra Heavy Duty with Tamper Proof Screws

MILLWORK:

	finish	doors	combination doors & open	lockable	adjustable shelves	microwave shelf	Options:
Upper Cabinets	<input type="checkbox"/> Standing Height Counter						
Lower Cabinets/Drawers	<input type="checkbox"/>						

Countertop: min. length (mm) finish Custom: Reception, Transaction Counter, or Care Team Station Desk: finish
Washroom Vanity: Patient Wardrobe: Mail Slots:

MECHANICAL REQUIREMENTS

HVAC: Type: I

Remarks:

PLUMBING:

quantity	mounting type	faucet type	control type	plumbing remarks
Hand Hygiene	2	Wall Hung	Gooseneck	Electronic Control

Other Fixtures: Urinal: Instantaneous Hot Water: Emergency Shower
 Macerator: Eye Wash: Floor Drain:
 Water Closet:

MEDICAL GASES:

(Quantity)	Headwall 1		Headwall 2		Overhead Booms			Other
	Nursing Side	Non-Nursing Side	Nursing Side	Non-Nursing Side				
Oxygen	2							
Medical Air	1							
Medical Vacuum	2							
Nitrous Oxide								
Nitrogen								
CO2								
Scavenging								
Laser Smoke Evac.								

Medical Gas Remarks: Quantities listed are per stretcher bay.

ROOM CONTROLS: Room Temp Control with Local Adjustment and Readout Room Relative Humidity with Local Readout Room Pressure Monitor with Local Readout Room Control Remarks:

VENTILATION: Relative Pressure Equal Positive Negative Other: Exhaust Required: Yes No Dedicated Exhaust Remarks:

ELECTRICAL REQUIREMENTS

location	power type	receptacle type	quantity	remarks
General Power	Normal 1	15A/20A, 120V Housekeeping	1	
	Normal 2	Quad	1	locate at column
	Conditional 1			
	Conditional 2			
	Conditional 3			
	Delayed Vital			
Vital	Duplex		3	2 duplex column & 1 duplex for bed
	Duplex		3	2 duplex column & 1 duplex above column for monitor
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			
Boom:	Normal			
	Conditional			
	Delayed Vital			
	Vital			
	UPS			

Patient Care Area Designation as per CSA Z32
 Remote Power Shut-Off
 Headwall
 Clock

LIGHTING:

Workstation Task Light
 Bedside Staff Light
 Visitor Light
 Night Light
 Vanity Light
 In Use Light Laser and/or X-ray
 Zone Controller
 Colour Tunable
 Reading Light
 Hand Hygiene Sink Light
 Examination Light
 Shower Light
 Circadian Lighting

lighting remarks
Provide a separately switched down light located between bays for charting

TECHNOLOGY REQUIREMENTS

IMIT SYSTEMS:

	quantity
Telecommunication Outlets 2A/1I	2
Television Outlets 1A/1C/1NC	0
Patient Monitoring Outlets 2A Red Data Port	1
Headwall Outlets 2PM/3A (per headwall)	0

Legend;
A – Active/Allocated Data Port or Data Jack
I – Inactive/Unallocated Data Port or Data Jack
C – Coax
NC – Nurse Call
PM- Patient Monitoring Outlet

Intercom Station
 Video Intercom Station
 Overhead Paging (Pub Address)
 Teleconferencing

NURSE CALL:

	quantity
DS Duty Station	
MCS Full feature master control station	
EPCA Emergency Pull Cord station with Audio	
Other:	

	quantity	feature 1	feature 2	feature 3	feature 4
PS: Patient Station	1	Code Blue	Code White	Patient Assist	
2/3B: 2/3 button station					
4B: 4 button station (single gang)					
VST: VoIP Staff Terminal/Station	1	Code Blue	Code White	Code Pink	Staff Assist
Other					

IMIT Remarks: Locate VST on front of column (staff). Locate P.S. Patient station on patient side of column (patient)

SECURITY SYSTEM: Security Camera Panic Duress - Wired Clinical Camera Patient Wandering System
 Clinical Camera Monitor Security Camera Monitor Infant Abduction System